

**WATER SUPPLY INSPECTION REPORT**

<b>Facility Name</b> DASSA MCKINNEY ELEM SCHOOL	<b>PWSID No</b> 5100316	<b>Inspection Date</b> 2020-04-22
<b>Facility Location</b> 391 HOOKER ROAD WEST SUNBURY PA 16061	<b>County</b> Butler	<b>Municipality</b> Clay
<b>Responsible Officials Name</b> ARNEY SUPERINTENDENT SEAN	<b>Telephone:</b> (724) 637-2117	
	<b>SystemType:</b> NonTransient NonCommunity	<b>Population:</b> 590
<b>Certified Operator name</b> ----	<b>Field Order Number:</b> ----	
	<b>Issue Date(mm/dd/yy):</b> ----	

**Person(s) Interviewed**

**Name:** JEFFREY CAMPBELL

**Title:** BUILDINGDIRECTOR

**eFACTS info**

**Inspection ID:** 3022347

**Inspection Type:** RTPT

**General Comments**

Spoke via telephone with Jeffrey Campbell, Director of Buildings and Grounds. Per Mr. Campbell, the school's water treatment system remains in operation and has not shut down despite the cessation of school functions due to the COVID-19 pandemic. Essential staff continue to visit the building on an as-needed basis and lunches are provided to those students who request them. These lunches usually consist of fruit and pre-packaged snacks that do not involve preparation. They will continue to monitor the water quality as per their monitoring calendar and inform the Department if the school shuts down at any point.

**Signatures**

Received by(Print Name):

JEFFREY CAMPBELL

Unable To Receive Signature:

Completed remotely

Investigator (Print Name):

ZANE BARGER

**WATER SUPPLY INSPECTION REPORT**

<b>Facility Name</b> MONITEAU JR/SR HIGH SCHOOL	<b>PWSID No</b> 5100324	<b>Inspection Date</b> 2020-04-28
<b>Facility Location</b> 1810 WEST SUNBURY ROAD WEST SUNBURY PA 16061	<b>County</b> Butler	<b>Municipality</b> Cherry
<b>Responsible Officials Name</b> ARNEY SEAN	<b>Telephone:</b> (724) 637-2117	
	<b>SystemType:</b> NonTransient NonCommunity	<b>Population:</b> 600
<b>Certified Operator name</b> ----	<b>Field Order Number:</b> ----	
	<b>Issue Date(mm/dd/yy):</b> ----	

**eFACTS info**

**Inspection ID:** 3024778

**Inspection Type:** RTPT

**General Comments**

Discussed the status of the school with Mr. Jeff Campbell (operator). Currently, the school is closed to the public however, there is construction taking place in the school, at this time. The PWS and Environmental Service Lab continues to monitor the water as if the school were open. The school shares information about water sampling on it's webpage, to inform the public about the school's water production. The PWS currently has an estimated 30-days worth of chemicals on-hand, but could last longer due to lower population. Jeff stated during this time while the school is closed that the day tanks are being cleaned as they empty. Standard operating procedure have been updated/revised. In the case of an emergency the PWS has several operators that can assist with the PWS, if needed.

**Reminders:**

1. Should you need to contact the Department please contact myself at aoleski@pa.gov or 814.521.8054 or Sanitarian supervisor Kyle Smith at kyasmit@pa.gov or 814.332.6107.
2. Nitrate/nitrite samples are due in 2nd or 3rd quarter.

Signatures

Received by(Print Name): ----	Unable To Receive Signature: Report completed offsite
Investigator (Print Name): ANDREW OLESKI	