

**Moniteau School District
Maintenance Department
Moniteau High School
Monthly Operations Report
Wastewater DMR Test Results
April 2022**



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Wed, May 4, 2022 at 3:41 PM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 04/01/2022-04/30/2022
Report Due Date: 05/28/2022

Submitted By: Jeffrey Campbell
Submission Id: 327809
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 04/01/2022
 DMR Effective To: 04/30/2022
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2022	04	01	2022	04	30

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		6.51	***		1/week
	PERMIT REQUIREMENT	***		4.0 Min	***	mg/L	1/week
pH (00400)	SAMPLE MEASUREMENT	***		7.18	***	8.70	1/week
	PERMIT REQUIREMENT	***		6.0 Min	***	9.0 Max	1/week
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***	***	5.0	2/month
	PERMIT REQUIREMENT	***		***	***	30 Avg Mo	2/month
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		***	***	8.41	2/month
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	2/month
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		***	***	.70	2/month
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	2/month
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	***	4.87	1/week
	PERMIT REQUIREMENT	***		***	***	Monitor & Report Avg Mo	1/week
Flow (50050)	SAMPLE MEASUREMENT	.0056	MGD	***	***	***	1/week
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	***	1/week

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		<1.0	<1.0		No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***		2000	10000	IM/AX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		<2.00	***			2/month	Grab
	PERMIT REQUIREMENT	***	***		25	***		mg/L	2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------


Moniteau School District
Moniteau High School
WASTE WATER TREATMENT FACILITY
Monthly Operations Report
April 2022


Flow	$168,028 \div 30 = 5,600$ Daily Avg.
UV	$121.7 \div 25 = 4.868$
TOTAL Nitrogen	$16.1 + < 0.729 = 16.829 \div 2 = 8.41$
TSS	$5 + < 5 = 10 \div 2 = 5$
TKN	$5.03 + < 0.625 = 5.655 \div 2 = 2.82$
Nitrite / Nitrate	$11.1 + 0.415 = 11.515 \div 2 = 5.75$
Phos	$1.3 + < 0.10 = 1.4 \div 2 = 0.7$
CBOD	$< 2.00 + < 2.00 = < 2.00$
Fecal Coliform	$< 1 + < 1 = < 1$
PH Low	7.18 #2 BASIN 4/29
High	8.70 #1 BASIN 4/22
D.O. Low	6.51 #2 BASIN 4/22
High.	9.90 #1 BASIN 4/19

The following table shows the results of the experiment. The data is presented in a table with columns for the different conditions and rows for the different measurements. The values are given in the units specified in the table.

Condition	Measurement 1	Measurement 2	Measurement 3
Control	1.2	1.5	1.8
Condition A	2.1	2.4	2.7
Condition B	3.0	3.3	3.6
Condition C	4.0	4.3	4.6
Condition D	5.0	5.3	5.6
Condition E	6.0	6.3	6.6
Condition F	7.0	7.3	7.6
Condition G	8.0	8.3	8.6
Condition H	9.0	9.3	9.6
Condition I	10.0	10.3	10.6
Condition J	11.0	11.3	11.6
Condition K	12.0	12.3	12.6
Condition L	13.0	13.3	13.6
Condition M	14.0	14.3	14.6
Condition N	15.0	15.3	15.6
Condition O	16.0	16.3	16.6
Condition P	17.0	17.3	17.6
Condition Q	18.0	18.3	18.6
Condition R	19.0	19.3	19.6
Condition S	20.0	20.3	20.6
Condition T	21.0	21.3	21.6
Condition U	22.0	22.3	22.6
Condition V	23.0	23.3	23.6
Condition W	24.0	24.3	24.6
Condition X	25.0	25.3	25.6
Condition Y	26.0	26.3	26.6
Condition Z	27.0	27.3	27.6

Moniteau High School Sewage Treatment Plant				Daily Operations Worksheet			
Permit # PA0091341				APRIL 2022			
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Operator
4-1	Fri	AERATION	7.65	9.57	5.5	5,813,986	Jeff C
4-2	SAT						
4-3	SUN	AERATION	7.79	9.64	5.0		Jeff C
4-4	Mon	7.29	9.54	7.75	9.67	5.0	Jeff C
4-5	Tues	7.46	9.50	7.89	9.50	5.0	Jeff C
4-6	Wed	7.52	9.47	8.01	9.38	5.0	Jeff C
4-7	Thurs	7.81	9.40	8.10	9.04	5.0	Jeff C
4-8	Fri	7.88	9.37	8.08	9.11	4.9	Jeff C
4-9	SAT	8.05	8.58	8.38	9.62	5.0	Jeff C
4-10	SUN	8.39	7.29	8.59	9.88	5.0	Jeff C
4-11	Mon	8.40	7.67	8.50	9.01	4.3	Jeff C
4-12	Tues	8.42	7.90	8.48	8.72	4.5	Jeff C
4-13	Wed	8.47	8.08	8.48	8.40	5.0	Jeff C
4-14	Thurs	8.50	8.10	8.52	8.20	5.00	Jeff C
4-15	Fri	8.43	8.01	8.48	8.13	5.0	Jeff C
4-16	SAT	8.36	8.93	8.40	8.82	5.0	Jeff C
4-17	SUN	EASTER					
4-18	Mon	8.20	8.86	8.22	8.95	4.8	Jeff C
4-19	Tues	8.24	9.90	8.24	8.45	4.8	Jeff C
4-20	Wed	8.28	9.90	8.30	8.48	4.3	Jeff C
4-21	Thurs	8.30	9.01	8.18	8.06	5.1	Jeff C
4-22	Fri	8.70	8.12	7.45	6.51	4.8	Jeff C
4-23	SAT						
4-24	SUN						
4-25	Mon	8.68	8.93	7.40	7.71	4.5	Jeff C
4-26	Tues	8.63	9.34	7.44	8.44	4.3	Jeff C
4-27	Wed	8.58	9.01	7.51	8.26	4.8	Jeff C
4-28	Thurs	8.50	8.30	7.32	8.12	4.9	Jeff C
4-29	Fri	8.49	7.84	7.18	8.07	5.2	Jeff R
4-30	SAT						
						121.7	5,982,014
							168,028 ÷ 30 = 5,600





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

22 April 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 2040596
 Project: Wastewater
 Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2040596-01	Waste Water	04/07/2022 10:30	4/7/22 15:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications


Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/22/2022 14:11

Lab Sample ID#: 2040596-01
 Sample Type: Waste Water
 Sample Source: Grab
 Sampler: Client
 Client Sample ID: Effluent Outfall 001

Sample Date: 04/07/2022 10:30
 Receipt Date: 04/07/2022 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	<0.729	mg/L		0.729	DAA	04/20/22 06:00	04/20/22 14:19
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	04/14/22 11:30	04/14/22 12:30
General Chemistry	Analytical Method: SM4500 NH3 F-11				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	04/20/22 06:00	04/20/22 14:19
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.415	mg/L		0.104	AW	04/14/22 11:52	04/14/22 11:52
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	<0.10	mg/L		0.10	AW	04/14/22 12:25	04/14/22 12:25
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L		2.00	AW	04/08/22 12:54	04/12/22 09:22
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	KD	04/07/22 15:13	04/08/22 12:45

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

MONITORING NUMBER
2040596

FOR INT'L
LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Date	Time	Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab						
Date on/of	Time on/of	Date	Time						
Effluent Outfall 001	2040596			4/7/02	10:30 AM	WW	1	Poly 1000mL None	CBOD, TSS
						WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
						WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

Project Notes:

- 1. THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
- 2. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1.18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- 3. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 4/7/02 10:30 AM

Relinquished By: (Signature) *[Signature]* Date/ Time 4/7/02 1:00

Relinquished By: (Signature) *[Signature]* Date/ Time 4-7-02 1:11

Relinquished By: (Signature) *[Signature]* Date/ Time

Relinquished By: (Signature) *[Signature]* Date/ Time

Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature

Wastewater

Company/Name: **MONITEAU SCHOOL DISTRICT**
Contact Person: **JEFFREY CAMPBELL**
Address: **1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061**
Phone / Cell: **724-406-4426**
Email: **icampbell@moniteau.org**



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Montevu</u>	Work C	2040596
------------------------	--------	---------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>(00582)</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>4/7/22 1500</u>	Date Sampled: <u>4/7/22</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>33</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above): _____ Signature Date Time

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
Sample containers intact and sealed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created: YES <u>NO</u>

Effective Date: _____

**Moniteau School District
Maintenance Department
Moniteau High School
Monthly Operations Report
Water Quality Test Results
April 2022**

MONTEAU HIGH SCHOOL WATER TREATMENT PLANT												
MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
Apr. 1	Fri	58.0	10.67	5,813,986	0.63	0.72	7.0	0.03	0	1.73	Jeff C	11:00 AM
	SAT											
	SUN											
	Mon	61.0	8.53	5,813,986	0.64	0.72	7.0	0.02	0	1.71	Jeff C	8:00 AM
	Tues	61.0	10.22	5,856,910	0.67	0.75	6.9	0.02	0	1.40	Jeff C	2:00 PM
	wed	61.0	9.30	5,856,910	0.68	0.75	6.9	0.02	0	1.40	Jeff C	2:30 PM
	Thurs	62.0	8.24	5,865,776	0.68	0.75	7.0	0.02	0	1.38	Jeff C	4:00 PM
	Fri	62.0	11.45	5,883,315	0.69	0.76	6.9	0.02	0	1.94	Jeff C	8:00 AM
	SAT											
	SUN											
	Mon	59.5	11.51	5,919,908	0.86	0.96	6.9	0.03	0	1.37	Jeff C	10:00 AM
	Tues	62.5	8.41	5,929,813	0.88	0.96	7.0	0.02	0	1.32	Jeff C	3:00 PM
	wed	66.5	7.09	5,929,813	0.88	0.96	7.0	0.02	0	1.33	Jeff C	4:00 PM
	Thurs	59.1	11.25	5,951,669	0.83	0.92	6.8	0.03	0	1.28	Jeff C	10:30 AM
	Fri	58.6	9.17	5,951,669	0.83	0.92	7.0	0.02	0	1.28	Jeff C	7:00 AM
	SAT											
	SUN											
	Mon	57.0	7.70	5,951,669	0.82	0.92	7.0	0.02	0	1.29	Jeff C	1:30 PM
	Tues	56.0	11.10	5,966,804	0.50	0.55	6.8	0.02	0	0.90	Jeff C	2:00 PM
	wed	62.0	9.77	5,966,804	0.48	0.55	6.8	0.02	0	0.88	Jeff C	2:30 PM
	Thurs	55.0	9.41	5,975,750	0.90	0.99	6.9	0.03	0	1.19	Jeff C	9:00 AM
	Fri	67.0	9.62	5,956,498	1.03	1.10	7.0	0.01	0	1.08	Jeff C	4:00 PM
	SAT											
	SUN											
	Mon	68.0	8.10	5,956,498	1.10	1.15	7.0	0.01	0	1.10	Jeff C	9:00 AM
	Tues	67.0	7.20	5,956,498	1.11	1.18	7.0	0.00	0	1.11	Jeff C	1:00 PM
	wed	65.0	9.81	5,970,115	1.25	1.35	7.0	0.00	0	0.97	Jeff C	8:00 AM
	Thurs	66.0	7.91	5,970,115	1.26	1.37	7.0	0.00	0	0.99	Jeff C	8:00 AM
	Fri	66.0	9.61	5,982,014	1.46	1.53	7.1	0.02	0	1.07	Jeff R	11:45 AM
	SAT											
	SUN											


Turned up CL2 5/150

3/31/22 Meter Reading 5,796,391

- Sewage Samples

- Water Samples





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 April 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2040685
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	2040685-01	Drinking Water	04/07/2022 11:45	4/7/22 14:17	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.


Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/13/2022 12:49

Lab Sample ID#: 2040685-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 04/07/2022 11:45
Receipt Date: 04/07/2022 14:17

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.710	mg/L		0.200	PS	04/07/22 11:45	04/07/22 11:45
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KD	04/07/22 14:41	04/08/22 15:52
E. Coli	Absent	per 100 mL		1	KD	04/07/22 14:41	04/08/22 15:52

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Rce
Van Voorhis, PA 1536
(724) 258-TEST
FAX: (724) 258-8376



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	2040685				
801 KITCHEN-SINK 802 ROOM 617 SINK	01	DW	1	NA THIO	Free Chlorine 7.1 mg/L
Sample Type		Date		Time	
Grab		4-7-22		1145	

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* 4-7-22 1145 Date/ Time
Relinquished By: (Signature) *[Signature]* 4-7-22 1411 Date/ Time
Relinquished By: (Signature) _____ Date/ Time
Relinquished By: (Signature) _____ Date/ Time

Received By: (Signature) *[Signature]* 4-7-22 1417 Date/ Time
Received By: (Signature) _____ Date/ Time
Received By: (Signature) _____ Date/ Time
Receipt Temperature 3.8°C

Notes/Special Instructions::

Drinking Water Dassa McKinney - Monthly

Company Name: MONITEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.org
Billing Address: 5100316
PWSID:

Correct Preservations Y / N / NA Correct Containers Y / N / NA



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.71	040722	802		040722	D	1145	32382	2040685-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040822	802		040722	D	1145	32382	2040685-01	BROWNKA_69



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 April 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2041288
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	2041288-01	Drinking Water	04/14/2022 12:20	4/14/22 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Shane Molyneux
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/18/2022 14:37

Lab Sample ID#: 2041288-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 04/14/2022 12:20
Receipt Date: 04/14/2022 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.720	mg/L		0.200	PS	04/14/22 12:20	04/14/22 12:20

ENVIRONMENTAL SERVICE LABORATORIES

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



2041288

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

FAX: (724) 258-8376

FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>801</u>	<u>2041288</u>	<u>4/14/12</u>	<u>1220</u>	DW	Field	Field	Free Chlorine <u>0.72</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY. IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Email Address: jcampbell@moniteau.org</p> <p>Billing Address: 5100316</p> <p>PWSID: 5100316</p>			
<p>Sampled By: (Signature) <i>[Signature]</i> Date/ Time <u>4/14/12 1220</u></p>		<p>Received By: (Signature) <i>[Signature]</i> Date/ Time <u>4/14/12 1430</u></p>		<p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time <u>4/14/12 1430</u></p>		<p>Relinquished By: (Signature) _____ Date/ Time _____</p>	
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>		<p>Relinquished By: (Signature) _____ Date/ Time _____</p>		<p>Relinquished By: (Signature) _____ Date/ Time _____</p>		<p>Correct Preservations <u>Y/N/NA</u> Correct Containers <u>Y/N/NA</u> Receipt Temperature _____</p>	




E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	041422	801		041422	D	1220	32382	2041288-01	BROWNKA_492
5100316	1013	FREE CHLORINE	301	0.71	040722	802		040722	D	1145	32382	2040685-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040822	802		040722	D	1145	32382	2040685-01	BROWNKA_69



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

25 April 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2041797
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	2041797-01	Drinking Water	04/21/2022 11:30	4/21/22 14:05	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/25/2022 09:14

Lab Sample ID#: 2041797-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 04/21/2022 11:30
Receipt Date: 04/21/2022 14:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.880	mg/L		0.200	PS	04/21/22 11:30	04/21/22 11:30

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
 1803 Philadelphia St
 Indiana, PA 15701
 (724) 453-TEST
 FAX: (724) 455-4209

SOUTHERN DIVISION
 1276 Berryville Road
 Van Voorhis, PA 15386
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN DIVISION
 435 Broad Street
 N

NORTHWEST DIVISION
 3A 16 ST
 ST
 55-4209

FOR INTERNAL LABORA

2041797

Sample Identification	ESL#	Grab		Matrix	# of Bottles	Field	Container Type Preservative	Analysis Requested
		Date	Time					
Distribution: 803	2041797	4/11/12	1130	DW			Field	Free Chlorine .50 mg/L

- ROTATION**
- WK 1 - 801 Kitchen Sink
 - WK 2 - 802 Room 617 Sink
 - WK 3 - 803 Room 606 Sink
 - WK 4 - 804 Room 408 Sink
 - WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD WEST SUNBURY, PA 16061**
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **724-406-4426**
 Email Address: **jcampbell@moniteau.org**
 Billing Address: **5100316**
 PWSID: **5100316**

Sampled By: (Signature) *[Signature]* Date/ Time **4/11/12 1130**
 Relinquished By: (Signature) *[Signature]* Date/ Time **4/11/12 1130**

Received By: (Signature) *[Signature]* Date/ Time **4/11/12 1130**
 Received By: (Signature) *[Signature]* Date/ Time **4/11/12 1130**

Correct Preservations **Y/N/NA** Correct Containers **Y/N/NA** Receipt Temperature _____



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	041422	801		041422	D	1220	32382	2041288-01	BROWNKA_492
5100316	1013	FREE CHLORINE	301	0.71	040722	802		040722	D	1145	32382	2040685-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040822	802		040722	D	1145	32382	2040685-01	BROWNKA_69
5100316	1013	FREE CHLORINE	301	0.88	042122	803		042122	D	1130	32382	2041797-01	BROWNKA_755



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

29 April 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2042387
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	2042387-01	Drinking Water	04/28/2022 11:00	4/28/22 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/29/2022 13:28

Lab Sample ID#: 2042387-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 04/28/2022 11:00
Receipt Date: 04/28/2022 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.430	mg/L		0.200	PS	04/28/22 11:00	04/28/22 11:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



54

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

<p>Sample Identification</p> <p>Distribution: <u>804</u></p>	<p>ESL#</p> <p><u>2042387</u></p>	<p>Sample Type</p> <table border="1"> <tr> <th>Grab</th> <th>Time</th> </tr> <tr> <td></td> <td></td> </tr> </table>	Grab	Time			<p># of Bottles</p> <p>Field</p>	<p>Container Type</p> <p>Preservative</p> <p>Field</p>	<p>Analysis Requested</p> <p>Free Chlorine <u>4.3</u> mg/L</p>
Grab	Time								
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802-Room 617 Sink</p>									
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>									
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>									
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>4-28-22 1100</u></p>			<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>4/28/22 1400</u></p>						
<p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>4-28-22 1300</u></p>			<p>Received By: (Signature) _____ Date/ Time _____</p>						
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>			<p>Received By: (Signature) _____ Date/ Time _____</p>						
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>			<p>Received By: (Signature) _____ Date/ Time _____</p>						
<p>Correct Preservations Y / N / NA</p>	<p>Correct Containers Y / N / NA</p>	<p>Receipt Temperature _____</p>							
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD</p> <p>WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Billing Address: 5100316</p> <p>PWSID: 5100316</p>									



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	041422	801		041422	D	1220	32382	2041288-01	BROWNKA_492
5100316	1013	FREE CHLORINE	301	0.71	040722	802		040722	D	1145	32382	2040685-01	BROWNKA_68
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	040822	802		040722	D	1145	32382	2040685-01	BROWNKA_69
5100316	1013	FREE CHLORINE	301	0.88	042122	803		042122	D	1130	32382	2041797-01	BROWNKA_755
5100316	1013	FREE CHLORINE	301	0.43	042822	804		042822	D	1100	32382	2042387-01	BROWNKA_1444

**Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Monthly Operations Report
Water Quality Test Results
April 2022**

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
Apr	1	8.7	0.00	0.66	0.73	1.20	13292300	Jeff R	3:30P	4600
	2									
	3									
	4	8.7	0.00	0.66	0.74	1.32	13296900	Jeff R	4:00P	4600
	5	8.7	0.00	0.68	0.75	1.48	13301400	Jeff R	4:00P	4500
	6	8.7	0.01	0.70	0.77	1.32	13305700	Jeff R	4:30P	4300
	7	8.7	0.01	0.71	0.79	1.38	13309500	Jeff R	3:30P	3800
	8	8.7	0.00	0.78	0.88	1.26	13313600	Jeff R	3:00P	4100
	9									
	10									
	11	8.7	0.01	0.89	0.68	1.48	13318200	Jeff R	4:30P	4600
	12	8.7	0.00	0.62	0.71	1.67	13321900	Jeff R	4:30P	3700
	13									
	14	8.7	0.00	0.78	0.88	1.05	13329400	Jeff R	3:00P	7500
	15			Good	Friday					
	16									
	17									
	18	8.7	0.01	0.79	0.89	1.25	13332800	Jeff R	2:30P	3400
	19	8.7	0.01	0.59	0.70	1.12	13337200	Jeff C	4:30P	4400
	20	8.7	0.00	0.62	0.64	1.39	13340700	Jeff R	3:00P	3500
	21	8.7	0.01	0.64	0.71	1.44	13344800	Jeff R	3:00P	4100
	22	8.7	0.00	0.61	0.67	1.58	13346800	Jeff R	12:00P	2000
	23									
	24									
	25	8.7	0.64	0.67	0.77	1.79	13353800	Jeff R	3:30P	7000
	26	8.7	0.06	0.57	0.63	1.68	13358200	Jeff C	3:15P	4400
	27	8.7	0.03	0.59	0.64	1.81	13362500	Jeff R	3:30P	4300
	28	8.7	0.02	0.63	0.68	1.70	13366000	Jeff R	2:30P	3500
	29	8.7	0.03	0.75	0.79	1.49	13370000	Jeff R	3:00P	4000
	30									
	31									

Meter Reading Mar. 31, 2022 - 13287,700



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

13 April 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 2040686
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	2040686-01	Drinking Water	04/07/2022 12:05	4/7/22 14:17	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/13/2022 12:53

Lab Sample ID#: 2040686-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 04/07/2022 12:05
Receipt Date: 04/07/2022 14:17


Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.760	mg/L		0.200	PS	04/07/22 12:05	04/07/22 12:05
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KD	04/07/22 14:41	04/08/22 15:52
E. Coli	Absent	per 100 mL		1	KD	04/07/22 14:41	04/08/22 15:52

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVIS
1276 Bentleyville I
Van Voorhis, PA 1
(724) 258-TEST
FAX: (724) 258-8



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRCLE ONE: 704-KITCHEN-MAIN SINK 802 ROOM 204 SINK	2040686	4-7-22	1205 PM	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine
<p>704: Jan, Mar, May, Jul, Sept, Nov</p> <p>802: Feb, Apr, Jun, Aug, Oct, Dec</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <i>[Signature]</i> 1205 PM</p> <p>Date/ Time 4-7-22</p>				<p>Received By: (Signature) <i>[Signature]</i> (00382)</p> <p>Date/ Time 4/7/22 1417</p>			
<p>Relinquished By: (Signature) <i>[Signature]</i></p> <p>Date/ Time 4-7-22</p>				<p>Received By: (Signature)</p> <p>Date/ Time</p>			
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>				<p>Received By: (Signature)</p> <p>Date/ Time</p>			
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>				<p>Received By: (Signature)</p> <p>Date/ Time</p>			
<p>Correct Preservations <i>(-)</i> / N / NA</p>				<p>Correct Containers <i>(-)</i> / N / NA</p>			
<p>Receipt Temperature 5.0 (4) °C</p>							
<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Monthly</p>							
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: icampbell@moniteau.org</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>							



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.76	040722	802		040722	D	1205	32382	20406886-01	BROWNKA_70
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	040822	802		040722	D	1205	32382	20406886-01	BROWNKA_71



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 April 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2041289
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	2041289-01	Drinking Water	04/14/2022 12:40	4/14/22 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Shane Molyneaux
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 04/18/2022 16:21

Lab Sample ID#: 2041289-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 04/14/2022 12:40
Receipt Date: 04/14/2022 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.820	mg/L		0.200	PS	04/14/22 12:40	04/14/22 12:40

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



2041289

SOUTHERN DIVISION
1276 Bentleyville Roac
Van Voorhis, PA 1536f
(724) 258-TEST
FAX: (724) 258-8376

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>704</u>	<u>2041289</u>	Grab	DW	Field	Field	Free Chlorine <u>82</u> mg/L
	<u>01</u>	Date				
		Time				
		<u>4:44 PM</u>				
		<u>12:40</u>				
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Moniteau Jr/Sr - Weekly</i></p>						
<p>Company/Name:</p> <p>MONITEAU SCHOOL DISTRICT</p>			<p>Address:</p> <p>391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p>			
<p>Received By: (Signature)</p> <p><i>[Signature]</i></p>			<p>Received By: (Signature)</p> <p><i>[Signature]</i></p>			
<p>Date/Time</p> <p><u>4-14-12 12:40</u></p>			<p>Date/Time</p> <p><u>4-14-12 12:40</u></p>			
<p>Relinquished By: (Signature)</p> <p><i>[Signature]</i></p>			<p>Relinquished By: (Signature)</p> <p><i>[Signature]</i></p>			
<p>Date/Time</p> <p><u>4-14-12 12:40</u></p>			<p>Date/Time</p> <p><u>4-14-12 12:40</u></p>			
<p>Relinquished By: (Signature)</p> <p><i>[Signature]</i></p>			<p>Relinquished By: (Signature)</p> <p><i>[Signature]</i></p>			
<p>Date/Time</p> <p><u>4-14-12 12:40</u></p>			<p>Date/Time</p> <p><u>4-14-12 12:40</u></p>			
<p>Correct Preservations Y / N / (NA)</p> <p>Y / N / (NA)</p>			<p>Correct Containers Y / N / (NA)</p> <p>Y / N / (NA)</p>			
<p>Receipt Temperature</p>			<p>Receipt Temperature</p>			



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.82	041422	704		041422	D	1240	32382	2041289-01	BROWNKA_493
5100324	1013	FREE CHLORINE	301	0.76	040722	802		040722	D	1205	32382	2040686-01	BROWNKA_70
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	040822	802		040722	D	1205	32382	2040686-01	BROWNKA_71



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

25 April 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 2041796
 Project: Drinking Water Moniteau Jr/Sr - Weekly
 Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	2041796-01	Drinking Water	04/21/2022 11:47	4/21/22 14:05	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/25/2022 09:14

Lab Sample ID#: 2041796-01
 Sample Type: Drinking Water
 Sample Source: Grab
 Sampler: Paul Somogyi
 Client Sample ID: 803 Admin Sink

Sample Date: 04/21/2022 11:47
 Receipt Date: 04/21/2022 14:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.810	mg/L		0.200	PS	04/21/22 11:47	04/21/22 11:47

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E ___ 1 ___ OF ___ 1 ___

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 256-TEST
FAX: (724) 259-8376

DIVISION
16
F
5-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>803</u>	<u>2041796</u>			DW	Field	Field Preservative	Free Chlorine <u>8.1</u> mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Montieau Jr/Sr - Weekly

Notes/Special Instructions:..

Sampled By: (Signature) [Signature] Date/ Time 4-17-09 1147

Relinquished By: (Signature) [Signature] Date/ Time 4-17-09 1305

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Y / N / NA Correct Containers Y / N / NA Y / N / NA Receipt Temperature _____

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 JEFFREY CAMPBELL**
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: _____
 Email Address: **jcambell@montieau.org**
 Billing Address: _____
 PW/SID: **5100324**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.82	041422	704		041422	D	1240	32382	2041289-01	BROWNKA_493
5100324	1013	FREE CHLORINE	301	0.76	040722	802		040722	D	1205	32382	2040686-01	BROWNKA_70
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	040822	802		040722	D	1205	32382	2040686-01	BROWNKA_71
5100324	1013	FREE CHLORINE	301	0.81	042122	803		042122	D	1147	32382	2041796-01	BROWNKA_756



The latest news for you

message

Environmental Service Laboratories <ar@envlabs.com>
Reply-To: ar@envlabs.com
From: drock@moniteau.org

Wed, Apr 13, 2022 at 10:13 A



April 13, 2022

Dear ESL Client,

The Revised Total Coliform Rule, effective April 1st, 2016, requires a "Site Plan" schedule to be submitted specifying the locations of the drinking water sites to be sampled each month. A copy of this plan is needed by our lab in order to maintain your drinking water compliance. Without the Site Plan we cannot guarantee that your samples are taken from the appropriate sites.

We would appreciate it if you would please forward a copy of your Site Plan as soon as possible by one of the following methods:

Email to jsilvis@envlabs.com or trudriguez@envlabs.com

Fax to 724/463-4209

Give a copy to the field technician at the next sampling event

Mail a copy to:

Environmental Service Laboratories
1803 Philadelphia Street
Indiana, PA 15701

Sincerely,

Julie Silvis

Municipal/Industrial Sales Director

www.envlabs.com

[Download Document](#)

It's a fact: people don't mind scrolling to read an email, as long as it's relevant and interesting. Make sure your message follows through on the promise in your subject line, and use several short paragraphs if you have a lot to say. When in doubt, challenge yourself to write less and add links that support your topic.





Facilities covered by certain NPDES permits must, as a condition of the permit, pay an annual fee as authorized by 25 Pa. Code § 92a.26, and 25 Pa. Code § 92a.62 for general and individual NPDES permits, respectively.

NPDES Permit Number:	PA0091341
Fee Category:	Minor Sewage Facility <0.05 MGD
Account Number:	379411
Invoice Number:	1242633
Amount Due:	\$ 500.00
Due Date:	6/1/2022

Permittee Mailing Address:		Facility Physical Address:	
Name:	MONITEAU SCH DIST	Name:	MONITEAU JR SR HIGH SCHOOL
Contact:	JEFF CAMPBELL	Contact:	
Address:	1810 W SUNBURY RD	Address:	1810 W SUNBURY RD
City, State, Zip:	WEST SUNBURY PA 16061-1220	City, State, Zip:	WEST SUNBURY PA 16061-1220

Please pay the Amount Due in full by the date listed on this invoice. Failure to pay the Annual Fee in full by the due date is a violation of 25 Pa. Code § 92a and may subject the permittee to enforcement action and penalties. For corrections, please contact DEP at ra-annualfee@state.pa.us.

To seek exemption as a financially distressed municipality under Act 47 of 1987, please submit documentation of determination from the Pennsylvania Department of Community and Economic Development (DCED) with a copy of this invoice.

Note: Please submit one full payment per invoice. We are unable to accept partial payments or combined payments for multiple DEP invoices with one check.

Online payments are preferred and can be made via credit card at:

www.depgreenport.state.pa.us/NPDESpay

PAY BY CHECK: CUT OR TEAR ALONG LINE AND RETURN PORTION BELOW

Preferred: Pay online at **www.depgreenport.state.pa.us/NPDESpay**

Permit Number: PA0091341
Account ID: 379411
Invoice ID: 1242633
Due Date: 6/1/2022

Make checks payable to "**Commonwealth of Pennsylvania**" and *mail with this invoice stub* in the enclosed envelope to:

PA Department of Environmental Protection
Bureau of Clean Water
Re: Chapter 92a Annual Fee
P.O.Box 8466
Harrisburg, PA 17105-8466

AMOUNT DUE:	\$ 500.00
AMOUNT PAID:	

For DEP Use Only

Date Payment Entered:	_____	Check No:	_____
Entered By:	_____	Check Amount:	_____

Bureau of Clean Water



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 May 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 2041786
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2041786-01	Waste Water	04/21/2022 10:45	4/21/22 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 05/02/2022 15:32

Lab Sample ID#: 2041786-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 04/21/2022 10:45
Receipt Date: 04/21/2022 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	16.1	mg/L		1.14	DAA	04/29/22 12:10	05/02/22 08:01
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	5	mg/L		5	LMB	04/25/22 10:55	04/25/22 13:30
General Chemistry	Analytical Method: SM4500 NH3 F-11				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	5.03	mg/L		0.625	DAA	04/29/22 12:10	05/02/22 08:01
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	11.1	mg/L		0.520	AW	04/27/22 13:16	04/27/22 13:16
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	1.3	mg/L		0.50	AW	04/28/22 11:30	04/28/22 11:30
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L		2.00	AW	04/22/22 12:56	04/27/22 09:03
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	KD	04/21/22 15:11	04/22/22 12:20



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Intervec</u>	Work Order

PART A: GENERAL INFORMATION - SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC/EC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION - INDIANA LABORATORY

Received by/Lab ID: <u>(00582)</u>	Date/Time Received: <u>4/21/12 1:00 PM</u>
Method of Delivery: Fedex UPS Client Drop off <u>ESL courier</u> Other: _____	Date Sampled: <u>4/17/12</u>
Sample Receipt Temperature: <u>3.4</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above): _____

Signature _____ Date / / Time _____

Sample Receipt Criteria	Comments	YES	NO
Chain of custody documents included with samples?	Comments:	YES	NO
COC form is properly signed in relinquished/received sections?	Comments:	YES	NO
Sample containers intact and sealed?	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____	YES	NO
Number of containers received matches number indicated on COC?	Sample IDs and Containers Affected:	YES	NO
Sample IDs on COC match IDs on bottles?	Sample IDs and Containers Affected:	YES	NO
Date and time on COC match date and time on bottles?	Sample IDs and Containers Affected:	YES	NO
Samples received within holding time?	Sample IDs and Containers Affected and Observed pH:	YES	NO
Samples received at appropriate pH for analysis requested?	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.	YES	NO
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Analyses Affected:	YES	NO
Adequate sample volume received?	Sample IDs and Containers Affected:	YES	NO
VOA vials free of headspace (defined as < 6 mm bubble)?	Sample IDs and Containers Affected:	YES	NO
Other Comments:	Deficiency Log Created: YES <u>NO</u>		