

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for July 2023



**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220
 STAGE: Final Effluent

PA0091341
 PERMIT NUMBER

001
 OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 07/01/2023
 DMR Effective To: 07/31/2023
 Permit Expires: 01/31/2028
 Permit Application Due: 08/04/2027
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	07	01	2023	07	31

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	7.42	***	***	***	***	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	4.0	***	***	***	***	mg/L	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	7.07	***	***	8.00	***	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	6.0	***	***	9.0	***	S.U.	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***	***	***	2.5	***	5.0	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	30.0	***	60.0	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***	***	***	Avg Mo	***	IMAX	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	<.165	***	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***	***	***	Monitor & Report	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	Avg Mo	***	***	Daily when Discharging	Grab
Flow (50050)	SAMPLE MEASUREMENT	.001256	***	***	5.01	***	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	Monitor & Report	***	***	Monitor & Report	***	µM/cm²	Daily when Discharging	Grab
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***	***	Avg Mo	***	***	1/week	Measured
	PERMIT REQUIREMENT	***	***	***	***	***	***	1/week	Measured
		***	***	***	<1.0	***	<1.0	2/month	Grab
		***	***	***	200	***	1000	2/month	Grab
		***	***	***	Geo Mean	***	IMAX	2/month	Grab



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	<2.00	<2.00	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	25.0 Avg Mo	50.0 IMAX		2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Thu, Aug 17, 2023 at 7:40 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 07/01/2023-07/31/2023
Report Due Date: 08/28/2023

Submitted By: Jeffrey Campbell
Submission Id: 409728
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: July 2023

Flow	38,969 ÷ 31			: <u>1256.94</u> Daily Avg
UV Light	90.2 ÷ 18			: <u>5.01</u> Daily Avg
		Basin #	Date	
PH Low	7.07	#1	7/10/23	
PH High	8.00	#2	7/17/23	
D. O. Low	7.42	#2	7/6/23	
D. O. High	8.55	#2	7/17/23	

Date:	7/6/23	7/20/23	Sub TOTAL	TOTAL	
Total Nitrogen	1.17	10.5	11.67	5.835	
TSS	< 5	5	5	2.5	
TKN	< 0.625	0.647	1.272	0.636	
Nitrate/Nitrate	1.17	9.90	11.07	5.535	
Phos	0.40	1.7	2.1	1.05	
CBOD	< 2.00	< 2.00		< 2.00	
Fecal	< 1.	< 1		< 1	
Ammonia	< 0.165	< 0.165		< 0.165	



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0520
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23G0520-01	Waste Water	07/06/2023 11:00	7/6/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/20/2023 12:22

Lab Sample ID#: 23G0520-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 07/06/2023 11:00
Receipt Date: 07/06/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time	
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]			
Total Nitrogen	1.17	mg/L			0.729	AW	07/14/23 13:44	07/14/23 13:44	
General Chemistry	Analytical Method: ASTM D6919-17					Prep Method: No Prep - WetChem			
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	07/17/23 23:14	07/17/23 23:14	
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B			
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	07/13/23 12:18	07/13/23 12:18	
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem			
Total Suspended Solids	<5	mg/L			5	AH	07/10/23 14:36	07/11/23 13:55	
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem			
Nitrate/Nitrite	1.17	mg/L			0.104	AW	07/14/23 13:44	07/14/23 13:44	
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B			
Phosphorus	0.40	mg/L			0.20	JMS	07/18/23 18:50	07/18/23 18:50	
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem			
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, SS		2.00	TW	07/07/23 14:41	07/12/23 11:00	
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro			
Fecal Coliforms	<1	MPN/100 mL			1	DAA	07/06/23 14:57	07/07/23 12:30	

HEADQUARTERS
 1803 Philadelphia St.
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Voorhis, PA 15366
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN
 435 Broad S
 Montoursvill
 (570) 321-9
 FAX: (570)



NORTHWEST DIVISION
 3rd
 PA 16150
 TEST
 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23G0520	Composite		Sample Type		Matrix	# of Containers	Container Type Preservative	Analysis Requested	
		Date on/of	Time on/of	Date	Grab Time					
Effluent Outfall 001	23G0520					WW	1	Poly 500mL H2SO4	Ammonia, Total Nitrogen, Total Phosphorus	
										7/6/03 11:00 AM

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Project Notes:
Wastewater

Signed By: (Signature) [Signature] **Date/ Time** 7/6/03 11:05 AM

Signed By: (Signature) [Signature] **Date/ Time** 7/6/03 11:05

Signed By: (Signature) [Signature] **Date/ Time** 7-6-03 PM 1:38

Signed By: (Signature) [Signature] **Date/ Time** 7-6-03 PM 1:38

Signed By: (Signature) [Signature] **Date/ Time** 7-6-03 PM 1:38

Signed By: (Signature) [Signature] **Date/ Time** 7-6-03 PM 1:38

Signed By: (Signature) [Signature] **Date/ Time** 7-6-03 PM 1:38

Company/Name: MONITEAU SCHOOL DISTRICT

Contact Person: JEFFREY CAMPBELL

Address: 1810 WEST SUNBURY ROAD, WEST SUNBURY, PA 16061

Phone / Cell: 724-406-4426

Email: jcampbell@moniteau.org

Correct Containers Y / N / NA **Receipt Temperature**



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Montevu</u>	Work Order: 23G0520
------------------------	---

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	Received on Ice? YES <input type="checkbox"/> NO <input type="checkbox"/>
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FE CAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JND / 00382</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>7/6/23 1330</u>	Date Sampled: <u>7/6/23</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input type="checkbox"/> ESL courier Other: _____	
Sample Receipt Temperature: <u>3.7</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input type="checkbox"/> NO

PART C: Receipt Details Completed (if different from above): _____ / _____ / _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO	Comments:
COC form is properly signed in relinquished/received sections?	YES NO	Comments:
Sample containers intact and sealed?	YES NO	Circle Applicable: Damaged Container <input type="checkbox"/> Leaking Container <input type="checkbox"/> Custody Seal Broken <input type="checkbox"/> Other: _____
Number of containers received matches number indicated on COC?	YES NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO	Sample IDs and Containers Affected:
Samples received within holding time?	YES NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES NO	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created: YES <input type="checkbox"/> NO

Effective Date: _____



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

02 August 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23G2509
 Project: Wastewater
 Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23G2509-01	Waste Water	07/20/2023 10:00	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

- LL Laboratory control sample below acceptance criteria, result may be biased low.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/02/2023 15:22


Lab Sample ID#: 23G2509-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 07/20/2023 10:00
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD				Prep Method: [CALC]			
Total Nitrogen	10.5	mg/L			1.66	AW	07/31/23 12:31	07/31/23 12:31
General Chemistry	Analytical Method: ASTM6919-17				Prep Method: No Prep - WetChem			
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	08/01/23 04:14	08/01/23 04:14
General Chemistry	Analytical Method: EPA 351.2 2.0				Prep Method: SM 4500-Norg B			
Total Kjeldahl Nitrogen	0.647	mg/L			0.625	AW	07/31/23 12:31	07/31/23 12:31
General Chemistry	Analytical Method: SM2540 D-15				Prep Method: No Prep - WetChem			
Total Suspended Solids	5	mg/L	LL		5	AH	07/25/23 13:04	07/25/23 13:04
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)				Prep Method: No Prep - WetChem			
Nitrate/Nitrite	9.90	mg/L			1.04	AW	07/28/23 14:45	07/28/23 14:45
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: SM 4500 P B			
Phosphorus	1.7	mg/L			1.0	JMS	08/01/23 13:20	08/01/23 13:20
General Chemistry	Analytical Method: SM5210 B-16				Prep Method: No Prep - WetChem			
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G		2.00	TW	07/21/23 17:00	07/26/23 13:04
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro			
Fecal Coliforms	<1	MPN/100 mL			1	JP	07/20/23 14:39	07/21/23 11:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209









SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Containers	Matrix	Container Type <small>Preservative</small>	Analysis Requested
		Composite <small>Date on/of</small>	Grab <small>Date</small>				
Effluent Outfall 001	23G2509	Time on/of	Date	1	WW	Poly 1000mL	CBOD, TSS
		Time on/of	Date				
		Time on/of	Date				
				1	WW	None	
				1	WW	Poly 500mL H2SO4	Ammonia, Total Nitrogen, Total Phosphorus
				1	WW	Sterile Plastic 125mL Na2S2O3	Fecal Coliform
 23G2509							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature)  Date/ Time <u>7/20/03 10:00 AM</u>				Project Notes: Wastewater			
Relinquished By: (Signature)  Date/ Time <u>7/20/03 11:50</u>				Company Name: MONITEAU SCHOOL DISTRICT			
Relinquished By: (Signature)  Date/ Time <u>7/20/03 1:50</u>				Contact Person: JEFFREY CAMPBELL			
Relinquished By: (Signature)  Date/ Time <u>7/20/03 1:50</u>				Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061			
Relinquished By: (Signature)  Date/ Time <u>7/20/03 1:50</u>				Phone / Cell: 724-406-4426			
Correct Preservations Y / N / NA				Email: jcampbell@moniteau.org			
Correct Containers Y / N / NA				Receipt Temperature			



SAMPLE RECEIPT AND REVIEW FORM

Client: Munitec


 23G2509

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JD / 05382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>7/20/23 1400</u>	Date Sampled: <u>7/20/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u>	NO	Comments:
COC form is properly signed in relinquished/received sections?	<u>YES</u>	NO	Comments:
Sample containers intact and sealed?	<u>YES</u>	NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>YES</u>	NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>YES</u>	NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>YES</u>	NO	Sample IDs and Containers Affected:
Samples received within holding time?	<u>YES</u>	NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>YES</u>	NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>YES</u>	NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>YES</u>	NO	Analyses Affected:
VOA vial headspace < 6 mm?	YES	NO <u>N/A</u>	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log-Created: YES <u>NO</u>

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 August 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G2509
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23G2509-01	Waste Water	07/20/2023 10:00	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

- LL Laboratory control sample below acceptance criteria, result may be biased low.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/02/2023 15:22

Lab Sample ID#: 23G2509-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 07/20/2023 10:00
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time	
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]			
Total Nitrogen	10.5	mg/L			1.66	AW	07/31/23 12:31	07/31/23 12:31	
General Chemistry	Analytical Method: ASTM6919-17					Prep Method: No Prep - WetChem			
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	08/01/23 04:14	08/01/23 04:14	
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B			
Total Kjeldahl Nitrogen	0.647	mg/L			0.625	AW	07/31/23 12:31	07/31/23 12:31	
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem			
Total Suspended Solids	5	mg/L	LL		5	AH	07/25/23 13:04	07/25/23 13:04	
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem			
Nitrate/Nitrite	9.90	mg/L			1.04	AW	07/28/23 14:45	07/28/23 14:45	
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: SM 4500 P B			
Phosphorus	1.7	mg/L			1.0	JMS	08/01/23 13:20	08/01/23 13:20	
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem			
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G		2.00	TW	07/21/23 17:00	07/26/23 13:04	
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro			
Fecal Coliforms	<1	MPN/100 mL			1	JP	07/20/23 14:39	07/21/23 11:20	

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209


SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab	Date	Time				
Effluent Outfall 001	7502509	Time on/off	Time on/off	7/20/03	10:00 AM	WW	1	Poly 1000mL None	CBOD, TSS
		Time on/off	Time on/off			WW	1	Poly 500mL H2SO4	Ammonia, Total Nitrogen, Total Phosphorus
		Time on/off	Time on/off			WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform
 23G2509									
Project Notes: Wastewater									
Company Name: MONITEAU SCHOOL DISTRICT									
Contact Person: JEFFREY CAMPBELL									
Address: 1810 WEST SUNBURY ROAD									
WEST SUNBURY, PA 16061									
Phone / Cell: 724-406-4426									
Email: jcampbell@moniteau.org									

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY
 ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 7/20/03 10:00 AM

Relinquished By: (Signature) *[Signature]* Date/ Time 7/20/03 11:50

Relinquished By: (Signature) *[Signature]* Date/ Time 7/20/03 1:50

Relinquished By: (Signature) *[Signature]* Date/ Time 7/20/03 1:50

Relinquished By: (Signature) *[Signature]* Date/ Time 7/20/03 1:50

Received By: (Signature) *[Signature]* Date/ Time 7/20/03 11:50

Received By: (Signature) *[Signature]* Date/ Time 7/20/03 1:50

Received By: (Signature) *[Signature]* Date/ Time 7/20/03 1:50

Received By: (Signature) *[Signature]* Date/ Time 7/20/03 1:50

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



SAMPLE RECEIPT AND REVIEW FORM

Client: Moniteau



23G2509

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other:	Received on Ice? YES NO
Sample Receipt Temperature: °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>50 / 00382</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>7/20/23 1400</u>	Date Sampled: <u>7/20/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other:	
Sample Receipt Temperature: <u>3.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other:	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature		Date		Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>YES</u>	NO				Comments:
COC form is properly signed in relinquished/received sections?	YES	NO				Comments:
Sample containers intact and sealed?	YES	NO				Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other:
Number of containers received matches number indicated on COC?	YES	NO				Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES	NO				Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES	NO				Sample IDs and Containers Affected:
Samples received within holding time?	YES	NO				Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES	NO				Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES	NO				For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES	NO				Analyses Affected:
VOA vial headspace < 6 mm?	YES	NO	<u>N/A</u>			Sample IDs and Containers Affected:
Other Comments:						Deficiency Log Created: YES <u>NO</u>

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for July 2023

MONTEAU HIGH SCHOOL WATER TREATMENT PLANT											
MONTH	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	SAT										
2	SUN										
3	Mon	Closed	Holiday								
4	Tues	Closed	Holiday								
5	WED	72.0	11.34	8,164,391	0.67	0.74	7.1	0.02	0	0.99	Jeff C 6:00 AM
6	Thurs	73.6	10.97	8,164,391	0.67	0.75	7.1	0.02	0	0.99	Jeff C 10:00 AM
7	Fri	74.5	9.99	8,164,391	0.67	0.74	7.1	0.02	0	0.99	Jeff C 1:00 PM
8	SAT										
9	SUN										
10	Mon	76.4	9.42	8,164,391	0.67	0.72	7.1	0.01	0	0.98	Jeff C 1:00 PM
11	Tues	77.9	8.97	8,164,391	0.67	0.72	7.1	0.01	0	0.98	Jeff C 2:00 PM
12	Wed	80.0	8.37	8,164,391	0.67	0.72	7.1	0.01	0	0.98	Jeff C 3:00 PM
13	Thurs	70.0	11.80	8,175,842	0.75	0.78	7.2	0.03	0	1.20	Jeff C 11:00 AM
14	Fri	Closed									
15	SAT										
16	SUN										
17	Mon	77.5	9.54	8,175,842	0.75	0.79	7.2	0.02	0	1.19	Jeff C 2:00 PM
18	Tues	77.9	9.03	8,175,842	0.75	0.78	7.2	0.02	0	1.20	Jeff C 2:00 PM
19	Wed	69.3	11.74	8,191,769	0.63	0.66	7.2	0.03	0	2.29	Jeff C 2:00 PM
20	Thurs	70.2	11.09	8,191,769	0.62	0.66	7.2	0.03	0	2.29	Jeff C 2:00 PM
21	Fri	Closed									
22	SAT										
23	SUN										
24	Mon	75.1	9.23	8,191,769	0.62	0.66	7.2	0.02	0	2.25	Jeff C 2:00 AM
25	Tues	77.3	8.16	8,191,769	0.61	0.66	7.2	0.03	0	2.25	Jeff C 9:00 AM
26	Wed	77.9	8.05	8,191,769	0.61	0.65	7.2	0.03	0	2.21	Jeff C 7:00 AM
27	Thurs	69.5	11.52	8,203,356	0.55	0.58	7.3	0.03	0	1.31	Jeff C 8:00 PM
28	Fri	Closed									
29	SAT										
30	SUN										
31	Mon	78.0	8.53	8,203,356	0.53	0.55	7.3	0.03	0	1.26	Jeff C 3:00 PM

■ = Sewage Samples
 ■ = Water Samples



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0641
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23G0641-01	Drinking Water	07/06/2023 11:15	7/6/23 14:32	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/12/2023 08:43

Lab Sample ID#: 23G0641-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 07/06/2023 11:15
Receipt Date: 07/06/2023 14:32

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.910	mg/L		0.200	PS	07/06/23 11:15	07/06/23 11:15
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00
E. Coli	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E ___ 1 ___ OF ___ 1 ___

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTH
435 Bro
Montau
(570) 3:
FAX: (5...)



ION
30
9

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23G0641	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRGETE ONE: 704 KITCHEN MAIN-SINK 802-ROOM 204 SINK	SN	7/03	1156	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.91

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions::

Drinking Water Monteau Jr/Sr - Monthly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONTTEAU SCHOOL DISTRICT**

Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

Contact Person: **JEFFREY CAMPBELL**

Phone Number: 724-406-4426
Cell Phone: jcampbell@monteau.org
Email Address: 5100324
Billing Address:
PWSID:

Sampled By: (Signature)	7/03 7:00 PM	1156	Received By: (Signature)	7/03 1303	1432
Relinquished By: (Signature)			Received By: (Signature)		
Relinquished By: (Signature)			Received By: (Signature)		
Relinquished By: (Signature)			Received By: (Signature)		
Correct Preservations	Y	N/NA	Correct Containers	Y	N/NA
			Receipt Temperature	3.6	#3



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Recor
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysi s Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO 237



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0516
Project: Drinking Water Moniteau Jr/Sr - Annual
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Entry Point 101	23G0516-01	Drinking Water	07/06/2023 11:20	7/6/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/11/2023 15:43

Lab Sample ID#: 23G0516-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: Entry Point 101

Sample Date: 07/06/2023 11:20
Receipt Date: 07/06/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: EPA300.0 2.1				Prep Method: No Prep - WetChem		
Nitrate	<0.100	mg/L		0.100	TLL	07/07/23 02:12	07/07/23 02:12
Nitrite	<0.100	mg/L		0.100	TLL	07/07/23 02:12	07/07/23 02:12

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vortals, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 177
(570) 321-9003
FAX: (570) 321-1957



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Entry Point 101	23G0516	7/28/05	11:20	DW	1	Plastic Pint None	Nitrate, Nitrite pk 7

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Annual

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

MONITEAU SCHOOL DISTRICT

1810 WEST SUNBURY ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

jcampbell@moniteau.org

51003324

Sampled By: (Signature)

7/28/05 08:11:20

Company/Name:

MONITEAU SCHOOL DISTRICT

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work Order: 23G0516
-------------------------	----------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JVD / 00382</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>7/6/23 1330</u>	Date Sampled: <u>7/6/23</u>
Method of Delivery: FedEx UPS Client Drop off ESL courier Other: _____	
Sample Receipt Temperature: <u>4.1</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES	NO	Comments:
COC form is properly signed in relinquished/received sections?	YES	NO	Comments:
Sample containers intact and sealed?	YES	NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES	NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES	NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES	NO	Sample IDs and Containers Affected:
Samples received within holding time?	YES	NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES	NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES	NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES	NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	NO	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created: YES NO

Effective Date: _____



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BROW 237



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

18 July 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23G1717
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23G1717-01	Drinking Water	07/13/2023 12:12	7/13/23 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/18/2023 17:05

Lab Sample ID#: 23G1717-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 07/13/2023 12:12
Receipt Date: 07/13/2023 14:50


Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-II			Prep Method: No Prep - Field			
Chlorine, Free	0.920	mg/L		0.200	PS	07/13/23 12:12	07/13/23 12:12

ENVIRONMENTAL SERVICE LABORATORIES, INC


SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHWEST DIVISION
950 Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL# 25617

Distribution: 802

Sample Type	Grab	
	Date	Time
	7/13/23	12:12

Matrix DW
of Bottles Field
Field

Container Type Field
Preservative

Analysis Requested
Free Chlorine 0.292 mg/L

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room 204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1.8% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:..

Drinking Water Monteau Jr/Sr - Weekly

Sampled By: (Signature) [Signature]
Date/ Time 7/13/23 12:12

Received By: (Signature) [Signature]
Date/ Time 7-13-23 14:50 PM

Relinquished By: (Signature) _____
Date/ Time _____

Received By: (Signature) _____
Date/ Time _____

Relinquished By: (Signature) _____
Date/ Time _____

Received By: (Signature) _____
Date/ Time _____

Correct Preservations Y / N / NA
Correct Containers Y / N / NA
Receipt Temperature _____

Company Name: **MONTEAU SCHOOL DISTRICT**

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person: _____
Phone Number: 724-406-4426
Cell Phone: _____
Email Address: jcampbell@monteau.org
Billing Address: _____
PW/SID: 5100324



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112
5100324	1013	FREE CHLORINE	301	0.92	071323	802		071323	D	1212	32382	23G1717-01	BROW 557

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO 237



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

27 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G2650
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23G2650-01	Drinking Water	07/20/2023 11:50	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/27/2023 10:42

Lab Sample ID#: 23G2650-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 07/20/2023 11:50
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-C1 G-II				Prep Method: No Prep - Field		
Chlorine, Free	0.800	mg/L		0.200	PS	07/20/23 11:50	07/20/23 11:50



**E-Government Application for Drinking Water
 Program**
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112
5100324	1013	FREE CHLORINE	301	0.92	071323	802		071323	D	1212	32382	23G1717-01	BROW 557
5100324	1013	FREE CHLORINE	301	0.8	072023	804		072023	D	1150	32382	23G2650-01	BROW 1965

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO 237

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NI 43
MK (57)
FA

FOR INTERNAL LABORATORY USE



23G2650

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>23G2650</u>		<u>1150</u>	DW	Field	Field	Free Chlorine <u>0.80</u>

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 7/20/03 1150
 Relinquished By: (Signature) [Signature] Date/ Time 7/20/03 1300

Received By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations / N / NA Correct Containers / N / NA Receipt Temperature _____

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
 Contact Person:
 Phone Number: **724-406-4426**
 Cell Phone: **jcampbell@moniteau.org**
 Email Address:
 Billing Address:
 PWSID: **5100324**



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

01 August 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G3417
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23G3417-01	Drinking Water	07/27/2023 11:15	7/27/23 13:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/01/2023 13:39

Lab Sample ID#: 23G3417-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 07/27/2023 11:15
Receipt Date: 07/27/2023 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.720	mg/L		0.200	PS	07/27/23 11:15	07/27/23 11:15

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Field	Field	Container Type	Analysis Requested
		Grab	Time						
Distribution: <u>Soil</u>	23G3417			DW				Field	Free Chlorine <u>0.22</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Montreau Jr/Sr - Weekly

<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>7/22/03 08:45</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>7/22/03 09:15</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Correct Preservations Y/N/NA _____ Correct Containers Y/N/NA _____ Receipt Temperature _____</p>	<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>7-21-13 13:15</u></p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>
<p>Company/Name: _____</p> <p>Address: _____</p> <p>Contact Person: _____</p> <p>Phone Number: _____</p> <p>Cell Phone: _____</p> <p>Email Address: _____</p> <p>Billing Address: _____</p> <p>PWSID: _____</p>	
<p>MONTTEAU SCHOOL DISTRICT</p> <p>391 HOOKER ROAD</p> <p>WEST SUNBURY, PA 16061</p> <p>JEFFREY CAMPBELL</p> <p>724-406-4426</p> <p>jcambbell@montiteau.org</p> <p>5100324</p>	



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100324	1013	FREE CHLORINE	301	0.91	070623	704		070623	D	1115	32382	23G0641-01	BROW 104
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	704		070623	D	1115	32382	23G0641-01	BROW 112
5100324	1013	FREE CHLORINE	301	0.92	071323	802		071323	D	1212	32382	23G1717-01	BROW 557
5100324	1013	FREE CHLORINE	301	0.8	072023	804		072023	D	1150	32382	23G2650-01	BROW 1965
5100324	1013	FREE CHLORINE	301	0.72	072723	804		072723	D	1115	32382	23G3417-01	BROW 2838

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100324	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO' 228
5100324	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1120	32382	23G0516-01	BRO' 237

Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for July 2023

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
July	Sat									
1	Sat									
2	Sun									
3	Mon									
4	Tues									
5	Wed	8.7	0.06	1.18	1.26	3.12	142.54300	Jeff R	1:30P	
6	Thurs	8.7	0.03	1.06	1.14	3.25	142.54500	Jeff R	1:30P	200
7	Fri	8.7	0.02	1.00	1.07	2.44	142.54700	Jeff R	1:30P	200
8	Sat									
9	Sun									
10	Mon	8.7	0.01	1.02	1.08	2.45	142.55000	Jeff R	3:30P	300
11	Tues	8.7	0.02	0.98	1.06	2.38	142.55200	Jeff R	3:30P	200
12	Wed	8.7	0.02	0.92	1.00	2.49	142.55500	Jeff R	3:30P	300
13	Thurs									
14	Fri									
15	Sat									
16	Sun									
17	Mon	8.7	0.02	0.41	0.47	2.30	142.56900	Jeff R	3:30P	1400
18	Tues	8.7	0.02	0.54	0.62	2.35	142.57300	Jeff R	3:30P	400
19	Wed	8.7	0.04	0.52	0.60	2.58	142.58000	Jeff R	11:00A	700
20	Thurs	8.7	0.03	0.81	0.61	2.69	142.58600	Jeff R	2:00P	600
21	Fri									
22	Sat									
23	Sun									
24	Mon	8.7	0.02	0.41	0.45	2.26	142.58800	Jeff R	3:30P	200
25	Tues	8.7	0.00	0.78	0.86	2.31	142.59000	Jeff R	3:30P	200
26	Wed	8.7	0.03	0.60	0.68	2.48	142.59300	Jeff R	2:00P	300
27	Thurs									
28	Fri									
29	Sat									
30	Sun									
31	Mon	8.7	0.02	0.46	0.54	2.67	142.60300	Jeff R	3:30P	1000



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

11 July 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23G0517
Project: Drinking Water Dassa McKinney - Annual
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Entry Point 101	23G0517-01	Drinking Water	07/06/2023 11:05	7/6/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/11/2023 15:42

Lab Sample ID#: 23G0517-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: Entry Point 101

Sample Date: 07/06/2023 11:05
Receipt Date: 07/06/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: EPA300.0 2.1				Prep Method: No Prep - WetChem		
Nitrate	<0.100	mg/L		0.100	TLL	07/07/23 01:53	07/07/23 01:53
Nitrite	<0.100	mg/L		0.100	TLL	07/07/23 01:53	07/07/23 01:53

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E ___ 1 ___ OF ___ 1 ___

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



23G0517

ST DIVISION
Incl
PA 16150
EST

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Date				
EP 101 TREATMENT ROOM	23G0517		7/10/03	DW	1	Plastic Pint Preservative None	Nitrate, Nitrite PH

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Annual

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name:

MONTTEAU SCHOOL DISTRICT

Address:

391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person:

JEFFREY CAMPBELL

Phone Number:

724-406-4426

Cell Phone:

icampbell@montteau.org

Email Address:

Billing Address:

5100316

PW/SID:

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature

Sampled By: (Signature)

7/10/03
Date/ Time

Relinquished By: (Signature)

7/10/03
Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monitew</u>	Work Order: 23G0517
------------------------	--



PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JMD / 00382</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>7/6/23 1330</u>	Date Sampled: <u>7/6/23</u>
Method of Delivery: FedEx UPS Client Drop off ESL courier Other: _____	
Sample Receipt Temperature: <u>4.1</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details Completed (if different from above): _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO	Comments:
COC form is properly signed in relinquished/received sections?	YES NO	Comments:
Sample containers intact and sealed?	YES NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO	Sample IDs and Containers Affected:
Samples received within holding time?	YES NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES NO	Sample IDs and Containers Affected:
Other Comments:		Deficiency Log Created:
		YES NO

Effective Date: _____

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW111

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BROW236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8378
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G0640
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23G0640-01	Drinking Water	07/06/2023 11:00	7/6/23 14:32	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/12/2023 08:43

Lab Sample ID#: 23G0640-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 07/06/2023 11:00
Receipt Date: 07/06/2023 14:32

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-C1 G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.640	mg/L		0.200	PS	07/06/23 11:00	07/06/23 11:00
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00
E. Coli	Absent	per 100 mL		1	DAA	07/06/23 15:13	07/07/23 16:00

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
 1803 Philadelphia St
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Vortals, PA 15366
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHEAST DIVISION
 435 Bro. Monour
 (570) 32
 FAX: (570) 32

FOR INTERNAL LABORATORY



23G0640

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
801 KITCHEN SINK	55666			DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.64 mg/L
802 ROOM 617 SINK							

Rotation:
 801: Jan, Mar, May, Jul, Sep, Nov
 802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Monthly

Sampled By: (Signature) *[Signature]* Date/ Time *7:00 PM Dec 7-03*

Relinquished By: (Signature) *[Signature]* Date/ Time *7:00 PM Dec 7-03*

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature *3.0* #3

Company/Name: **MONTTEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD WEST SUNBURY, PA 16061**
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **724-406-4426**
 Email Address: **jcampbell@montiteau.org**
 Billing Address: _____
 PWSID: **5100316**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysi s Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G1718
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23G1718-01	Drinking Water	07/13/2023 12:00	7/13/23 14:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 07/18/2023 17:04

Lab Sample ID#: 23G1718-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 07/13/2023 12:00
Receipt Date: 07/13/2023 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.530	mg/L		0.200	PS	07/13/23 12:00	07/13/23 12:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 171754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Field	Container Type	Analysis Requested
		Grab	Time					
Distribution: <u>SEA</u>	<u>256718</u>			DW	Field	Field	Field	Free Chlorine <u>0.53</u> mg/L

ROTATION

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name:

MONTTEAU SCHOOL DISTRICT

Address:

391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person:

JEFFREY CAMPBELL

Phone Number:

724-406-4426

Cell Phone:

jcampbell@monteau.org

Email Address:

5100316

Billing Address:

PWSID:

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Company/Name: **MONTTEAU SCHOOL DISTRICT**

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@monteau.org

Email Address: 5100316

Billing Address:

PWSID:

Sampled By: (Signature)

Date/ Time

7/13/05 08:12:05

Relinquished By: (Signature)

Date/ Time

7/13/05 11:14:55

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111
5100316	1013	FREE CHLORINE	301	0.53	071323	802		071323	D	1200	32382	23G1718-01	BROW 556

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

21 July 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G2649
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23G2649-01	Drinking Water	07/20/2023 11:35	7/20/23 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 07/21/2023 16:22

Lab Sample ID#: 23G2649-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 07/20/2023 11:35
Receipt Date: 07/20/2023 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.400	mg/L		0.200	PS	07/20/23 11:35	07/20/23 11:35

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL LABOR

CAMPBELL ENVIRONMENTAL LABORATORY



3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>7562649</u>			DW	Field	Field	Free Chlorine <u>0.40</u> mg/L

- ROTATION**
- WK 1 - 801 Kitchen Sink
 - WK 2 - 802 Room 617 Sink
 - WK 3 - 803 Room 606 Sink
 - WK 4 - 804 Room 408 Sink
 - WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: *Drinking Water Dassa McKinney - Weekly*

<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>7/20/03 18:15</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>7/20/03 18:15</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Correct Preservations <input checked="" type="checkbox"/> N / NA Correct Containers <input checked="" type="checkbox"/> N / NA Receipt Temperature <u>2.4</u> # <u>3</u></p>	<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>7-20-03 14:00</u></p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Company/Name: MONTICAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: _____ Phone Number: 724-406-4426 Cell Phone: icampbell@monticau.org Email Address: _____ Billing Address: _____ PWSID: 5100316</p>
--	---



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111
5100316	1013	FREE CHLORINE	301	0.53	071323	802		071323	D	1200	32382	23G1718-01	BROW 556
5100316	1013	FREE CHLORINE	301	0.4	072023	804		072023	D	1135	32382	23G2649-01	BROW 1964

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Reco
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 236



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

01 August 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23G3418
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23G3418-01	Drinking Water	07/27/2023 10:55	7/27/23 13:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Data Qualifiers/Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 08/01/2023 13:39

Lab Sample ID#: 23G3418-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 07/27/2023 10:55
Receipt Date: 07/27/2023 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-C1 G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.580	mg/L		0.200	PS	07/27/23 10:55	07/27/23 10:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
 803 Philadelphia St.
 Merama, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Voorhis, PA 15386
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN DIVISION
 435 Broad Street
 Montoursville, PA 17784
 (570) 321-9003
 FAX: (570) 321-1957

NORTHWEST DIVISION
 950 Main Street
 Sharpville, PA 16
 (724) 463-TEST
 FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>2308</u>	<u>1/18</u>	<u>07</u>	<u>DW</u>	<u>1655</u>	Field	Free Chlorine <u>0.58</u> mg/L

- ROTATION**
- WK 1 - 801 Kitchen Sink
 - WK 2 - 802 Room 617 Sink
 - WK 3 - 803 Room 606 Sink
 - WK 4 - 804 Room 408 Sink
 - WK 5 - 802 Room 617 Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH, (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **icampbell@moniteau.org**
 Email Address: **5100316**
 Billing Address:
 PWSID:

Sampled By: (Signature) [Signature] Date/ Time 7/27/23 1655
 Relinquished By: (Signature) [Signature] Date/ Time 7/27/23 1815

Received By: (Signature) [Signature] Date/ Time 7-23-23 1815

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y/N / NA Correct Containers Y/N / NA Receipt Temperature _____



E-Government Application for Drinking Water
Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Recor
5100316	1013	FREE CHLORINE	301	0.64	070623	801		070623	D	1100	32382	23G0640-01	BROW 103
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	070723	801		070623	D	1100	32382	23G0640-01	BROW 111
5100316	1013	FREE CHLORINE	301	0.53	071323	802		071323	D	1200	32382	23G1718-01	BROW 556
5100316	1013	FREE CHLORINE	301	0.4	072023	804		072023	D	1135	32382	23G2649-01	BROW 1964
5100316	1013	FREE CHLORINE	301	0.58	072723	804		072723	D	1055	32382	23G3418-01	BROW 2837

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Recor
5100316	1040	NITRATE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 227
5100316	1041	NITRITE	120	0.0	0.10000		070723	101		070623	E	1105	32382	23G0517-01	BRO 236