

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for November 2022

**COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220
 FACILITY: MONTEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220
 STAGE: Final Effluent

PA0091341
 PERMIT NUMBER

001
 OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 11/01/2022
 DMR Effective To: 11/30/2022
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2022	11	01	2022	11	30

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION						SAMPLING FREQUENCY	SAMPLING TYPE	
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS	VALUE	UNITS			
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.77	***	***	***	***	***	***	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	***	***	***	***	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		7.18	***	8.62	***	9.0	***	***	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	***	Max	***	<5.0	***	***	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***	***	30	***	Avg Mo	***	***	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	1.37	***	Monitor & Report Avg Mo	***	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		***	***	***	***	Monitor & Report Avg Mo	***	***	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	.16	***	Monitor & Report Avg Mo	***	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		***	***	6.02	***	Monitor & Report Avg Mo	***	***	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	***	***	Monitor & Report Avg Mo	***	***	1/week	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	***	***	***	Monitor & Report Avg Mo	***	***	1/week	Grab
	PERMIT REQUIREMENT	***		***	***	***	***	Monitor & Report Avg Mo	***	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.002034	MGD	***	***	***	***	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	MGD	***	***	***	***	***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***	<1.0	<1.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***	2000	Geo Mean	10000	IMAX	2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***	<2.00	***	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***	25	Avg Mo	***	***	2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>

Fri, Dec 2, 2022 at 9:46 AM

To: jcampbell@moniteau.org, mcafoose92@hotmail.com

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 11/01/2022-11/30/2022

Report Due Date: 12/28/2022

Submitted By: Jeffrey Campbell

Submission Id: 362639

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Monthly Operations Report

November 2022

11/3

Flow	61,035 ÷ 30 =		2,034.5	Daily Avg.
U.V. light	114.5 ÷ 19 =		6.02	Daily Avg.
PH low	7.18	11/1 - #2	BASIN	
	8.62	11/18 - #1	BASIN	
D.O. low	7.77	11/23 - #2	BASIN	
	10.49	11/14 #2	BASIN	
Total Nitrogen	2.01	< 0.729	2.739 ÷ 2 =	1.369
TKN	< 0.625	< 0.625		< 0.625
TSS	< 5	< 5		< 5
Nitrate/Nitrite	2.01	0.180	2.19 ÷ 2 =	1.095
Phos.	0.20	0.12	0.32 ÷ 2 =	0.16
CBOD	< 2.00	< 2.00		< 2.00
Fecal	1	< 1		< 1



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

15 November 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22K0444
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	22K0444-01	Waste Water	11/03/2022 10:00	11/3/22 14:44	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/15/2022 15:51

Lab Sample ID#: 22K0444-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 11/03/2022 10:00
Receipt Date: 11/03/2022 14:44

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD				Prep Method: [CALC]		
Total Nitrogen	2.01	mg/L		0.729	DAA	11/10/22 17:45	11/11/22 17:54
General Chemistry	Analytical Method: EPA 351.2 2.0				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	11/10/22 06:45	11/11/22 17:54
General Chemistry	Analytical Method: SM2540 D-15				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	ATJ	11/10/22 12:00	11/10/22 18:15
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	2.01	mg/L		0.104	DAA	11/10/22 17:45	11/11/22 11:57
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.20	mg/L		0.10	DAA	11/11/22 14:13	11/14/22 18:46
General Chemistry	Analytical Method: SM5210 B-16				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	SS	2.00	TJC	11/04/22 16:22	11/09/22 13:18
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	1	MPN/100 mL		1	DAA	11/03/22 15:46	11/04/22 12:15



SAMPLE RECEIPT AND REVIEW FORM

Client: MONITEAU SD Work Order _____



PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____ Date/Time Received: / / _____
 Method of Delivery: Client Drop-Off ESL Courier Other: _____ Received on Ice? YES NO
 Sample Receipt Temperature: _____ °C IR Gun ID: _____
 Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: MKE (00382) Samples Received on Ice? YES NO
 Date/Time Received: 11 / 3 / 22 1444 Date Sampled: 11 / 3 / 22
 Method of Delivery: FedEx UPS Client Drop off ESL courier Other: _____
 Sample Receipt Temperature: 4.5 °C IR Gun ID: 3
 Sample State of Collection: PA NY OH WV Other: _____ PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details

Completed (if different from above): _____ Signature _____ Date / / _____ Time _____

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="radio"/>	<input type="radio"/>	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/>	<input type="radio"/>	Comments:
Sample containers intact and sealed?	<input checked="" type="radio"/>	<input type="radio"/>	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/>	<input type="radio"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="radio"/>	<input type="radio"/>	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input type="radio"/>	<input checked="" type="radio"/>	Sample IDs and Containers Affected:
Other Comments:			
			Deficiency Log Created: YES <input checked="" type="radio"/> NO

Effective Date:



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

30 November 2022

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 22K1778
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	22K1778-01	Waste Water	11/17/2022 10:30	11/17/22 13:44	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/30/2022 09:23

Lab Sample ID#: 22K1778-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 11/17/2022 10:30
Receipt Date: 11/17/2022 13:44

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD				Prep Method: [CALC]		
Total Nitrogen	<0.729	mg/L		0.729	DAA	11/28/22 06:30	11/28/22 17:47
General Chemistry	Analytical Method: EPA 351.2 2.0				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	11/28/22 06:30	11/28/22 17:47
General Chemistry	Analytical Method: SM2540 D-15				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	TLL	11/22/22 11:02	11/22/22 16:15
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.180	mg/L		0.104	AW	11/23/22 10:19	11/23/22 10:19
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.12	mg/L		0.10	AW	11/21/22 13:05	11/21/22 13:05
General Chemistry	Analytical Method: SM5210 B-16				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB	2.00	TJC	11/18/22 15:48	11/23/22 09:54
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	AMB	11/17/22 15:18	11/18/22 11:54



22K1778

SAMPLE REQUEST & CHAIN OF CUST


ENVIRONMENTAL SERVICE LABORATORIES, INC. HEADQUARTERS 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209		<input checked="" type="checkbox"/>		SOUTHERN DIVISION 1276 Beniteville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376		<input type="checkbox"/>		NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957		NORTHWEST DIVISION 950 Main Street Sharpville, PA 16150 (724) 463-TEST FAX: (724) 465-4209		<input type="checkbox"/>	
--	--	-------------------------------------	--	--	--	--------------------------	--	---	--	--	--	--------------------------	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type	Analysis Requested				
		Composite	Grab								
		Date on/of	Time on/of	Date	Time						
Effluent Outfall 001	22K1778			11/17/22	10:30 AM	WW	1	Poly 1000mL	CBOD, TSS		
	01					WW	1	None	Total Nitrogen, Total Phosphorus		
						WW	1	H2SO4	Fecal Coliform		
								Sterile Plastic 125mL			
								Na2S2O3			
Project Notes: Wastewater								Company/Name: MONITEAU SCHOOL DISTRICT			
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.								Contact Person: JEFFREY CAMPBELL Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 Phone / Cell: 724-406-4426 Email: jcampbell@moniteau.org			
Sampled By: (Signature) <i>[Signature]</i> Date/ Time 11/17/22 10:30 AM		Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 11/17/22 1110		Received By: (Signature) <i>[Signature]</i> Date/ Time 11-17-22 1344		Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 11-17-22 1335		Received By: (Signature) <i>[Signature]</i> Date/ Time			
Correct Preservations Y/N/NA		Correct Containers Y/N/NA		Receipt Temperature							



SAMPLE RECEIPT AND REVIEW FORM

Client: MONITEAU SD Work Order:  22K1778

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____ Date/Time Received: / /
 Method of Delivery: Client Drop-Off ESL Courier Other: _____ Received on Ice? YES NO
 Sample Receipt Temperature: _____ °C IR Gun ID: _____
 Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: MKE (00382) Samples Received on Ice? YES NO
 Date/Time Received: 11/17/22 1344 Date Sampled: 11/17/22
 Method of Delivery: FedEx UPS Client Drop off ESL courier Other: _____
 Sample Receipt Temperature: 2.1 °C IR Gun ID: 3
 Sample State of Collection: PA NY OH WV Other: _____ PWSID Compliance Drinking Water Samples: YES NO

PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="radio"/>	<input type="radio"/>	Comments: _____
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/>	<input type="radio"/>	Comments: _____
Sample containers intact and sealed?	<input checked="" type="radio"/>	<input type="radio"/>	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected: _____
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected: _____
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected: _____
Samples received within holding time?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected: _____
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected and Observed pH: _____
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/>	<input type="radio"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="radio"/>	<input type="radio"/>	Analyses Affected: _____
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected: _____
Other Comments:	<input checked="" type="radio"/>	<input type="radio"/>	

Deficiency Log Created: YES NO

Effective Date: _____

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for November 2022

MONITEAU HIGH SCHOOL WATER TREATMENT PLANT												
MONTH	NOV	2022	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	Tues	60.4	10.63	7,288,848	0.62	0.67	7.0	0.00	0	1.27	Jeff C	2:00 PM
2	Wed	60.6	9.87	7,288,848	0.62	0.67	7.0	0.00	0	1.25	Jeff C	9:00 AM
3	Thurs	59.8	8.57	7,288,848	0.62	0.67	7.0	0.00	0	1.25	Jeff C	8:45 AM
4	Fri	61.5	10.77	7,301,670	0.58	0.64	7.0	0.01	0	1.17	Jeff C	5:30 AM
5	SAT											
6	SUN											
7	Mon	64.1	9.20	7,301,670	0.61	0.68	7.1	0.02	0	1.27	Jeff R	11:30 AM
8	Tues	64.2	10.52	7,309,322	0.64	0.70	7.0	0.02	0	1.28	Jeff R	11:45 AM
9	Wed	61.6	11.22	7,315,355	0.56	0.61	7.1	0.00	0	0.99	Jeff R	11:30 AM
10	Thurs	61.4	10.30	7,315,355	0.55	0.58	7.0	0.00	0	1.12	Jeff R	11:30 AM
11	Fri	61.0	9.08	7,315,355	0.55	0.59	7.0	0.00	0	1.11	Jeff C	6:00 PM
12	SAT											
13	SUN											
14	Mon	57.5	8.00	7,315,355	0.51	0.60	6.9	0.00	0	1.55	Jeff C	11:30 AM
15	Tues	54.5	10.72	7,324,153	0.65	0.68	7.0	0.00	0	1.38	Jeff C	4:00 PM
16	Wed	51.9	9.37	7,324,153	0.65	0.70	7.0	0.00	0	1.35	Jeff C	3:00 PM
17	Thurs	51.7	8.73	7,324,153	0.65	0.71	7.0	0.00	0	1.32	Jeff C	10:00 AM
18	Fri	48.0	10.80	7,338,330	0.64	0.70	7.0	0.00	0	1.11	Jeff C	7:00 AM
19	SAT											
20	SUN											
21	Mon	44.0	8.61	7,338,330	0.64	0.70	7.0	0.00	0	1.12	Jeff C	3:00 AM
22	Tues	44.0	8.01	7,338,330	0.63	0.69	7.0	0.00	0	1.11	Jeff C	4:00 PM
23	Wed	50.0	11.62	7,349,883	0.59	0.68	7.0	0.00	0	1.19	Jeff C	10:00 AM
24	Thurs	HOLIDAY		- No School								
25	Fri	49.8	10.19	7,349,883	0.60	0.63	7.0	0.00	0	1.18	Jeff C	8:00 AM
26	SAT											
27	SUN											
28	Mon	HOLIDAY		- No School								
29	Tues	49.8	9.10	7,349,883	0.63	0.65	7.0	0.00	0	1.18	Jeff C	8:00 AM
30	Wed	52.8	8.22	7,349,883	0.62	0.65	7.0	0.00	0	1.19	Jeff C	9:00 AM
31												

METER READING ON 10/31/22
2277859

WATER TEST DAYS

SEWAGE TEST DAYS



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K0492
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	22K0492-01	Drinking Water	11/03/2022 12:10	11/3/22 14:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/11/2022 09:30

Lab Sample ID#: 22K0492-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 11/03/2022 12:10
Receipt Date: 11/03/2022 14:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.630	mg/L		0.200	PS	11/03/22 12:10	11/03/22 12:10
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	11/03/22 15:33	11/04/22 16:50
E. Coli	Absent	per 100 mL		1	DAA	11/03/22 15:33	11/04/22 16:50

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



22K0492

FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRGLE ONE: 704 KITCHEN MAIN SINK 802-ROOM 204 SINK	22K0492	11-3-22	1210	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.63

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) *[Signature]* Date/ Time 11-3-22 1210

Received By: (Signature) *[Signature]* Date/ Time 11-3-22 1435

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations *[Signature]* Y/N/NA Correct Containers *[Signature]* Y/N/NA Receipt Temperature 2.8 #3

Notes/Special Instructions:
Drinking Water Moniteau Jr/Sr - Monthly

Company/Name: **MONITEAU SCHOOL DISTRICT**
Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.org
Billing Address: 5100324
PWSID: 5100324



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	110322	704		110322	D	1210	32382	22K0492-01	BROWNKA_74
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	704		110322	D	1210	32382	22K0492-01	BROWNKA_75



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

16 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K1210
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	22K1210-01	Drinking Water	11/10/2022 11:20	11/10/22 13:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/16/2022 08:48

Lab Sample ID#: 22K1210-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 11/10/2022 11:20
Receipt Date: 11/10/2022 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.520	mg/L			Client	11/10/22 11:20	11/10/22 11:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



22K1210

SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time			
Distribution: <u>802</u>	<u>22K1210</u>	<u>11/02/11</u>	<u>1200</u>	Field	Field	Free Chlorine <u>0.52</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>11/02/11</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>11/02/11</u>
Relinquished By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time	
Correct Preservations	Y / N / NA	Correct Containers	Y / N / NA
Receipt Temperature			

Company/Name:	MONITEAU SCHOOL DISTRICT
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Contact Person:	724-406-4426
Phone Number:	jcambell@moniteau.org
Cell Phone:	
Email Address:	
Billing Address:	
PWSID:	5100324



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	110322	704		110322	D	1210	32382	22K0492-01	BROWNKA_74
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	704		110322	D	1210	32382	22K0492-01	BROWNKA_75
5100324	1013	FREE CHLORINE	301	0.52	111022	802		111022	D	1120	32382	22K1210-01	BROWNKA_329



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K1858
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	22K1858-01	Drinking Water	11/17/2022 11:15	11/17/22 13:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/18/2022 16:11

Lab Sample ID#: 22K1858-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 11/17/2022 11:15
Receipt Date: 11/17/2022 13:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.630	mg/L		0.200	PS	11/17/22 11:15	11/17/22 11:15

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

ENVIRONMENTAL SERVICE LABORATORIES, INC. HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209		SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376		NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957		NORTH 950 Mei Sharpsh (724) 41 FAX: (724) 1858	
---	--	---	--	---	--	---	--



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>22K1858</u>	<u>11/7/82</u>	<u>1115</u>	DW	Field	Field	Free Chlorine <u>0.623</u> mg/L
ROTATION Wk 1 - 704 Kitchen Sink Wk 2 - 802 Room 204 Sink Wk 3 - 803 Admin-Sink Wk 4 - 804 400 Hall RR Sink Wk 5 - 804 400 Hall RR Sink							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time <u>11-17-82 1115</u>	Received By: (Signature) Date/ Time <u>11/17/82 1335</u>
Relinquished By: (Signature) Date/ Time <u>11-17-82 1335</u>	Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____	Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____	Received By: (Signature) _____ Date/ Time _____
Correct Preservations Y / N / NA	Correct Containers Y / N / NA
Receipt Temperature _____	Receipt Temperature _____

Notes/Special Instructions:
Drinking Water Moniteau Jr/Sr - Weekly

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100324**

PWSID: **5100324**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	110322	704		110322	D	1210	32382	22K0492-01	BROWNKA_74
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	704		110322	D	1210	32382	22K0492-01	BROWNKA_75
5100324	1013	FREE CHLORINE	301	0.52	111022	802		111022	D	1120	32382	22K1210-01	BROWNKA_329
5100324	1013	FREE CHLORINE	301	0.63	111722	803		111722	D	1115	32382	22K1858-01	BROWNKA_1190



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

22 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K2079
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	22K2079-01	Drinking Water	11/21/2022 09:05	11/21/22 14:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 11/22/2022 16:29

Lab Sample ID#: 22K2079-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 11/21/2022 09:05
Receipt Date: 11/21/2022 14:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.640	mg/L		0.200	PS	11/21/22 09:05	11/21/22 09:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
 1803 Philadelphia St.
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Voorhis, PA 15366
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN DIVISION
 435 Broad Street
 Montoursville, PA 17754
 (570) 321-9003
 FAX: (570) 321-1957

NORTHWE
 950 Main S
 Sharpsville
 (724) 463-
 FAX: (724)



22K2079

SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: 804	22K 2079	11/21/22	0905	DW	Field	Field	Free Chlorine 0.64 mg/L
<div style="border: 1px solid black; padding: 5px; width: fit-content; margin: 0 auto;"> ROTATION Wk 1 - 704 Kitchen Sink Wk 2 - 802 Room 204 Sink Wk 3 - 803 Admin Sink Wk 4 - 804 400 Hall RR Sink Wk 5 - 804 400 Hall RR Sink </div>							

Notes/Special Instructions: **Drinking Water Moniteau Jr/Sr - Weekly**

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) *[Signature]* Date/ Time 11/21/22 0905
 Received By: (Signature) *[Signature]* Date/ Time 11/21/22 1445
 Received By: (Signature) _____ Date/ Time _____
 Received By: (Signature) _____ Date/ Time _____
 Received By: (Signature) _____ Date/ Time _____

Company Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **jcampbell@moniteau.org**
 Email Address: **jcampbell@moniteau.org**
 Billing Address: _____
 PWSID: **5100324**

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	110322	704		110322	D	1210	32382	22K0492-01	BROWNKA_74
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	704		110322	D	1210	32382	22K0492-01	BROWNKA_75
5100324	1013	FREE CHLORINE	301	0.52	111022	802		111022	D	1120	32382	22K1210-01	BROWNKA_329
5100324	1013	FREE CHLORINE	301	0.63	111722	803		111722	D	1115	32382	22K1858-01	BROWNKA_1190
5100324	1013	FREE CHLORINE	301	0.64	112122	804		112122	D	0905	32382	22K2079-01	BROWNKA_1511

Moniteau School District
Maintenance Department
Dassa McKinney School
Water Treatment Facility
Monthly Report for November 2022

Dassa McKinney Elementary School Water Treatment Facility											
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes	
Nov. 2022											
1	Tues	8.7	0.03	0.67	0.73	2.60	13694100	Jeff R	4:30P	4000	
2	Wed	8.7	0.02	0.70	0.78	2.71	13697400	Jeff R	3:30P	3300	
3	Thurs	8.7	0.00	0.75	0.81	2.38	13702100	Jeff R	4:30P	4700	
4	Fri		CONFERENCE DAY								
5	Sat										
6	Sun										
7	Mon	8.7	0.04	0.60	0.67	2.55	13709600	Jeff R	4:30P	7500	
8	Tues	8.7	0.03	0.69	0.78	2.47	13713700	Jeff R	4:30P	4100	
9	Wed	8.7	0.02	0.59	0.66	2.88	13717500	Jeff R	4:30P	3800	
10	Thurs	8.7	0.00	0.67	0.73	1.89	13718100	Jeff R	3:00P	600	
11	Fri	8.7	0.02	0.65	0.72	1.92	13718900	Jeff R	2:00P	800	
12	Sat										
13	Sun										
14	Mon	8.7	0.01	0.53	0.58	1.87	13720900	Jeff R	12:30P	2000	
15	Tues	8.7	0.00	0.72	0.80	1.98	13723800	Jeff R	12:00P	2900	
16	Wed	8.7	0.00	0.82	0.91	1.88	13727500	Jeff R	12:00P	3700	
17	Thurs	8.7	0.00	0.76	0.86	1.84	13731300	Jeff R	12:00P	3800	
18	Fri	8.7	0.00	0.75	0.84	1.91	13737000	Jeff R	2:00P	5700	
19	Sat										
20	Sun										
21	Mon	8.7	0.00	0.88	0.98	2.97	13750700	Jeff R	4:00P	13700	
22	Tues	8.7	0.00	0.89	0.97	1.74	13754500	Jeff R	4:30P	3800	
23	Wed	8.7	0.00	0.88	0.97	1.82	13754800	Jeff R	2:30P	300	
24	Thurs		HOLIDAY								
25	Fri		HOLIDAY								
26	Sat										
27	Sun										
28	Mon		HOLIDAY								
29	Tues	8.7	0.02	0.67	0.76	2.89	13758000	Jeff R	3:30P	3200	
30	Wed	8.7	0.02	0.75	0.80	1.91	13761000	Jeff C	1:00 PM		
31											

Meter Reading 10/31/2022 - 13690100



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K0491
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	22K0491-01	Drinking Water	11/03/2022 11:50	11/3/22 14:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/11/2022 09:29

Lab Sample ID#: 22K0491-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 11/03/2022 11:50
Receipt Date: 11/03/2022 14:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.780	mg/L		0.200	PS	11/03/22 11:50	11/03/22 11:50
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	11/03/22 15:33	11/04/22 16:50
E. Coli	Absent	per 100 mL		1	DAA	11/03/22 15:33	11/04/22 16:50

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benetleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTH
950 Ma
Sharps
(724) 41
FAX: (724) 465-4209



22K0491

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

801 KITCHEN SINK
802-ROOM 617 SINK

ESL#
22K0491

oi

Sample Type

Grab

Date

Time

11-3-22

1150

Matrix

DW

of Bottles

1

Container Type

Preservative
STERILE PLASTIC

NA THIO

Analysis Requested

TC/EC

Free Chlorine

0.78

mg/L

Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

Notes/Special Instructions:

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Monthly

MONITEAU SCHOOL DISTRICT

391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
724-406-4426
jcampbell@moniteau.org
5100316

Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

Received By: (Signature)
[Signature] 11/3/22 1435

Received By: (Signature)

Received By: (Signature)

Received By: (Signature)

11-3-22 1150

Date/ Time

11-3-22 1435

Date/ Time

Date/ Time

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature 2.8#3



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.78	110322	801		110322	D	1150	32382	22K0491-01	BROWNKA_72
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	801		110322	D	1150	32382	22K0491-01	BROWNKA_73



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K1209
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	22K1209-01	Drinking Water	11/10/2022 11:00	11/10/22 13:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/11/2022 15:39

Lab Sample ID#: 22K1209-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Client
Client Sample ID: 802 Room 617 Sink

Sample Date: 11/10/2022 11:00
Receipt Date: 11/10/2022 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.540	mg/L			Client	11/10/22 11:08	11/10/22 11:08

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
 1803 Philadelphia St.
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Voorhis, PA 15366
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN DIVISION
 435 Broad Street
 Montoursville, PA 17754
 (570) 321-9003
 FAX: (570) 321-1957

NORTHWEST DIVISION
 950 Main Street
 Sharpsville, PA 1
 (724) 463-TEST
 FAX: (724) 465-



22K1209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Bottles	Matrix	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 802	22K1209	11-10-02	11:00	Field	DW	Field	Free Chlorine 0.54 mg/L
ROTATION Wk 1 - 801-Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: *Drinking Water Dassa McKinney - Weekly*

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcambell@moniteau.org**

Cell Phone: **5100316**

Email Address: **jcambell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Sampled By: (Signature) *[Signature]* Date/ Time 11-10-02 11:00

Relinquished By: (Signature) *[Signature]* Date/ Time 11-10-02 13:15

Received By: (Signature) *[Signature]* Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.78	110322	801		110322	D	1150	32382	22K0491-01	BROWNKA_72
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	801		110322	D	1150	32382	22K0491-01	BROWNKA_73
5100316	1013	FREE CHLORINE	301	0.54	111022	802		111022	D	1108	32382	22K1209-01	BROWNKA_328



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K1857
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	22K1857-01	Drinking Water	11/17/2022 10:00	11/17/22 13:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/18/2022 16:09

Lab Sample ID#: 22K1857-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 11/17/2022 10:00
Receipt Date: 11/17/2022 13:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.890	mg/L		0.200	PS	11/17/22 10:00	11/17/22 10:00

SE ___ OF ___

SAMPLE REQUEST & CHAIN OF CUSTODY



ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>803</u>	22K1857			DW	Field	Field	Free Chlorine <u>0.89</u> mg/L
	01						

FOR INTERNAL LABORATORY USE ONLY

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD**

Contact Person: **WEST SUNBURY, PA 16061**

Phone Number: **JEFFREY CAMPBELL**

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Received By: (Signature) [Signature] Date/ Time 11-17-22 1000

Relinquished By: (Signature) [Signature] Date/ Time 11-17-22 1335

Relinquished By: (Signature) [Signature] Date/ Time 11-17-22 1335

Relinquished By: (Signature) [Signature] Date/ Time 11-17-22 1335

Relinquished By: (Signature) [Signature] Date/ Time 11-17-22 1335

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.78	110322	801		110322	D	1150	32382	22K0491-01	BROWNKA_72
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	801		110322	D	1150	32382	22K0491-01	BROWNKA_73
5100316	1013	FREE CHLORINE	301	0.54	111022	802		111022	D	1108	32382	22K1209-01	BROWNKA_328
5100316	1013	FREE CHLORINE	301	0.89	111722	803		111722	D	1000	32382	22K1857-01	BROWNKA_1189



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

22 November 2022

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 22K2080
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	22K2080-01	Drinking Water	11/21/2022 08:50	11/21/22 14:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/22/2022 16:29

Lab Sample ID#: 22K2080-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 11/21/2022 08:50
Receipt Date: 11/21/2022 14:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.770	mg/L		0.200	PS	11/21/22 08:50	11/21/22 08:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

HEADQUARTER
 1803 Philadelphia St.
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Bentleyville Road
 Van Voorhis, PA 15366
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN DIVISION
 435 Broad Street
 Montoursville, PA 17754
 (570) 321-9003
 FAX: (570) 321-1957

NORTHWEST DIVISION
 950 Main Street
 Sharpsville, PA 16
 (724) 463-TEST
 FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>SCH</u>	22K2080	Date: <u>11-21-22</u>	Time: <u>0850</u>	DW	Field	Field	Free Chlorine <u>0.27</u> mg/L
	01						

- ROTATION
- Wk 1 - 801 Kitchen Sink
 - Wk 2 - 802 Room 617 Sink
 - Wk 3 - 803 Room 606 Sink
 - Wk 4 - 804 Room 408 Sink
 - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 11-21-22 0850
 Relinquished By: (Signature) [Signature] Date/ Time 11-21-22 1445

Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA _____ Correct Containers Y / N / NA _____ Receipt Temperature _____

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

Company Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **jcampbell@moniteau.org**
 Billing Address: _____
 PWSID: **5100316**



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.78	110322	801		110322	D	1150	32382	22K0491-01	BROWNKA_72
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	110422	801		110322	D	1150	32382	22K0491-01	BROWNKA_73
5100316	1013	FREE CHLORINE	301	0.54	111022	802		111022	D	1108	32382	22K1209-01	BROWNKA_328
5100316	1013	FREE CHLORINE	301	0.89	111722	803		111722	D	1000	32382	22K1857-01	BROWNKA_1189
5100316	1013	FREE CHLORINE	301	0.77	112122	804		112122	D	0850	32382	22K2080-01	BROWNKA_1510