

**Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Plant
Monthly Report
October 2019**

MONTH	DAY	TEMP	2019 LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
OCT	1	Tues	67.9	7.49	2,719,687	0.54	0.60	7.3	0.02	0	1.47	JEFF C	08:30A
	2	Wed	68.5	7.02	2,723,231	0.59	0.65	7.3	0.00	0	1.75	JEFF C	09:00A
	3	Thurs	69.7	6.70	2,727,247	0.62	0.71	7.3	0.00	0	2.06	JEFF C	09:30A
	4	Fri	68.5	7.08	2,733,760	0.62	0.68	7.3	0.00	0	2.02	JEFF C	09:30A
	5	SAT											
	6	Sun											
	7	Mon	65.0	7.11	2,740,190	0.77	0.83	7.3	0.00	0	1.83	JEFF C	11:00A
	8	Tues	64.1	6.99	2,745,217	0.75	0.81	7.3	0.00	0	1.80	JEFF C	11:00A
	9	Wed	63.6	7.04	2,756,574	0.82	0.93	7.2	0.00	0	1.58	JEFF C	08:30A
	10	Thurs	63.5	7.00	2,756,574	0.82	0.91	7.3	0.00	0	1.62	JEFF C	08:00A
	11	Fri	62.9	6.26	2,756,574	0.81	0.90	7.3	0.00	0	1.62	JEFF C	07:00A
	12	SAT											
	13	Sun											
	14	Mon	62.0	6.27	2,760,527	0.76	0.81	7.3	0.00	0	1.57	JEFF C	11:00A
	15	Tues	62.0	7.76	2,768,216	0.75	0.80	7.3	0.00	0	1.52	JEFF C	09:00A
	16	Wed	61.6	7.82	2,771,441	0.75	0.80	7.3	0.00	0	1.52	JEFF C	1:30P
	17	Thurs	58.6	7.13	2,772,074	0.74	0.77	7.3	0.00	0	1.50	JEFF C	09:00A
	18	Fri	57.6	7.50	2,779,790	0.58	0.69	7.3	0.00	0	1.69	JEFF C	09:00A
	19	SAT											
	20	Sun											
	21	Mon	58.7	7.05	2,788,180	0.59	0.63	7.0	0.01	0	1.19	JEFF R	11:5A
	22	Tues	61.8	7.38	2,793,012	0.51	0.57	6.9	0.02	0	1.81	JEFF R	11:40A
	23	Wed	60.0	6.50	2,795,159	0.58	0.62	6.9	0.01	0	1.08	JEFF R	12:00P
	24	Thurs	59.5	7.29	2,800,671	0.59	0.64	7.1	0.00	0	1.26	JEFF R	12:00P
	25	Fri	61.0	7.70	2,807,714	0.51	0.59	7.0	0.00	0	1.22	JEFF R	11:30A
	26	SAT											
	27	Sun											
	28	Mon	58.6	6.57	2,807,714	0.52	0.58	7.0	0.00	0	1.22	JEFF C	08:30A
	29	Tues	60.0	7.58	2,814,418	0.49	0.56	7.3	0.00	0	1.55	JEFF C	09:00A
	30	Wed	60.9	6.12	2,814,418	0.49	0.54	7.3	0.00	0	1.55	JEFF C	08:30A
	31	Thurs	61.5	7.18	2,821,449	0.54	0.62	7.3	0.00	0	1.38	JEFF C	08:30A

Meter Reading 9/30/19

2,712,843



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9100413
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	9100413-01	Drinking Water	10/03/2019 13:38	10/3/19 15:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/11/2019 12:14

Lab Sample ID#: 9100413-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 10/03/2019 13:38
Receipt Date: 10/03/2019 15:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.510	mg/L		0.200	PFS	10/03/19 13:38	10/03/19 13:38
Chlorine, Total	0.620	mg/L		0.200	PFS	10/03/19 13:38	10/03/19 13:38
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	ANP	10/03/19 16:26	10/04/19 16:28
E. Coli	Absent	per 100 mL		1	ANP	10/03/19 16:26	10/04/19 16:28

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



1803 Philadelphia St.
 Indiana, PA 15701
 P: 724-463-TEST
 F: 724-465-4209

1276 Bentleyville Rd.
 Van Voorhis, PA 15366
 P: 724-258-TEST
 F: 724-258-8376

1200 River Avenue
 Williamsport, PA 17701
 P: 570-321-9002
 F: 570-321-1957

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE _____ OF _____

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802-ROOM-617-SINK	9100413	10-3-19	1338	DW	1	STERILE PLASTIC NA THIO	TC / EC TRC <u>1.62</u> Free Chlorine <u>1.51</u> mg/L
EP 101				DW	1	PLASTIC LITER NONE	3.4 ilc @ 1525 XMR 10/3/19

704: Jan, Mar, May, Jul, Sept, Nov
 802: Feb, Apr, Jun, Aug, Oct, Dec



9100413

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

PWSID: 5100324
 Jr-Sr High

Sampled By: (Signature) [Signature] Date/ Time 10-3-19 1338
 Relinquished By: (Signature) [Signature] Date/ Time 10-3-19 1528

Received By: (Signature) [Signature] Date/ Time 10-3-19 1554
 Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

Company/Name: **MONTEAU SCHOOL DISTRICT**
 Address: 1810 WEST SUNBURY ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: _____
 Email Address: jcampbell@monteau.k12.pa.us
 Billing Address: _____

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1000	TOTAL CHLORINE	301	0.49	090519	704		090519	D	1330	32382	9090446-01	BROWNKA_58
5100324	1000	TOTAL CHLORINE	301	0.62	100319	704		100319	D	1338	32382	9100413-01	BROWNKA_2626
5100324	1013	FREE CHLORINE	301	0.38	090519	704		090519	D	1330	32382	9090446-01	BROWNKA_59
5100324	1013	FREE CHLORINE	301	0.51	100319	704		100319	D	1338	32382	9100413-01	BROWNKA_2627
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090619	704		090519	D	1330	32382	9090446-01	BROWNKA_60
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100419	704		100319	D	1338	32382	9100413-01	BROWNKA_2628
5100324	1013	FREE CHLORINE	301	0.49	091219	802		091219	D	1325	32382	9091114-01	BROWNKA_337
5100324	1013	FREE CHLORINE	301	0.57	091919	803		091919	D	1230	32382	9091743-01	BROWNKA_874
5100324	1013	FREE CHLORINE	301	0.4	092619	804		092619	D	1150	32382	9092306-01	BROWNKA_1544



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

25 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9100725
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	9100725-01	Drinking Water	10/10/2019 13:20	10/11/19 8:13	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/25/2019 14:11

Lab Sample ID#: 9100725-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 10/10/2019 13:20
Receipt Date: 10/11/2019 08:13

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.770	mg/L		0.200	PFS	10/10/19 13:20	10/10/19 13:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-19

FOR INTERNAL LABORATORY USE ONLY



9100725

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: _____	9100725			DW	Field	Field	Free Chlorine .77 mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:..

Jr/Sr High School - Weekly

Sampled By: (Signature) _____ Date/ Time 10-10-19 1330

Company/Name: **MONTTEAU SCHOOL DISTRICT**

Relinquished By: (Signature) _____ Date/ Time 10-10-19 1500

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061

Relinquished By: (Signature) _____ Date/ Time _____

Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426

Relinquished By: (Signature) _____ Date/ Time _____

Email Address: jcampbell@montiteau.k12.pa.us
Billing Address: _____
PWSID: 5100324

Correct Preservations Y/N/NA _____ Correct Containers Y/N/NA _____ Receipt Temperature _____

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.77	101019	802		101019	D	1320	32382	9100725-01	BROWNKA_916
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.47	102419	804		102419	D	1145	32382	9102278-01	BROWNKA_870



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

17 October 2019

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 9101746
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	9101746-01	Drinking Water	10/17/2019 13:10	10/17/19 15:19	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/17/2019 16:09

Lab Sample ID#: 9101746-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 10/17/2019 13:10
Receipt Date: 10/17/2019 15:19

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.630	mg/L		0.200	PFS	10/17/19 13:10	10/17/19 13:10



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376


NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification Sample ID: <u>ESL# 9101746</u>		Sample Type Grab <u>1310</u> Date <u>10/17/19</u> Time <u>1310</u>		Container Type Preservative <u>Field</u>		Analysis Requested Free Chlorine <u>63</u> mg/L	
Distribution: <u>01</u>		Matrix <u>DW</u>		# of Bottles Field		mg/L	
<p style="text-align: center;">ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p style="text-align: center;">THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature) 		Date/ Time <u>10/17/19 1310</u>		Notes/Special Instructions: <u>Jr/Sr High School - Weekly</u>			
Relinquished By: (Signature)		Date/ Time <u>10/17/19 1450</u>		Company/Name: <u>MONITEAU SCHOOL DISTRICT</u>			
Relinquished By: (Signature)		Date/ Time		Address: <u>391 HOOKER ROAD</u>			
Relinquished By: (Signature)		Date/ Time		Contact Person: <u>JEFFREY CAMPBELL</u>			
Relinquished By: (Signature)		Date/ Time		Phone Number: <u>724-406-4426</u>			
Relinquished By: (Signature)		Date/ Time		Cell Phone: <u>jcampbell@moniteau.k12.pa.us</u>			
Relinquished By: (Signature)		Date/ Time		Email Address: <u>jcampbell@moniteau.k12.pa.us</u>			
Relinquished By: (Signature)		Date/ Time		Billing Address: <u>5100324</u>			
Relinquished By: (Signature)		Date/ Time		PWSID:			
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Receipt Temperature			





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9102278
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	9102278-01	Drinking Water	10/24/2019 11:45	10/24/19 14:03	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/24/2019 16:10

Lab Sample ID#: 9102278-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/24/2019 11:45
Receipt Date: 10/24/2019 14:03

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field			
Chlorine, Free	0.470	mg/L		0.200	PFS	10/24/19 11:45	10/24/19 11:45

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.47	102419	804		102419	D	1145	32382	9102278-01	BROWNKA_870

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

Sample Identification	ESL#	9102278	Matrix	# of Bottles	Container Type	Analysis Requested
	Sample Type	Grab				
Distribution:	Date	10/24/19	Time	11:45	Field	mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: Jr/Sr High School - Weekly

Sampled By: (Signature)	10/24/19 11:45	Date/ Time
Relinquished By: (Signature)	10/24/19 1340	Date/ Time
Relinquished By: (Signature)		Date/ Time
Relinquished By: (Signature)		Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature

Company Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@moniteau.k12.pa.us

Email Address: jcampbell@moniteau.k12.pa.us

Billing Address: 5100324

PWSID: 5100324



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

31 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9102743
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	9102743-01	Drinking Water	10/31/2019 12:35	10/31/19 14:33	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/31/2019 15:25

Lab Sample ID#: 9102743-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/31/2019 12:35
Receipt Date: 10/31/2019 14:33

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.700	mg/L		0.200	PFS	10/31/19 12:35	10/31/19 12:35



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1022	COPPER	171	0.22	081319	001		080819	D	0500	32382	9080801-01	BROWNKA_1104
5100324	1030	LEAD	171	0.0	081319	001		080819	D	0500	32382	9080801-01	BROWNKA_1105
5100324	1022	COPPER	171	0.036	081319	002		080819	D	0505	32382	9080801-02	BROWNKA_1106
5100324	1030	LEAD	171	0.0	081319	002		080819	D	0505	32382	9080801-02	BROWNKA_1107
5100324	1022	COPPER	171	0.029	081519	003		080819	D	0510	32382	9080801-03	BROWNKA_1108
5100324	1030	LEAD	171	0.0	081519	003		080819	D	0510	32382	9080801-03	BROWNKA_1109
5100324	1022	COPPER	171	0.23	081519	004		080819	D	0515	32382	9080801-04	BROWNKA_1110
5100324	1030	LEAD	171	0.0	081519	004		080819	D	0515	32382	9080801-04	BROWNKA_1111
5100324	1022	COPPER	171	0.22	081519	005		080819	D	0520	32382	9080801-05	BROWNKA_1112
5100324	1030	LEAD	171	0.0	081519	005		080819	D	0520	32382	9080801-05	BROWNKA_1113
5100324	1022	COPPER	171	0.22	081519	006		080819	D	0525	32382	9080801-06	BROWNKA_1114
5100324	1030	LEAD	171	0.0	081519	006		080819	D	0525	32382	9080801-06	BROWNKA_1115
5100324	1022	COPPER	171	0.26	081519	007		080819	D	0530	32382	9080801-07	BROWNKA_1116
5100324	1030	LEAD	171	0.0030	081519	007		080819	D	0530	32382	9080801-07	BROWNKA_1117
5100324	1022	COPPER	171	0.24	081519	008		080819	D	0535	32382	9080801-08	BROWNKA_1118
5100324	1030	LEAD	171	0.0	081519	008		080819	D	0535	32382	9080801-08	BROWNKA_1119
5100324	1022	COPPER	171	0.033	081519	009		080819	D	0540	32382	9080801-09	BROWNKA_1120
5100324	1030	LEAD	171	0.0	081519	009		080819	D	0540	32382	9080801-09	BROWNKA_1121
5100324	1022	COPPER	171	0.38	081519	010		080819	D	0545	32382	9080801-10	BROWNKA_1122

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1030	LEAD	171	0.0	081519	010		080819	D	0545	32382	9080801-10	BROWNKA_1123
5100324	1013	FREE CHLORINE	301	0.77	101019	802		101019	D	1320	32382	9100725-01	BROWNKA_916
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.47	102419	804		102419	D	1145	32382	9102278-01	BROWNKA_870
5100324	1013	FREE CHLORINE	301	0.7	103119	804		103119	D	1235	32382	9102743-01	BROWNKA_1170

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



9102743

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL #	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>9102743</u>	<u>10/3/19</u>	<u>1235</u>	DW	Field	Field	Free Chlorine <u>70</u> mg/L

ROTATION
Wk 1 - 704 Kitchen Sink
Wk 2 - 802 Room 204 Sink
Wk 3 - 803 Admin Sink
Wk 4 - 804 400 Hall RR Sink
Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: Jr/Sr High School - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.k12.pa.us
Billing Address: 5100324
PWSID: 5100324

Sampled By: (Signature) [Signature] Date/ Time 10-3/19 1235
Relinquished By: (Signature) [Signature] Date/ Time 10/3/19 1410
Relinquished By: (Signature) [Signature] Date/ Time 10/3/19 14:33
Relinquished By: (Signature) [Signature] Date/ Time
Relinquished By: (Signature) [Signature] Date/ Time

Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature

**Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Plant
Monthly Report
October 2019**

MONTH	DAY	TEMP	2019 LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
OCT	1	67.9	7.49	2,719,687	0.54	0.60	7.3	0.02	0	1.47	JEFF C	08:30A
	2	68.5	7.02	2,723,231	0.59	0.65	7.3	0.00	0	1.75	JEFF C	09:00A
	3	69.7	6.70	2,727,247	0.62	0.71	7.3	0.00	0	2.06	JEFF C	09:30A
	4	68.5	7.08	2,733,760	0.62	0.68	7.3	0.00	0	2.02	JEFF C	09:30A
	5	SAT										
	6	Sun										
	7	Mon	65.0	7.11	2,740,190	0.77	0.83	7.3	0.00	1.83	JEFF C	11:00A
	8	Tues	64.1	6.99	2,745,217	0.75	0.81	7.3	0.00	1.80	JEFF C	11:00A
	9	Wed	63.6	7.04	2,756,574	0.82	0.93	7.2	0.00	1.58	JEFF C	08:30A
	10	Thurs	63.5	7.00	2,756,574	0.82	0.91	7.3	0.00	1.62	JEFF C	08:00A
	11	Fri	62.9	6.26	2,756,574	0.81	0.90	7.3	0.00	1.62	JEFF C	07:00A
	12	SAT										
	13	Sun										
	14	Mon	62.0	6.27	2,760,527	0.76	0.81	7.3	0.00	1.57	JEFF C	11:00A
	15	Tues	62.0	7.76	2,768,216	0.75	0.80	7.3	0.00	1.52	JEFF C	09:00A
	16	Wed	61.6	7.82	2,771,441	0.75	0.80	7.3	0.00	1.52	JEFF C	1:30P
	17	Thurs	58.6	7.13	2,772,074	0.74	0.77	7.3	0.00	1.50	JEFF C	09:00A
	18	Fri	57.6	7.50	2,779,790	0.58	0.69	7.3	0.00	1.69	JEFF C	09:00A
	19	SAT										
	20	Sun										
	21	Mon	58.7	7.05	2,788,180	0.59	0.63	7.0	0.01	1.19	JEFF R	11:5A
	22	Tues	61.8	7.38	2,793,012	0.51	0.57	6.9	0.02	1.81	JEFF R	11:40A
	23	Wed	60.0	6.50	2,795,159	0.58	0.62	6.9	0.01	1.08	JEFF R	12:00P
	24	Thurs	59.5	7.29	2,800,671	0.59	0.64	7.1	0.00	1.26	JEFF R	12:00P
	25	Fri	61.0	7.70	2,807,714	0.51	0.59	7.0	0.00	1.22	JEFF R	11:30A
	26	SAT										
	27	Sun										
	28	Mon	58.6	6.57	2,807,714	0.52	0.58	7.0	0.00	1.22	JEFF C	08:30A
	29	Tues	60.0	7.58	2,814,418	0.49	0.56	7.3	0.00	1.55	JEFF C	09:00A
	30	Wed	60.9	6.12	2,814,418	0.49	0.54	7.3	0.00	1.55	JEFF C	08:30A
	31	Thurs	61.5	7.18	2,821,449	0.54	0.62	7.3	0.00	1.38	JEFF C	08:30A

Meter Reading 9/30/19

2,712,843



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9100413
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	9100413-01	Drinking Water	10/03/2019 13:38	10/3/19 15:25	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/11/2019 12:14

Lab Sample ID#: 9100413-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 10/03/2019 13:38
Receipt Date: 10/03/2019 15:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.510	mg/L		0.200	PFS	10/03/19 13:38	10/03/19 13:38
Chlorine, Total	0.620	mg/L		0.200	PFS	10/03/19 13:38	10/03/19 13:38
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	ANP	10/03/19 16:26	10/04/19 16:28
E. Coli	Absent	per 100 mL		1	ANP	10/03/19 16:26	10/04/19 16:28

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



1803 Philadelphia St.
 Indiana, PA 15701
 P: 724-463-1EST
 F: 724-465-4209

1276 Bentleyville Rd.
 Van Voorhis, PA 15366
 P: 724-258-TEST
 F: 724-258-8376

1200 River Avenue
 Williamsport, PA 17701
 P: 570-321-9002
 F: 570-321-1957

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE _____ OF _____

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802-ROOM-617-SINK	9100413	10-3-19	1338	DW	1	STERILE PLASTIC NA THIO	TC / EC TRC <u>1.62</u> Free Chlorine <u>1.51</u> mg/L
EP 101				DW	1	PLASTIC LITER NONE	3.4 ilc @ 1525 XMR 10/3/19

704: Jan, Mar, May, Jul, Sept, Nov
 802: Feb, Apr, Jun, Aug, Oct, Dec



9100413

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

PWSID: 5100324
 Jr-Sr High

Sampled By: (Signature) [Signature] Date/ Time 10-3-19 1338
 Relinquished By: (Signature) [Signature] Date/ Time 10-3-19 1528

Received By: (Signature) [Signature] Date/ Time 10-3-19 1554
 Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

Company/Name: **MONTEAU SCHOOL DISTRICT**
 Address: 1810 WEST SUNBURY ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: _____
 Email Address: jcampbell@monteau.k12.pa.us
 Billing Address: _____

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1000	TOTAL CHLORINE	301	0.49	090519	704		090519	D	1330	32382	9090446-01	BROWNKA_58
5100324	1000	TOTAL CHLORINE	301	0.62	100319	704		100319	D	1338	32382	9100413-01	BROWNKA_2626
5100324	1013	FREE CHLORINE	301	0.38	090519	704		090519	D	1330	32382	9090446-01	BROWNKA_59
5100324	1013	FREE CHLORINE	301	0.51	100319	704		100319	D	1338	32382	9100413-01	BROWNKA_2627
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090619	704		090519	D	1330	32382	9090446-01	BROWNKA_60
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100419	704		100319	D	1338	32382	9100413-01	BROWNKA_2628
5100324	1013	FREE CHLORINE	301	0.49	091219	802		091219	D	1325	32382	9091114-01	BROWNKA_337
5100324	1013	FREE CHLORINE	301	0.57	091919	803		091919	D	1230	32382	9091743-01	BROWNKA_874
5100324	1013	FREE CHLORINE	301	0.4	092619	804		092619	D	1150	32382	9092306-01	BROWNKA_1544



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

25 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9100725
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	9100725-01	Drinking Water	10/10/2019 13:20	10/11/19 8:13	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/25/2019 14:11

Lab Sample ID#: 9100725-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 10/10/2019 13:20
Receipt Date: 10/11/2019 08:13

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.770	mg/L		0.200	PFS	10/10/19 13:20	10/10/19 13:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-19

FOR INTERNAL LABORATORY USE ONLY



9100725

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: _____	9100725			DW	Field	Field	Free Chlorine .77 mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:..

Jr/Sr High School - Weekly

Company/Name: **MONTTEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Email Address: **jcampbell@montiteau.k12.pa.us**

Billing Address: **5100324**

PW/SID: _____

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) _____ Date/ Time 10-10-19 1330

Relinquished By: (Signature) _____ Date/ Time 10-10-19 1500

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature _____

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.77	101019	802		101019	D	1320	32382	9100725-01	BROWNKA_916
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.47	102419	804		102419	D	1145	32382	9102278-01	BROWNKA_870



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

17 October 2019

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 9101746
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	9101746-01	Drinking Water	10/17/2019 13:10	10/17/19 15:19	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/17/2019 16:09

Lab Sample ID#: 9101746-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 10/17/2019 13:10
Receipt Date: 10/17/2019 15:19

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.630	mg/L		0.200	PFS	10/17/19 13:10	10/17/19 13:10



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification Sample ID: <u>ESL# 9101746</u>		Sample Type Grab <u>1310</u> Date <u>10/17/19</u> Time <u>1310</u>		Container Type Preservative <u>Field</u>		Analysis Requested Free Chlorine <u>63</u> mg/L	
Distribution: <u>01</u>		Matrix <u>DW</u>		# of Bottles <u>Field</u>		Free Chlorine <u>63</u> mg/L	
<p style="text-align: center;">ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p style="text-align: center;">  9101746 </p>							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).							
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) 		Date/ Time <u>10/17/19 1310</u>		Company/Name: MONITEAU SCHOOL DISTRICT		Address: 391 HOOKER ROAD	
Relinquished By: (Signature)		Date/ Time <u>10/17/19 1450</u>		Contact Person: JEFFREY CAMPBELL		Phone Number: 724-406-4426	
Relinquished By: (Signature)		Date/ Time		Cell Phone: jcampbell@moniteau.k12.pa.us		Billing Address:	
Relinquished By: (Signature)		Date/ Time		PWSID: 5100324		PWSID:	
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Receipt Temperature		Receipt Temperature	
Notes/Special Instructions: Jr/Sr High School - Weekly							



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9102278
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	9102278-01	Drinking Water	10/24/2019 11:45	10/24/19 14:03	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/24/2019 16:10

Lab Sample ID#: 9102278-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/24/2019 11:45
Receipt Date: 10/24/2019 14:03

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.470	mg/L		0.200	PFS	10/24/19 11:45	10/24/19 11:45

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.47	102419	804		102419	D	1145	32382	9102278-01	BROWNKA_870

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

Sample Identification Distribution: _____	Sample Type Date: 10/24/19 Time: 11:45	Matrix DW	# of Bottles Field	Container Type Preservative Field	Analysis Requested Free Chlorine 47 mg/L
	ESL# 9102278	Date: 10/24/19 Time: 11:45	Matrix DW	# of Bottles Field	Container Type Preservative Field
ROTATION Wk 1 - 704 Kitchen Sink Wk 2 - 802 Room 204 Sink Wk 3 - 803 Admin Sink Wk 4 - 804 400 Hall RR Sink Wk 5 - 804 400 Hall RR Sink					
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.					
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW). 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.					
Sampled By: (Signature) [Signature]		Date/ Time 10/24/19 1340		Received By: (Signature) [Signature]	
Relinquished By: (Signature) [Signature]		Date/ Time 10/24/19 1340		Received By: (Signature) [Signature]	
Relinquished By: (Signature) [Signature]		Date/ Time 10/24/19 1340		Received By: (Signature) [Signature]	
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Receipt Temperature _____	
Notes/Special Instructions: Jr/Sr High School - Weekly					
Company/Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.k12.pa.us Billing Address: 5100324 PWSID:					





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

31 October 2019

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 9102743
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	9102743-01	Drinking Water	10/31/2019 12:35	10/31/19 14:33	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/31/2019 15:25

Lab Sample ID#: 9102743-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/31/2019 12:35
Receipt Date: 10/31/2019 14:33

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.700	mg/L		0.200	PFS	10/31/19 12:35	10/31/19 12:35



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1022	COPPER	171	0.22	081319	001		080819	D	0500	32382	9080801-01	BROWNKA_1104
5100324	1030	LEAD	171	0.0	081319	001		080819	D	0500	32382	9080801-01	BROWNKA_1105
5100324	1022	COPPER	171	0.036	081319	002		080819	D	0505	32382	9080801-02	BROWNKA_1106
5100324	1030	LEAD	171	0.0	081319	002		080819	D	0505	32382	9080801-02	BROWNKA_1107
5100324	1022	COPPER	171	0.029	081519	003		080819	D	0510	32382	9080801-03	BROWNKA_1108
5100324	1030	LEAD	171	0.0	081519	003		080819	D	0510	32382	9080801-03	BROWNKA_1109
5100324	1022	COPPER	171	0.23	081519	004		080819	D	0515	32382	9080801-04	BROWNKA_1110
5100324	1030	LEAD	171	0.0	081519	004		080819	D	0515	32382	9080801-04	BROWNKA_1111
5100324	1022	COPPER	171	0.22	081519	005		080819	D	0520	32382	9080801-05	BROWNKA_1112
5100324	1030	LEAD	171	0.0	081519	005		080819	D	0520	32382	9080801-05	BROWNKA_1113
5100324	1022	COPPER	171	0.22	081519	006		080819	D	0525	32382	9080801-06	BROWNKA_1114
5100324	1030	LEAD	171	0.0	081519	006		080819	D	0525	32382	9080801-06	BROWNKA_1115
5100324	1022	COPPER	171	0.26	081519	007		080819	D	0530	32382	9080801-07	BROWNKA_1116
5100324	1030	LEAD	171	0.0030	081519	007		080819	D	0530	32382	9080801-07	BROWNKA_1117
5100324	1022	COPPER	171	0.24	081519	008		080819	D	0535	32382	9080801-08	BROWNKA_1118
5100324	1030	LEAD	171	0.0	081519	008		080819	D	0535	32382	9080801-08	BROWNKA_1119
5100324	1022	COPPER	171	0.033	081519	009		080819	D	0540	32382	9080801-09	BROWNKA_1120
5100324	1030	LEAD	171	0.0	081519	009		080819	D	0540	32382	9080801-09	BROWNKA_1121
5100324	1022	COPPER	171	0.38	081519	010		080819	D	0545	32382	9080801-10	BROWNKA_1122

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1030	LEAD	171	0.0	081519	010		080819	D	0545	32382	9080801-10	BROWNKA_1123
5100324	1013	FREE CHLORINE	301	0.77	101019	802		101019	D	1320	32382	9100725-01	BROWNKA_916
5100324	1013	FREE CHLORINE	301	0.63	101719	803		101719	D	1310	32382	9101746-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.47	102419	804		102419	D	1145	32382	9102278-01	BROWNKA_870
5100324	1013	FREE CHLORINE	301	0.7	103119	804		103119	D	1235	32382	9102743-01	BROWNKA_1170

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Monitorsville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



9102743

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL #	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>9102743</u>	<u>10/3/19</u>	<u>1235</u>	DW	Field	Field	Free Chlorine <u>70</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions: Jr/Sr High School - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 10-3/19 1235

Relinquished By: (Signature) [Signature] Date/ Time 10/3/19 1410

Relinquished By: (Signature) [Signature] Date/ Time 10/3/19 14:33

Relinquished By: (Signature) [Signature] Date/ Time 10/3/19 14:33

Relinquished By: (Signature) [Signature] Date/ Time 10/3/19 14:33

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature —

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@moniteau.k12.pa.us

Billing Address: 5100324

PWSID: 5100324