

**Moniteau School District
Maintenance Department
Moniteau High School
Monthly WasteWater Facility
Report
October 2020**

Moniteau High School Sewage Treatment Plant
Permit # PA0091341

Daily Operations Worksheet

Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Meter Reading	Time	Operator
10/1	Thurs	7.27	9.62	6.17	4.86	UV	3,904, 837	11:30 AM	JEFF C
10/2	Fri	7.20	9.42	6.22	6.12	7.8		1:00 PM	JEFF C
10/5	Mon	7.15	9.19	AERATION		7.8		3:30 PM	JEFF C
10/6	Tues	7.17	9.09	6.25	6.22	7.8		1:00 PM	JEFF C
10/7	Wed	7.19	9.02	6.36	6.27	7.8		8:00 AM	JEFF C
10/8	Thurs	7.12	9.61	6.47	7.07	7.8		11:00 AM	JEFF C
10/9	Fri	7.10	9.73	6.56	7.10	7.8		9:30 AM	JEFF C
10/12	Mon	7.74	9.78	6.56	7.17	7.6		12:45 M	JEFF C
10/13	Tues	7.77	9.80	6.60	7.21	7.6		10:00 AM	JEFF C
10/14	Wed	7.76	9.98	6.53	8.02	7.6		4:00 PM	JEFF C
10/15	Thurs	7.75	10.17	6.45	8.80	7.2		8:00 AM	JEFF C
10/16	Fri	7.04	9.55	6.22	8.61	7.6		9:00 AM	JEFF C
10/19	Mon	7.56	9.76	6.52	8.25	5.4		10:30 AM	JEFF R.
10/20	Tues	Aeration		6.11	6.12	5.8		11:15 AM	JEFF R.
10/21	Wed	7.42	9.51	6.27	4.28	5.2		10:30 AM	JEFF R.
10/22	Thurs	7.40	9.43	6.12	4.69	5.9		11:00 AM	JEFF R.
10/23	Fri	7.39	9.50	6.57	4.34	6.0		11:15 AM	JEFF R.
10/24	Mon	7.52	10.06	6.97	6.57	5.9		10:45 AM	JEFF C
10/27	Tues	7.57	10.02	7.07	7.23	8.3		8:30 AM	JEFF C
10/28	Wed	7.45	9.27	7.29	7.95	6.5		7:00 AM	JEFF C
10/29	Thurs	7.42	9.21	7.33	8.05	6.8		7:00 AM	JEFF C
10/30	Fri	7.40	9.18	7.35	8.08	6.9	4,029, 385	8:00 AM	JEFF C
PH		0.0					124,548	-31 =	4,017 Daily Avg.
Low	6.11	Low	4.28						
High	7.77	High	10.06				154.9	÷ 22 =	7.04 Daily Avg.

* TEST DAY

* TEST DAY

Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Monday, November 16, 2020, 09:10 AM EST

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 10/01/2020-10/31/2020

Report Due Date: 11/28/2020

Submitted By: Jeffrey Campbell

Submission Id: 234710

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

COMMONWEALTH OF PENNSYLVANIA
 DEPARTMENT OF ENVIRONMENTAL PROTECTION
 BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 10/01/2020
 DMR Effective To: 10/31/2020
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2020	10	01	2020	10	31

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		4.28	***	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.11	***	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		<5.0	***	2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		.58	***	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	2/month	Grab
Total Phosphorus (00655)	SAMPLE MEASUREMENT	***		.18	***	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	2/month	Grab
Ultraviolet light intensity (45607)	SAMPLE MEASUREMENT	***		7.04	***	1/week	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.004017	MGD	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	UNITS	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<1.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***		***	2000 Geo Mean	10000 IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (60082)	SAMPLE MEASUREMENT	***		***	<7.5	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	25 Avg Mo	***		2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER

Moniteau High School
WASTEWATER PLANT
Monthly Worksheet for Oct.

Flow - $124,548 \div 31 = 4,017$ Daily Avg.

UV - $154.9 \div 22 = 7.04$ Daily Avg.

PH

Low - 6.11

High - 7.77

D.O.

Low - 4.28

High - 10.06

TOTAL Nitrogen - $0.32 + 0.839 = 1.159 \div 2 = 0.579$

TOTAL Suspended Solids - $< 5 + < 5 = < 5$

Nitrate / Nitrite - $< 0.104 + 0.839 = 0.943 \div 2 = 0.471$

Phosphorus - $< 0.10 + 0.26 = 0.36 \div 2 = 0.18$

COD - $< 3.00 + < 12.0 = < 15 \div 2 = < 7.5$

Fecal - $< 1 + < 1 = < 1$



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0100079
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0100079-01	Waste Water	10/01/2020 11:00	10/1/20 14:45	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- C CBOD/ BOD dilutions did not meet method criteria of 1.0 mg/L final DO and/or 2.0 mg/L loss (depletion); results are estimated.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/18/2020 21:03

Lab Sample ID#: 0100079-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 10/01/2020 11:00
Receipt Date: 10/01/2020 14:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	0.32	mg/L		0.104	TLL	10/14/20 09:54	10/14/20 10:34
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	10/07/20 11:25	10/07/20 13:45
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	<0.104	mg/L		0.104	TLL	10/14/20 09:54	10/14/20 10:34
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	<0.10	mg/L		0.10	JPD	10/12/20 14:36	10/12/20 15:20
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	BB, C, SS	3.00	TLL	10/02/20 16:27	10/07/20 10:28
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	10/01/20 15:20	10/02/20 11:35

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Containers	Matrix	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab				
		Date on/of	Time on/of	Date	Time		
Effluent Outfall 001	0100079			10/1/20	11:00 AM	Poly 1000mL	CBOD, TSS 7
	01					Poly 1000mL	Total Nitrogen, Total Phosphorus 2
						H2SO4	Fecal Coliform
						Sterile Plastic 125mL	
						Na2S2O3	

Project Notes:

Wastewater

Company/Name:

MONITEAU SCHOOL DISTRICT

Contact Person:

JEFFREY CAMPBELL

Address:

1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

Phone / Cell:

724-406-4426

Email:

jcampbell@moniteau.k12.pa.us

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 10/1/20 11:00 AM

Relinquished By: (Signature) *[Signature]* Date/ Time 10/1/20 1240

Relinquished By: (Signature) *[Signature]* Date/ Time 10/1/20 1430


Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) *[Signature]* Date/ Time 10/1/20 1240

Received By: (Signature) *[Signature]* Date/ Time 10/1/20 1445

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y/N/NA _____ Correct Containers Y/N/NA _____ Receipt Temperature _____



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information



Client: <u>Monitron</u>		Work Order: _____	
Received by: <u>[Signature]</u>		Date/Time Received: <u>10/1/2014</u>	Date Sampled: <u>10/1/2014</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>2.7</u>		Samples Received on Ice: <u>YES</u> NO	
IR Gun # Used: 1 2 3 <u>4</u>			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)		Containers removed by Satellite Lab for analysis of:	TCMPN Fecal Coliform TC/EC ECMPN
Sample State of Collection: <u>PA</u> NY OH WV Other: _____		PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <u>NO</u>	

PART B: Receipt Details

Completed (if different from above): _____ / ____ / ____
Signature
Date
Time

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)			Deficiency Log Required	
1	Chain of custody documents included with samples?	Yes No N/A	Comments:			YES NO	
2	COC form is properly signed in relinquished/received sections?	Yes No N/A	Comments:			YES NO	
3	Sample containers intact and sealed?	Yes No N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____			YES NO	
4	Number of containers received match number indicated on COC?	Yes No N/A	Sample ID's affected:			YES NO	
5	Sample ID's on COC match ID's on bottles?	Yes No N/A	Sample ID's and containers affected:			YES NO	
6	Date and time on COC match date and time on bottles?	Yes No N/A	Sample ID's affected:			YES NO	
7	Samples received within holding time?	Yes No N/A	ID's and tests affected:			YES NO	
8	Samples received at appropriate pH for analysis requested?	Yes No N/A	Sample ID's, containers affected and observed pH:			YES NO	
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes No N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.			YES NO	
11	Adequate sample volume received?	Yes No N/A	Analyses Affected:			YES NO	
10	VOA vials free of headspace (defined as < 6mm bubble)?	Yes No <u>N/A</u>	Sample ID's and containers affected:			YES NO	
Other Comments:						Deficiency Log Created: Yes <u>No</u>	



Results Report

Order ID: 0101768

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 0101768-01	Site: 0100079-01	Sample ID: 0100079
Collector: Client	Collect Date: 10/01/2020 11:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Inorganics</u>									
Total Kjeldahl Nitrogen (TKN)	0.32	mg/L	EPA 351.2	0.50	1	10/05/20	CJ	10/06/20 13:03	DWL

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 10/07/2020 1:02 pm 0101768
STL_Results Revision #1.9 Effective: 04/16/2020



SUBCONTRACT O
Environmental Service Lab
0100079



0101768
 Lisa F. Care

Please report all results to reports@envlabs.com

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
 1803 Philadelphia Street
 Indiana, PA 15701
 Phone: 724-463-8378
 Fax: 724-465-4209
 Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
 1037F MacArthur Road
 Reading, PA 19605
 Phone : (610) 375-8378
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0100079-01			
Matrix: Water	Sampled: 10/01/2020 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	10/13/2020 23:00	10/29/2020 11:00	
Containers Supplied:			
Poly 250mL, H2SO4 (D)	<i>PHAZ</i>	<i>AMB</i>	

Suburban Testing Labs

Lab Date/Time: 10-2-20 10:50 Lab Temp: 2.0
 Number of containers/coolers match number on COC? N
 Sample labels and COC are free of discrepancies? N
 All containers in tact? N
 Received in lab within acceptable temperature limits? N
 40mL VOA vials free of headspace? N
 Relinquished by: _____
 Received in Lab by: Delivery
ahx

CA Released By _____ 10/1/20 Date _____ Received By _____ Date _____

Released By _____ Date _____ Received By _____ Date _____





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

28 October 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0101287
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0101287-01	Waste Water	10/15/2020 09:00	10/15/20 13:55	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934


Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/28/2020 08:51

Lab Sample ID#: 0101287-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 10/15/2020 09:00
Receipt Date: 10/15/2020 13:55

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	0.839	mg/L		0.104	DAA	10/23/20 17:06	10/25/20 09:15
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	10/20/20 11:58	10/20/20 13:30
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.839	mg/L		0.104	DAA	10/23/20 17:06	10/25/20 09:15
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.26	mg/L		0.10	JPD	10/26/20 13:38	10/26/20 14:30
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<12.0	mg/L	BB	12.0	AW	10/15/20 18:18	10/20/20 12:18
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	10/15/20 15:07	10/16/20 09:13



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information



0101287

Client: <u>Montezuma</u>	Work	
Received by: <u>JND</u>	Date/Time Received: <u>10/15/12 1555</u>	Date Sampled: <u>10/15/12</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____		
Sample Receipt Temp: <u>1.8</u>	Samples Received on Ice: <u>YES</u> NO	
IR Gun # Used: 1 2 <u>3</u> 4		
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)	Containers removed by Satellite Lab for analysis of:	TCMPN Fecal Coliform TC/EC ECMPN
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <u>NO</u>	

PART B: Receipt Details

Completed (if different from above): _____ / _____ / _____
Signature Date Time

Sample Receipt Criteria					Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required	
1	Chain of custody documents included with samples?	Yes	No	N/A	Comments:	YES	<u>NO</u>
2	COC form is properly signed in relinquished/received sections?	Yes	No	N/A	Comments:	YES	<u>NO</u>
3	Sample containers intact and sealed?	Yes	No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES	<u>NO</u>
4	Number of containers received match number indicated on COC?	Yes	No	N/A	Sample ID's affected:	YES	<u>NO</u>
5	Sample ID's on COC match ID's on bottles?	Yes	No	N/A	Sample ID's and containers affected:	YES	<u>NO</u>
6	Date and time on COC match date and time on bottles?	Yes	No	N/A	Sample ID's affected:	YES	<u>NO</u>
7	Samples received within holding time?	Yes	No	N/A	ID's and tests affected:	YES	<u>NO</u>
8	Samples received at appropriate pH for analysis requested?	Yes	No	N/A	Sample ID's, containers affected and observed pH:	YES	<u>NO</u>
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES	<u>NO</u>
11	Adequate sample volume received?	Yes	No	N/A	Analyses Affected:	YES	<u>NO</u>
10	VOA vials free of headspace (defined as < 6mm bubble)?	Yes	No	<u>N/A</u>	Sample ID's and containers affected:	YES	<u>NO</u>
Other Comments:						Deficiency Log Created: Yes <u>NO</u>	



Results Report

Order ID: 0103908

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 0103908-01

Site: 0101287-01

Sample ID:

Collector: Client

Collect Date: 10/15/2020 9:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Inorganics									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	10/21/20	CJ	10/26/20 12:13	ZJH

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Kelly Mays
Client Services Supervisor

Report Generated On: 10/26/2020 4:56 pm 0103908

STL_Results Revision #1.9 Effective: 04/16/2020



SUBCONTRACT C
Environmental Service Lab
0101287



0103908
Lisa F. Care

Please report all results to reports@envlabs.co

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone: (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0101287-01			
Matrix: Water	Sampled: 10/15/2020 09:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	10/27/2020 23:00	11/12/2020 09:00	
Containers Supplied: Poly 250mL, H2SO4 (D)			

(1) 250mlp \hat{e} H₂SO₄
PhLA RMH
10/16/20

Suburban Testing Labs

Lab Date/Time: 10/16/20 1040 Lab Temp: 14°C
 Number of containers/coolers match number on COC? Y/N
 Sample labels and COC are free of discrepancies? Y/N
 All containers in tact? Y/N
 Received in lab within acceptable temperature limits? Y/N
 40mL VOA vials free of headspace? Y/N
 Relinquished by: Delivery
 Received in Lab by: RMH 11.4

Released By _____ Date _____ Received By _____ Date _____

Released By _____ Date _____ Received By _____ Date _____





BUILDING USE FORM FACILITIES AGREEMENT

MONITEAU SCHOOL DISTRICT
1810 W SUNBURY RD
WEST SUNBURY, PA 16061
724.637.2117 office 724.637.3862 fax

NAME OF ORGANIZATION/GROUP	PURPOSE/ACTIVITY
Art Club	meeting

FACILITY REQUESTED: _____ USE TYPE: Community School Non-Resident

FACILITY	ROOMS/AREA TO BE USED	BUILDING PRINCIPAL APPROVAL	DATE
<input checked="" type="checkbox"/> DASSA MCKINNEY ELEMENTARY SCHOOL			
<input checked="" type="checkbox"/> MONITEAU HIGH SCHOOL	Art room		
<input type="checkbox"/> TRACK			
<input type="checkbox"/> SOFTBALL FIELD			
<input type="checkbox"/> FOOTBALL FIELD			
<input type="checkbox"/> OTHER			

DATES AND TIMES OF USE: Building Use Forms must be submitted 7 days prior to the event for school activities and 14 days for community activities.

DATE: Please include all proposed dates.	10/26/20						
	MONDAY	TUESDAY	WEDNESDAY	THURSDAY	FRIDAY	SATURDAY	SUNDAY
HOURS OF USE	3-5						CALL
OPEN BUILDING							FOR PRIOR
CLOSE BUILDING							APPROVAL

SPECIAL SERVICES, MATERIALS OR EQUIPMENT REQUIRED: _____ PA SYSTEM: AV SYSTEM:

SECURITY REQUIRED: YES NO Security arrangements can be made by contacting Mr. Garrick Lapusnak at 724-637-2117 x1720 glapusnak@moniteau.org

SECURITY Confirmed: _____ SPONSOR EMAIL ADDRESS: _____

By signing this agreement, I agree to the terms and conditions as set forth in Board Policy 707-Use of School Facilities.*

SPONSOR NAME	ADDRESS	PHONE #	SIGNATURE	DATE
1 Laura Smolen			<i>[Signature]</i>	10/26/20
2				

Just received today 10/28.

APPROVED BY:	OFFICIAL USE ONLY
MAINTENANCE DIRECT	FACILITY FEE \$
ATHLETIC DIRECTOR	CUSTODIAL FEE \$
SUPERINTENDENT	SECURITY FEE \$
DATE	Copy to Custodial Staff:
	Logged in District Calendar:
	Approved Copy to Sponsor:

User holds the school district harmless from all claims for injury to or the death of any person, and for damage to or the loss of any property arising out of or attributed directly or indirectly to the operations or omissions of the school district. User indemnifies the school district for all damage to property belonging to the school district and for all injuries to or the deaths of any representative or employees of the school district resulting from all acts or omissions of user.

Maintenance Director must be notified of any cancellation within 24 hrs before the scheduled event or sponsor may be liable for extra cost incurred.

**Moniteau School District
Maintenance Department
Dassa McKinney School
Monthly Water Facility Report
October 2020**

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
Oct										
2020										
1	Thurs	8.0	0.02	0.56	0.62	1.54	12090000	Jeff R	4:30P	5000
2	Fri	7.9	0.02	0.70	0.80	2.17	12095000	Jeff R	3:00P	5000
3	Sat									
4	Sun									
5	Mon	8.0	0.03	0.57	0.63	2.23	12099700	Jeff R	3:30P	4700
6	Tues	7.9	0.02	0.51	0.59	2.09	12104400	Jeff R	4:00P	4700
7	Wed	7.9	0.02	0.48	0.55	2.15	12109000	Jeff R	11:30A	4600
8	Thurs			SICK	Day		12113600			4600
9	Fri	8.0	0.05	0.49	0.53	2.38	12118500	Jeff R	3:30P	4900
10	Sat									
11	Sun									
12	Mon	7.9	0.04	0.49	0.54	2.12	12123100	Jeff R	4:30P	4600
13	Tues	8.0	0.00	0.65	0.71	2.04	12123700	Jeff R	3:00P	600
14	Wed	7.9	0.01	0.61	0.66	2.14	12131800	Jeff R	3:00P	8100
15	Thurs	7.9	0.03	0.58	0.61	2.09	12136800	Jeff R	4:00P	5000
16	Fri	8.0	0.02	0.50	0.54	2.11	12137600	Jeff R	3:30P	200
17	Sat									
18	Sun									
19	Mon	7.9	0.02	0.55	0.60	2.02	12147700	Jeff R	3:30P	4700
20	Tues	8.1	0.00	0.51	0.57	1.75	12147400	Jeff R	3:00P	5700
21	Wed	7.9	0.02	0.48	0.55	1.82	12151200	Jeff R	3:30P	3800
22	Thurs	8.0	0.04	0.77	0.83	2.17	12156000	Jeff R	2:30P	4800
23	Fri	8.0	0.02	0.79	0.83	2.14	12160800	Jeff R	3:00P	4800
24	Sat.									
25	Sun									
26	Mon	8.0	0.04	0.70	0.76	2.25	12165400	Jeff R	4:30P	4600
27	Tues	7.9	0.03	0.78	0.88	0.98	12169800	Jeff R	3:00P	4400
28	Wed	8.0	0.02	0.68	0.75	2.17	12174200	Jeff R	3:00P	4400
29	Thurs	8.1	0.02	0.51	0.58	2.13	12178800	Jeff R	3:30P	4600
30	Fri	7.9	0.01	0.55	0.62	1.47	12184000	Jeff R	3:30P	5200
31	Sat									

Meter Reading 9/30/20 12085000



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

11 October 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0100090
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0100090-01	Drinking Water	10/01/2020 12:25	10/1/20 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/11/2020 13:38

Lab Sample ID#: 0100090-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 10/01/2020 12:25
Receipt Date: 10/01/2020 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.07	mg/L		0.200	PFS	10/01/20 12:25	10/01/20 12:25
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KEL	10/01/20 15:22	10/02/20 15:38
E. Coli	Absent	per 100 mL		1	KEL	10/01/20 15:22	10/02/20 15:38

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benileyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DI
435 Broad St
Montoursville, I
(570) 321-9000
FAX: (570) 32

NORTHWEST DIVISION



0100090

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK 802 ROOM 617 SINK	0100090	10/13	1430	DW	1 ✓	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 1.07 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 10/13/14 1430
 Relinquished By: (Signature) *[Signature]* Date/ Time 10/13/14 1430
 Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Company Name: MONITEAU SCHOOL DISTRICT
 Address: 391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: jcampbell@montiteau.k12.pa.us
 Billing Address: 5100316
 PWSID: 5100316

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature 4.5 #4



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	100820	801		100820	D	1140	32382	0100696-01	BROWNKA_50
5100316	1013	FREE CHLORINE	301	1.07	100120	802		100120	D	1225	32382	0100090-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1225	32382	0100090-01	BROWNKA_49



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0100696
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	0100696-01	Drinking Water	10/08/2020 11:40	10/8/20 14:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/11/2020 13:51

Lab Sample ID#: 0100696-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 10/08/2020 11:40
Receipt Date: 10/08/2020 14:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.720	mg/L		0.200	PFS	10/08/20 11:40	10/08/20 11:40

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHER
435 Broad
Montoursvi
(570) 321-1
FAX: (570)

IN



0100696

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>807-804</u>	<u>0100696</u>	<u>10-8-20</u>	<u>1140</u>	DW	Field	Field	Free Chlorine <u>0.72</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY. IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time <u>10-8-20 1140</u>					
Relinquished By: (Signature)		Date/ Time <u>10-8-20 1400</u>					
Relinquished By: (Signature)		Date/ Time					
Relinquished By: (Signature)		Date/ Time					
Correct Preservations Y / N / (NA)		Correct Containers Y / N / (NA)		Receipt Temperature			
Company/Name: MONITEAU SCHOOL DISTRICT				Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcampbell@moniteau.k12.pa.us 5100316			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	100820	801		100820	D	1140	32382	0100696-01	BROWNKA_50
5100316	1013	FREE CHLORINE	301	1.07	100120	802		100120	D	1225	32382	0100090-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1225	32382	0100090-01	BROWNKA_49



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0101280
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	0101280-01	Drinking Water	10/15/2020 11:15	10/15/20 13:58	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/18/2020 20:42

Lab Sample ID#: 0101280-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 10/15/2020 11:15
Receipt Date: 10/15/2020 13:58

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.890	mg/L		0.200	PFS	10/15/20 11:15	10/15/20 11:15

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL

SAMPLE REQUEST & CHAIN OF CUSTODY

NORTHWEST DIVISION
Main Street
Pittsburgh, PA 15
(724) 463-TEST
FAX: (724) 465-4209



0101280

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>803</u>	<u>0101280</u>	Date	Time	DW	Field	Field	Free Chlorine <u>.59</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time <u>10/5/06 11:15</u>		Company/Name: MONITEAU SCHOOL DISTRICT			
Relinquished By: (Signature)		Date/ Time <u>10/5/06 13:55</u>		Address: 391 HOOKER ROAD			
Relinquished By: (Signature)		Date/ Time		Contact Person: WEST SUNBURY, PA 16061			
Relinquished By: (Signature)		Date/ Time		Phone Number: JEFFREY CAMPBELL			
Correct Preservations Y/N/NA		Correct Containers Y/N/NA		Cell Phone: 724-406-4426			
Receipt Temperature		Date/ Time		Email Address: jcampbell@moniteau.k12.pa.us			
Date/ Time		Date/ Time		Billing Address:			
Date/ Time		Date/ Time		PWSID: 5100316			



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL
 SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	100820	801		100820	D	1140	32382	0100696-01	BROWNKA_50
5100316	1013	FREE CHLORINE	301	1.07	100120	802		100120	D	1225	32382	0100090-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1225	32382	0100090-01	BROWNKA_49
5100316	1013	FREE CHLORINE	301	0.89	101520	803		101520	D	1115	32382	0101280-01	BROWNKA_522



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

22 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0101804
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0101804-01	Drinking Water	10/22/2020 10:10	10/22/20 12:44	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/22/2020 14:23

Lab Sample ID#: 0101804-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 10/22/2020 10:10
Receipt Date: 10/22/2020 12:44

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.470	mg/L		0.200	PFS	10/22/20 10:10	10/22/20 10:10

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorthis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

DATE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>SOY</u>	<u>0101804</u>	Date	Time	DW	Field	Field	Free Chlorine <u>0.7</u> mg/L
	<u>01</u>	<u>10-22-20</u>	<u>10:10</u>				
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time <u>10-22-20 10:10</u>					
Relinquished By: (Signature)		Date/ Time <u>10-22-20 12:33</u>		Received By: (Signature) Date/ Time <u>10/27/20 12:00</u>			
Relinquished By: (Signature)		Date/ Time		Received By: (Signature) Date/ Time			
Relinquished By: (Signature)		Date/ Time		Received By: (Signature) Date/ Time			
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Receipt Temperature <u> </u>			
Company/Name: MONITEAU SCHOOL DISTRICT							
Address: 391 HOOKER ROAD							
Contact Person: WEST SUNBURY, PA 16061							
Phone Number: JEFFREY CAMPBELL							
Cell Phone: 724-406-4426							
Email Address: jcampbell@moniteau.k12.pa.us							
Billing Address:							
PWSID: 5100316							



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	100820	801		100820	D	1140	32382	0100696-01	BROWNKA_50
5100316	1013	FREE CHLORINE	301	1.07	100120	802		100120	D	1225	32382	0100090-01	BROWNKA_48
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1225	32382	0100090-01	BROWNKA_49
5100316	1013	FREE CHLORINE	301	0.89	101520	803		101520	D	1115	32382	0101280-01	BROWNKA_522
5100316	1013	FREE CHLORINE	301	0.47	102220	804		102220	D	1010	32382	0101804-01	BROWNKA_685



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

29 October 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0102270
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0102270-01	Drinking Water	10/29/2020 11:00	10/29/20 13:28	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/29/2020 14:41

Lab Sample ID#: 0102270-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 10/29/2020 11:00
Receipt Date: 10/29/2020 13:28

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.500	mg/L		0.200	PFS	10/29/20 11:00	10/29/20 11:00

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN C
435 Broad Str
Montoursville,
(570) 321-900
FAX: (570) 321-1957



0102270

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

DATE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>SGJ</u>	<u>0102270</u>	<u>10/29/20</u>	<u>1100</u>	DW	Field	Field	Free Chlorine <u>50</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p> </div>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:
Drinking Water Dassa McKinney - Weekly

Sampled By: (Signature) Date/ Time <u>10/29/20 1100</u>	Received By: (Signature) Date/ Time <u>10/29/20 13:08</u>
Relinquished By: (Signature) Date/ Time <u>10/29/20 1308</u>	Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____	Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____	Received By: (Signature) _____ Date/ Time _____
Correct Preservations Y / N / NA <u>Y / N / NA</u>	Correct Containers Y / N / NA <u>Y / N / NA</u>
Receipt Temperature _____	

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcampbell@moniteau.k12.pa.us**

Cell Phone: **5100316**

Email Address: **5100316**

Billing Address: **5100316**

PWSID: **5100316**

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.72	100820	801		100820	D	1140	32382	0100696-01	BROWNKA_50
5100316	1013	FREE CHLORINE	301	1.07	100120	802		100120	D	1225	32382	0100090-01	BROWNKA_48
5100316	1013	FREE CHLORINE	301	0.5	102920	802		102920	D	1100	32382	0102270-01	BROWNKA_1087
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1225	32382	0100090-01	BROWNKA_49
5100316	1013	FREE CHLORINE	301	0.89	101520	803		101520	D	1115	32382	0101280-01	BROWNKA_522
5100316	1013	FREE CHLORINE	301	0.47	102220	804		102220	D	1010	32382	0101804-01	BROWNKA_685

**Moniteau School District
Maintenance Department
Moniteau High School
Monthly Water Facility Report
October 2020**

MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT										
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
1	Thurs	64.0	8.81	3,904,837	0.93	1.01	7.3	0.00	0	0.94	Jeff C	5:00 AM
2	Fri	62.5	8.19	3,904,1837	0.90	0.93	7.3	0.00	0	0.95	Jeff C	9:00 AM
3	SAT											
4	SUN											
5	Mon	65.0	5.00	3,918,433	0.77	0.82	7.4	0.02	0	1.03	Jeff C	10:30 AM
6	Tues	61.0	9.59	3,936,687	0.79	0.85	7.4	0.01	0	1.01	Jeff C	9:00 AM
7	Wed	63.0	8.79	3,938,822	0.81	0.91	7.2	0.04	0	1.00	Jeff C	12:15 PM
8	Thurs	62.0	9.60	3,946,777	0.81	0.90	7.3	0.02	0	0.99	Jeff C	8:30 AM
9	Fri	62.0	9.80	3,952,449	0.74	0.77	7.4	0.05	0	1.33	Jeff C	1:00 PM
10	SAT											
11	SUN											
12	Mon	65.0	8.47	3,962,064	0.65	0.80	7.4	0.05	0	1.47	Jeff C	1:00 PM
13	Tues	64.0	9.20	3,967,152	0.81	0.92	7.4	0.03	0	1.51	Jeff C	8:15 AM
14	Wed	62.5	9.06	3,976,255	0.79	0.86	7.4	0.02	0	1.45	Jeff C	2:00 PM
15	Thurs	63.1	8.44	3,976,255	0.81	0.86	7.4	0.02	0	1.42	Jeff C	9:00 AM
16	Fri	61.5	9.64	3,982,460	0.56	0.68	7.3	0.02	0	1.06	Jeff C	7:30 AM
17	SAT											
18	SUN											
19	Mon	61.0	8.90	3,986,314	0.88	0.96	7.5	0.04	0	1.04	Jeff R	11:00 AM
20	Tues	61.0	9.21	3,993,339	1.07	1.22	7.3	0.05	0	0.98	Jeff R	11:00 AM
21	Wed	61.2	9.03	3,996,250	0.87	0.95	7.8	0.05	0	0.61	Jeff R	11:15 AM
22	Thurs	62.0	8.75	3,999,066	0.97	1.05	7.4	0.02	0	1.03	Jeff R	11:30 AM
23	Fri	63.2	9.37	4,008,138	0.88	0.99	7.3	0.02	0	0.77	Jeff R	11:00 AM
24	SAT											
25	SUN											
26	Mon	60.7	9.37	4,012,702	0.85	0.97	7.5	0.02	0	1.01	Jeff C	10:00 AM
27	Tues	61.0	8.38	4,019,329	1.01	1.13	7.5	0.02	0	1.03	Jeff C	1:00 PM
28	Wed	59.7	9.61	4,023,537	0.89	1.09	7.5	0.01	0	1.05	Jeff C	7:30 AM
29	Thurs	58.0	8.05	4,023,537	0.92	1.10	7.3	0.00	0	1.25	Jeff C	9:00 AM
30	Fri	57.1	8.90	4,029,385	1.06	1.21	7.3	0.00	0	1.02	Jeff C	9:30 AM
31	SAT											

METER READING 9/30/20 3,895, 916



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

11 October 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0100093
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0100093-01	Drinking Water	10/01/2020 12:45	10/1/20 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/11/2020 13:38

Lab Sample ID#: 0100093-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 10/01/2020 12:45
Receipt Date: 10/01/2020 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	1.00	mg/L		0.200	PFS	10/01/20 12:45	10/01/20 12:45
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KEL	10/01/20 15:22	10/02/20 15:38
E. Coli	Absent	per 100 mL		1	KEL	10/01/20 15:22	10/02/20 15:38

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorthis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



0100093

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK (802 ROOM 204 SINK)	0100093	10-20-05	1245	DW	1 ✓	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 1.00
<p>704: Jan, Mar, May, Jul, Sept, Nov</p> <p>802: Feb, Apr, Jun, Aug, Oct, Dec</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <i>[Signature]</i> Date/ Time 10-20-05 1245</p> <p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 10-20-05 1430</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Notes/Special Instructions::</p> <p>Drinking Water Moniteau Jr/Sr - Monthly</p>			
<p>Correct Preservations Y / N / NA</p>				<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: _____</p> <p>PWSID: 5100324</p>			
<p>Correct Containers Y / N / NA</p>				<p>Receipt Temperature 46.75</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.03	100820	704		100820	D	1210	32382	0100697-01	BROWNKA_55
5100324	1013	FREE CHLORINE	301	1.0	100120	802		100120	D	1245	32382	0100093-01	BROWNKA_53
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1245	32382	0100093-01	BROWNKA_54



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0100697
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	0100697-01	Drinking Water	10/08/2020 12:10	10/8/20 14:35	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/11/2020 13:51

Lab Sample ID#: 0100697-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 10/08/2020 12:10
Receipt Date: 10/08/2020 14:35

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	1.03	mg/L		0.200	PFS	10/08/20 12:10	10/08/20 12:10

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benitleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-3376



0100697

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 804-801	0100697	10/8/20	1210	DW	Field	Field	Free Chlorine 1.03 mg/L

ROTATION
 Wk 1 - 704 Kitchen Sink
 Wk 2 - 802 Room 204 Sink
 Wk 3 - 803 Admin Sink
 Wk 4 - 804 400 Hall RR Sink
 Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:
Drinking Water Moniteau Jr/Sr - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 JEFFREY CAMPBELL**
 Contact Person:
 Phone Number:
 Cell Phone: **724-406-4426**
 Email Address: **jcampbell@moniteau.k12.pa.us**
 Billing Address:
 PWSID: **5100324**

Received By: (Signature) *[Signature]* Date/ Time **10/13/20 14:35**
 Received By: (Signature) Date/ Time
 Received By: (Signature) Date/ Time
 Received By: (Signature) Date/ Time

Correct Preservations **Y/N/NA** Correct Containers **Y/N/NA** Receipt Temperature **—**

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.03	100820	704		100820	D	1210	32382	0100697-01	BROWNKA_55
5100324	1013	FREE CHLORINE	301	1.0	100120	802		100120	D	1245	32382	0100093-01	BROWNKA_53
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1245	32382	0100093-01	BROWNKA_54



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

18 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0101281
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	0101281-01	Drinking Water	10/15/2020 11:35	10/15/20 13:59	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/18/2020 20:42

Lab Sample ID#: 0101281-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 10/15/2020 11:35
Receipt Date: 10/15/2020 13:59

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.780	mg/L		0.200	PFS	10/15/20 11:35	10/15/20 11:35

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



FOR INTERNAL USE ONLY

NORTHWEST DIVISION
950 Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>0101281</u>	<u>10/15/20</u>	<u>11:35</u>	DW	Field	Field	Free Chlorine <u>78</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly</p>							
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>10/15/20 11:35</u></p>				<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>10/15/20 15:55</u></p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Correct Preservations Y / N / NA</p>				<p>Correct Containers Y / N / NA</p>			
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p>				<p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p>			
<p>Phone Number: 724-406-4426</p>				<p>Cell Phone: jcampbell@moniteau.k12.pa.us</p>			
<p>Billing Address: 5100324</p>				<p>PWSID: 5100324</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.03	100820	704		100820	D	1210	32382	0100697-01	BROWNKA_55
5100324	1013	FREE CHLORINE	301	1.0	100120	802		100120	D	1245	32382	0100093-01	BROWNKA_53
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1245	32382	0100093-01	BROWNKA_54
5100324	1013	FREE CHLORINE	301	0.78	101520	803		101520	D	1135	32382	0101281-01	BROWNKA_523



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

22 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0101805
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0101805-01	Drinking Water	10/22/2020 10:55	10/22/20 12:44	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/22/2020 14:23

Lab Sample ID#: 0101805-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/22/2020 10:55
Receipt Date: 10/22/2020 12:44

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-CI G-11		Prep Method: No Prep - Field				
Chlorine, Free	1.11	mg/L		0.200	PFS	10/22/20 10:55	10/22/20 10:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



WEST DIVISION
Main Street
Pittsburgh, PA 15201
63-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>S04</u>	<u>0101805</u>	<u>10/27/20</u>	<u>1055</u>	DW	Field	Field	Free Chlorine <u>1.11</u> mg/L
<p style="text-align: center;">ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly

Company/Name:	MONITEAU SCHOOL DISTRICT
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Contact Person:	
Phone Number:	724-406-4426
Cell Phone:	jcampbell@moniteau.k12.pa.us
Email Address:	
Billing Address:	
PWSID:	5100324

Sampled By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>10-27-20 1035</u>
Relinquished By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>10-27-20 1233</u>
Received By: (Signature)	<u>[Signature]</u>	Date/ Time	<u>10/27/20 12:40</u>
Received By: (Signature)		Date/ Time	
Received By: (Signature)		Date/ Time	

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.03	100820	704		100820	D	1210	32382	0100697-01	BROWNKA_55
5100324	1013	FREE CHLORINE	301	1.0	100120	802		100120	D	1245	32382	0100093-01	BROWNKA_53
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1245	32382	0100093-01	BROWNKA_54
5100324	1013	FREE CHLORINE	301	0.78	101520	803		101520	D	1135	32382	0101281-01	BROWNKA_523
5100324	1013	FREE CHLORINE	301	1.11	102220	804		102220	D	1055	32382	0101805-01	BROWNKA_686



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

29 October 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0102271
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0102271-01	Drinking Water	10/29/2020 11:20	10/29/20 13:29	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/29/2020 14:41

Lab Sample ID#: 0102271-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/29/2020 11:20
Receipt Date: 10/29/2020 13:29

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.930	mg/L		0.200	PFS	10/29/20 11:20	10/29/20 11:20

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL LABORATORY USE

NORTHERN
435 Broad
Montoursv
(570) 321-
FAX: (57C



0102271

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>0102271</u>		<u>1120</u>	DW	Field	Field	Free Chlorine <u>93</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400-Hall-RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Moniteau Jr/Sr - Weekly</i></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time <u>10-29-10 1120</u>		Received By: (Signature)		Date/ Time <u>10-29-10 1325</u>	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time		Received By: (Signature)		Date/ Time	
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Receipt Temperature		-	
Company/Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: Phone Number: 724-406-4426 Cell Phone: Email Address: jcampbell@moniteau.k12.pa.us Billing Address: PWSID: 5100324							



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.03	100820	704		100820	D	1210	32382	0100697-01	BROWNKA_55
5100324	1013	FREE CHLORINE	301	1.0	100120	802		100120	D	1245	32382	0100093-01	BROWNKA_53
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	100220	802		100120	D	1245	32382	0100093-01	BROWNKA_54
5100324	1013	FREE CHLORINE	301	0.78	101520	803		101520	D	1135	32382	0101281-01	BROWNKA_523
5100324	1013	FREE CHLORINE	301	1.11	102220	804		102220	D	1055	32382	0101805-01	BROWNKA_686
5100324	1013	FREE CHLORINE	301	0.93	102920	804		102920	D	1120	32382	0102271-01	BROWNKA_1088