

**Moniteau School District  
Maintenance Department  
September 2020**

**Dassa McKinney Elementary  
School**

**Monthly Water Treatment  
Plant**

**Operations Report**





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 September 2020

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 0090386**  
**Project: Drinking Water Dassa McKinney - Monthly 801**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	0090386-01	Drinking Water	09/03/2020 11:55	9/3/20 14:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/11/2020 08:42

**Lab Sample ID#:** 0090386-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 09/03/2020 11:55  
**Receipt Date:** 09/03/2020 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.890	mg/L		0.200	PFS	09/03/20 11:55	09/03/20 11:55
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	09/03/20 15:45	09/04/20 16:34
E. Coli	Absent	per 100 mL		1	DAA	09/03/20 15:45	09/04/20 16:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

0090386

WEST DIVISION  
n Street  
ile, PA 16  
-7 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK 802-RQOML617 SINK	0090386 m	9-30	153	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 89 mg/L

4.1 #4 1430

**Rotation:**

- 801: Jan, Mar, May, Jul, Sep, Nov
- 802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: <b>Drinking Water Dassa McKinney - Monthly</b>	Company/Name: <b>MONITEAU SCHOOL DISTRICT</b>
Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061</b>	Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061</b>
Contact Person: <b>JEFFREY CAMPBELL</b>	Contact Person: <b>JEFFREY CAMPBELL</b>
Phone Number: <b>724-406-4426</b>	Phone Number: <b>724-406-4426</b>
Cell Phone: <b>jcampbell@moniteau.k12.pa.us</b>	Cell Phone: <b>724-406-4426</b>
Billing Address: <b>5100316</b>	Billing Address: <b>jcampbell@moniteau.k12.pa.us</b>
PWSID: <b>5100316</b>	PWSID: <b>5100316</b>

Sampled By: (Signature) <i>[Signature]</i>	Date/ Time <b>9-30 153</b>
Relinquished By: (Signature) <i>[Signature]</i>	Date/ Time <b>9-30 1405</b>
Received By: (Signature) <i>[Signature]</i>	Date/ Time <b>9/3/20 1430</b>
Relinquished By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Received By: (Signature)	Date/ Time
Correct Preservations Y / N (NA)	Correct Containers Y / N (NA)
Receipt Temperature	

**5100316: DASSA MCKINNEY ELEM SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.89	090320	801		090320	D	1155	32382	0090386-01	BROWNKA_54
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	801		090320	D	1155	32382	0090386-01	BROWNKA_55
5100316	1013	FREE CHLORINE	301	0.76	091020	802		091020	D	1135	32382	0090933-01	BROWNKA_56



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 September 2020

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 0090933**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0090933-01	Drinking Water	09/10/2020 11:35	9/10/20 14:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/11/2020 09:32

**Lab Sample ID#:** 0090933-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 09/10/2020 11:35  
**Receipt Date:** 09/10/2020 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.760	mg/L		0.200	PFS	09/10/20 11:35	09/10/20 11:35



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957




NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>801</u>	<u>0090933</u>	<u>9:08</u>	<u>11:35</u>	DW	Field	Field	Free Chlorine <u>0.76</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - <u>802 Room 617 Sink</u></p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p> </div>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) </p> <p>Date/ Time <u>9-10-20</u> <u>11:35</u></p>		<p>Received By: (Signature) </p> <p>Date/ Time <u>9/10/20</u> <u>14:30</u></p>		<p>Notes/Special Instructions:</p> <p><u>Drinking Water Dassa McKinney - Weekly</u></p>			
<p>Relinquished By: (Signature) </p> <p>Date/ Time <u>9-10-20</u> <u>14:15</u></p>		<p>Received By: (Signature)</p> <p>Date/ Time</p>		<p>Company Name: <u>MONITEAU SCHOOL DISTRICT</u></p> <p>Address: <u>391 HOOKER ROAD</u> <u>WEST SUNBURY, PA 16061</u></p> <p>Contact Person: <u>JEFFREY CAMPBELL</u></p> <p>Phone Number: <u>724-406-4426</u></p> <p>Cell Phone: <u>jcampbell@moniteau.k12.pa.us</u></p> <p>Billing Address: <u>5100316</u></p> <p>PWSID: <u>5100316</u></p>			
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Received By: (Signature)</p> <p>Date/ Time</p>		<p>Correct Preservations Y / N / NA</p> <p>Correct Containers Y / N / NA</p> <p>Receipt Temperature</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.89	090320	801		090320	D	1155	32382	0090386-01	BROWNKA_54
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	801		090320	D	1155	32382	0090386-01	BROWNKA_55
5100316	1013	FREE CHLORINE	301	0.76	091020	802		091020	D	1135	32382	0090933-01	BROWNKA_56



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

17 September 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0091547**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	0091547-01	Drinking Water	09/17/2020 11:45	9/17/20 14:26	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/17/2020 16:26

**Lab Sample ID#:** 0091547-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Room 606 Sink

**Sample Date:** 09/17/2020 11:45  
**Receipt Date:** 09/17/2020 14:26

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.630	mg/L		0.200	PFS	09/17/20 11:45	09/17/20 11:45



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



0091547

(570) 321-9003  
FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY

## CHAIN OF CUSTODY

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

DATE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 802	0091547	9-17-06	1145	DW	Field	Field	Free Chlorine 63 mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p> </div>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time 9-17-06 1145		Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly			
Relinquished By: (Signature)		Date/ Time 9-17-06 1355		Company Name: MONITEAU SCHOOL DISTRICT			
Relinquished By: (Signature)		Date/ Time		Address: 391 HOOKER ROAD			
Relinquished By: (Signature)		Date/ Time		Contact Person: WEST SUNBURY, PA 16061			
Correct Preservations Y / N (NA)		Correct Containers Y / N (NA)		Phone Number: JEFFREY CAMPBELL			
Receipt Temperature		Receipt Temperature		Cell Phone: 724-406-4426			
Receipt Temperature		Receipt Temperature		Email Address: jcampbell@moniteau.k12.pa.us			
Receipt Temperature		Receipt Temperature		Billing Address:			
Receipt Temperature		Receipt Temperature		PWSID: 5100316			



**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.89	090320	801		090320	D	1155	32382	0090386-01	BROWNKA_54
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	801		090320	D	1155	32382	0090386-01	BROWNKA_55
5100316	1013	FREE CHLORINE	301	0.76	091020	802		091020	D	1135	32382	0090933-01	BROWNKA_56
5100316	1013	FREE CHLORINE	301	0.63	091720	803		091720	D	1145	32382	0091547-01	BROWNKA_642



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

29 September 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0092119**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0092119-01	Drinking Water	09/24/2020 10:05	9/24/20 13:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/29/2020 12:12

**Lab Sample ID#:** 0092119-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 Room 408 Sink

**Sample Date:** 09/24/2020 10:05  
**Receipt Date:** 09/24/2020 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.470	mg/L		0.200	PFS	09/24/20 10:05	09/24/20 10:05

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 804	0092119	9/24/20	1005	DW	Field	Field	Free Chlorine 0.47 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: 5100316</p> <p>PWSID:</p>			
<p>Sampled By: (Signature)</p> <p>9/24/20 1005</p> <p>Date/ Time</p>		<p>Received By: (Signature)</p> <p>9/24/20 1300</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>9/24/20 1250</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>	
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>	
<p>Correct Preservations Y / N / NA</p>		<p>Correct Containers Y / N / NA</p>		<p>Receipt Temperature</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.89	090320	801		090320	D	1155	32382	0090386-01	BROWNKA_54
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	801		090320	D	1155	32382	0090386-01	BROWNKA_55
5100316	1013	FREE CHLORINE	301	0.76	091020	802		091020	D	1135	32382	0090933-01	BROWNKA_56
5100316	1013	FREE CHLORINE	301	0.63	091720	803		091720	D	1145	32382	0091547-01	BROWNKA_642
5100316	1013	FREE CHLORINE	301	0.47	092420	804		092420	D	1005	32382	0092119-01	BROWNKA_1249



**Moniteau School District  
Maintenance Department  
September 2020  
Moniteau High School  
Monthly Wastewater  
Treatment Plant  
Operations Report & DMR**

Moniteau High School Sewage Treatment Plant  
Permit # PA0091341

Daily Operations Worksheet

Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month UV	Meter Reading	Time	Operator
9/1	Tues	7.80	7.42	5.40	Down	5.0	3,727, 149	1:00	JEFFC
9/2	WED	7.83	7.47	"	"	5.0		4:00	JEFFC
9/3	Thurs	7.86	7.41	"	"	5.1		12:00	JEFFC
9/4	Fri	7.90	7.83	"	"	5.0		1:00 PM	JEFFC
9/7	Mon	7.95	7.99	"	"	5.0		7:00 AM	JEFFC
9/8	Tues	7.98	8.40	"	"	5.1		4:00 PM	JEFFC
9/9	Wed	8.05	8.61	"	"	5.0		7:00 AM	JEFFC
9/10	Thurs	8.08	8.70	"	"	5.0		9:00 AM	JEFFC
9/11	Fri	8.17	8.73	"	"	5.1		9:30 AM	JEFFC
9/14	Mon	7.96	9.48	7.84	8.23	4.0		7:45 AM	JEFFC
9/15	Tues	7.67	8.55	AERATION	AERATION	5.3		10:40 AM	JEFFC
9/16	Wed	7.65	8.51	7.71	8.28	5.0		7:00 AM	JEFFC
9/17	Thurs	7.62	9.01	7.53	7.56	5.9		11:30 AM	JEFFC
9/18	Fri	AERATION	AERATION	7.52	7.50	6.3		12:00 PM	JEFFC
9/21	Mon	7.80	9.81	6.59	8.72	5.9		2:30 PM	JEFFC
9/22	Tues	7.92	10.03	6.57	8.97	5.7		9:00 AM	JEFFC
9/23	Wed	7.95	10.05	6.50	9.03	6.3		5:00 PM	JEFFC
9/24	Thurs	7.80	9.85	6.86	8.26	6.4		9:30 AM	JEFFC
9/25	Fri	7.77	9.82	AERATION	AERATION	6.7		3:00 PM	JEFFC
9/28	Mon	AERATION	AERATION	6.24	8.56	7.3		2:00 PM	JEFFC
9/29	Tues	7.57	9.78	6.28	8.61	7.3		7:00 AM	JEFFC
9/30	WED	7.62	9.74	6.31	8.66	7.0	3,895, 916	4:00 AM	JEFFC
						TOTAL	124.4	168,768 ÷ 30 =	5,625
							÷ 22	5.65	Daily

Moniteau School District  
WASTEWATER TREATMENT FACILITY  
MONTHLY OPERATORS REPORT

FLOW -  $168,768 \div 30 = 5,625$  Daily Avg.

U.V Light -  $124.4 \div 22 = 5.65$  Daily Avg.

PH - Low 6.24

High 8.17

D.O. - Low 7.41

High 10.05

TOTAL Nitrogen -  $0.910 + 0.221 = 1.131 \div 2 = 0.565$  Avg.

TOTAL Suspended Solids -  $< 5 + < 5 = < 5$  Avg.

NITRATE / Nitrite -  $0.910 + 0.221 = 1.131 \div 2 = 0.565$  Avg.

Phosphorus -  $0.15 + 5.5 = 5.65 \div 2 = 2.82$  Avg.

CBOD -  $< 3.00 + < 3.00 = < 3.00$  Avg.

Fecal Coliforms -  $< 1 + < 1 = < 1$  Avg.

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONTEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341  
 PERMIT NUMBER

001  
 OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 09/01/2020  
 DMR Effective To: 09/30/2020  
 Permit Expires: 05/31/2022  
 Permit Application Due: 12/02/2021  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2020	09	01	2020	09	30

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.41		***		1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min		***		1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.24		8.17		1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min		9.0 Max		1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		<5.0		***		2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo		***		2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		***		***		2/month	Grab
	PERMIT REQUIREMENT	***		***		***		2/month	Grab
Total Phosphorus (00655)	SAMPLE MEASUREMENT	***		***		***		2/month	Grab
	PERMIT REQUIREMENT	***		***		***		2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***		***		1/week	Grab
	PERMIT REQUIREMENT	***		***		***		1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.005625		***		***		1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	MGD	***		***		1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		***	<1.0	<1.0		2/month	Grab
	PERMIT REQUIREMENT	***	***		***	200 Geo Mean	1000 IMAX	No./100 ml	2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		***	<3.0	***		2/month	Grab
	PERMIT REQUIREMENT	***	***		***	.25 Avg Mo	***	mg/L	2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



## Your eDMR Report Has Been Received For Permit No. PA0091341

**From:** depgreenporthelpdesk@state.pa.us

**To:** monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

**Date:** Monday, October 5, 2020, 01:35 PM EDT

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL

**Permit Number:** PA0091341

**Report Frequency:** Monthly

**Report Type:** DMR

**Reporting Period:** 09/01/2020-09/30/2020

**Report Due Date:** 10/28/2020

**Submitted By:** Jeffrey Campbell

**Submission Id:** 228403

**Submission Status:** Received

**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

17 September 2020

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 0090388**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	0090388-01	Waste Water	09/03/2020 12:00	9/3/20 14:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

#### Definitions

- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- C CBOD/ BOD dilutions did not meet method criteria of 1.0 mg/L final DO and/or 2.0 mg/L loss (depletion); results are estimated.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/17/2020 14:59

Lab Sample ID#: 0090388-01  
 Sample Type: Waste Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Effluent Grab

Sample Begin Date: 09/03/2020 00:00  
 Sample End Date: 09/03/2020 12:00  
 Receipt Date: 09/03/2020 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	0.221	mg/L		0.104	DAA	09/08/20 16:50	09/10/20 11:06
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	09/08/20 13:45	09/08/20 15:00
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	0.221	mg/L		0.104	DAA	09/08/20 16:50	09/10/20 11:06
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	5.5	mg/L		1.0	JPD	09/16/20 13:48	09/17/20 09:34
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	C, G	3.00	AW	09/04/20 14:46	09/09/20 09:20
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	09/03/20 15:50	09/04/20 13:36



**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

**HEADQUARTERS**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

**NORTHERN DIVISION**  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

**NORTHWEST DIVISION**  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Containers	Container Type	Analysis Requested
		Composite	Grab			
		Date on/off	Time on/off	Matrix	Preservative	
Effluent Outfall 001	0090388			WW	Poly 1000mL	CBOD, TSS
				WW	None	Total Nitrogen, Total Phosphorus
				WW	H2SO4	Fecal Coliform
					Sterile Plastic 125mL	
					Na2S2O3	

*Handwritten notes in table:*  
 - Date: 9/3/20, Time: 12:00 noon  
 - Matrix: WW  
 - Container Type: Poly 1000mL, None, H2SO4, Sterile Plastic 125mL, Na2S2O3  
 - Analysis Requested: CBOD, TSS, Total Nitrogen, Total Phosphorus, Fecal Coliform

**Project Notes:**  
**Wastewater**

**Company/Name:** MONITEAU SCHOOL DISTRICT

**Contact Person:** JEFFREY CAMPBELL  
**Address:** 1810 WEST SUNBURY ROAD  
 WEST SUNBURY, PA 16061  
**Phone / Cell:** 724-406-4426  
**Email:** jcampbell@moniteau.k12.pa.us

**Signature/Date/Time Log:**

Sampled By: (Signature)	9/3/20	12:00 noon
Relinquished By: (Signature)	9/3/20	12:05
Received By: (Signature)	9/3/20	1430
Received By: (Signature)	9/3/20	1430
Received By: (Signature)		

**Correct Preservations:** Y / N / N / A  
**Correct Containers:** Y / N / N / A  
**Receipt Temperature:**







### Results Report

Order ID: 0092209

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 0092209-01	Site: 0090388-01	Sample ID: 0090388
Collector: Client	Collect Date: 09/03/2020 12:00 pm	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

<b>Inorganics</b>										
Total Kjeldahl Nitrogen (TKN)	< 0.50	B3	mg/L	EPA 351.2	0.50	1	09/10/20	ZJH	09/11/20 15:20	DWL

**Data Qualifiers:**

B3      The target analyte was detected in the Method, Dilution Water, Instrument or Extraction Blank or Sterility Check at or above the MRL or applicable method, client, or regulatory requirement. Possibility of high bias in the sample result, however it is ND.

**Sample Receipt Conditions:**

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Lisa F. Care  
Project Manager I

Report Generated On: 09/14/2020 2:07 pm      0092209  
STL\_Results Revision #1.9      Effective: 04/16/2020



**SUBCONTRACT O**  
**Environmental Service Lab**  
**0090388**



0092209  
 Lisa F. Care

Please report all results to [reports@envlabs.com](mailto:reports@envlabs.com)

**SENDING LABORATORY:**

Environmental Service Laboratories, Inc.  
 1803 Philadelphia Street  
 Indiana, PA 15701  
 Phone: 724-463-8378  
 Fax: 724-465-4209  
 Project Manager: Rebecca Erwin

**RECEIVING LABORATORY:**

Suburban Water Testing Labs - Reading  
 1037F MacArthur Road  
 Reading, PA 19605  
 Phone : (610) 375-8378  
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0090388-01			
Matrix: Water	Sampled: 09/03/2020 12:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	09/16/2020 23:00	10/01/2020 12:00	
Containers Supplied: Poly 250mL, HNO3 (D) <u>PHEZ ANB</u>			

**Suburban Testing Labs**

Lab Date/Time: 9/4/20 11:20 Lab Temp: 2.1  
 Number of containers/coolers match number on COC?  Y  N  
 Sample labels and COC are free of discrepancies?  Y  N  
 All containers in tact?  Y  N  
 Received in lab within acceptable temperature limits?  Y  N  
 40mL VOA vials free of headspace?  Y  N  
 Relinquished by: Delivery  
 Received in Lab by: Lauren Haring ①

[Signature] 9/3/20  
 Released By \_\_\_\_\_ Date \_\_\_\_\_ Received By \_\_\_\_\_ Date \_\_\_\_\_

Released By \_\_\_\_\_ Date \_\_\_\_\_ Received By \_\_\_\_\_ Date \_\_\_\_\_







1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

30 September 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0091555**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0091555-01	Waste Water	09/17/2020 11:30	9/17/20 14:20	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

#### Definitions

- C CBOD/ BOD dilutions did not meet method criteria of 1.0 mg/L final DO and/or 2.0 mg/L loss (depletion); results are estimated.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/30/2020 15:33

**Lab Sample ID#:** 0091555-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 09/17/2020 11:30  
**Receipt Date:** 09/17/2020 14:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	0.910	mg/L		0.208	DAA	09/23/20 17:05	09/24/20 18:05
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	09/22/20 09:24	09/22/20 12:30
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	0.910	mg/L		0.208	DAA	09/23/20 17:05	09/24/20 18:05
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	0.15	mg/L		0.10	JPD	09/30/20 13:11	09/30/20 13:30
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	C	3.00	AW	09/18/20 12:55	09/23/20 10:22
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	09/17/20 15:02	09/18/20 12:36

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTERS  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

**SAMPLE REQUEST & CHAIN OF CUSTODY**



NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY  
FAX: (570) 321-1967

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab				
		Date on/off	Date				
Effluent Outfall 001	0041555		9/17/20	WW	1	Poly 1000mL	CBOD, TSS
			11:30 AM	WW	1	None	7
				WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
				WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform
<p>Project Notes:</p> <p><b>Wastewater</b></p> <p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Address: <b>1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 724-406-4426</b></p> <p>Phone / Cell: <b>icampbell@moniteau.k12.pa.us</b></p> <p>Email: <b>icampbell@moniteau.k12.pa.us</b></p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) *[Signature]* Date/ Time 9/17/20 1200  
 Relinquished By: (Signature) *[Signature]* Date/ Time 9/17/20 1355  
 Received By: (Signature) *[Signature]* Date/ Time 9/17/20 1420  
 Relinquished By: (Signature) *[Signature]* Date/ Time  
 Received By: (Signature) *[Signature]* Date/ Time  
 Relinquished By: (Signature) *[Signature]* Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature







### Results Report

Order ID: 0094129

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 0094129-01	Site: 0091555-01	Sample ID:
Collector: Client	Collect Date: 09/17/2020 11:30 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<b>Inorganics</b>									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	09/21/20	CJ	09/23/20 12:05	DWL

**Sample Receipt Conditions:**  
All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

\**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

**Reviewed and Released By:**

Kelly Mays  
Client Services Supervisor

Report Generated On: 09/23/2020 4:37 pm      0094129  
STL\_Results Revision #1.9      Effective: 04/16/2020







0094129  
 Lisa F. Care

Please report all results to reports@envlabs.com. C

**SENDING LABORATORY:**

Environmental Service Laboratories, Inc.  
 1803 Philadelphia Street  
 Indiana, PA 15701  
 Phone: 724-463-8378  
 Fax: 724-465-4209  
 Project Manager: Rebecca Erwin

**RECEIVING LABORATORY:**

Suburban Water Testing Labs - Reading  
 1037F MacArthur Road  
 Reading, PA 19605  
 Phone : (610) 375-8378  
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0091555-01			
Matrix: Water	Sampled: 09/17/2020 11:30	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	09/29/2020 23:00	10/15/2020 11:30	
Containers Supplied: Poly 250mL, H2SO4 (D)			

*(1) 250mlp H2SO4  
 Phila LHM  
 9/18/20*

**Suburban Testing Labs**

Lab Date/Time: 9/18/20 10:14 Lab Temp: 1.7°C  
 Number of containers/coolers match number on COC? Y/N  
 Sample labels and COC are free of discrepancies? Y/N  
 All containers in tact? Y/N  
 Received in lab within acceptable temperature limits? Y/N  
 40mL VOA vials free of headspace? Y/N  
 Relinquished by: Delivery  
 Received in Lab by: LHM DT 1.7  
ice

Released By: [Signature] Date: 9/18/20 Received By: \_\_\_\_\_ Date: \_\_\_\_\_

Released By: \_\_\_\_\_ Date: \_\_\_\_\_ Received By: \_\_\_\_\_ Date: \_\_\_\_\_



**Moniteau School District  
Maintenance Department  
September 2020  
Moniteau High School  
Monthly Water Treatment  
Plant  
Operations Report**

MONTH SEAT 2020 MONITEAU HIGH SCHOOL WATER TREATMENT PLANT													
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME		
1	Tues	74.0	4.85	3,727, 148	0.73	0.76	7.5	0.00	0	1.11	Jeff C	11:30 AM	
2	Wed	64.0	9.97	3,758, 411	0.96	1.15	7.3	0.00	0	0.58	Jeff C	7:00 AM	
3	Thurs	66.1	9.00	3,772, 179	0.91	0.99	7.3	0.00	0	0.61	Jeff C	5:00 PM	
4	Fri	67.0	8.10	3,772, 179	0.90	0.98	7.3	0.00	0	0.68	Jeff C	7:00 AM	
5	SAT												
6	SUN												
7	Mon	70.0	8.30	3,774, 762	0.90	0.97	7.3	0.00	0	0.72	Jeff C	11:30 AM	
8	Tues	70.0	7.07	3,774, 762	0.91	0.98	7.3	0.00	0	0.75	Jeff C	3:00 PM	
9	Wed	69.4	9.00	3,784, 234	0.99	0.99	7.3	0.00	0	1.01	Jeff C	7:00 AM	
10	Thurs	89.5	7.72	3,784, 234	1.07	1.17	7.3	0.00	0	1.03	Jeff C	1:30 PM	
11	Fri	69.0	8.31	3,790, 522	1.83	1.95	7.3	0.00	0	1.22	Jeff C	7:30 AM	
12	SAT												
13	SUN												
14	Mon	68.7	8.49	3,807, 441	1.23	1.40	7.4	0.03	0	1.13	Jeff C	7:15 AM	
15	Tues	62.0	8.72	3,834, 132	0.81	0.96	7.4	0.04	0	2.17	Jeff C	8:00 AM	
16	Wed	63.2	8.55	3,844, 358	0.74	0.76	7.4	0.01	0	1.96	Jeff C	3:30 PM	
17	Thurs	64.0	8.02	3,844, 358	0.60	0.61	7.4	0.01	0	1.95	Jeff C	8:00 AM	
18	Fri	64.4	8.57	3,849, 634	0.57	0.66	7.2	0.06	0	1.20	Jeff C	9:00 AM	
19	SAT												
20	SUN												
21	Mon	65.0	6.02	3,849, 634	0.55	0.65	7.2	0.03	0	1.23	Jeff C	7:00 PM	
22	Tues	63.0	9.71	3,863, 708	0.50	0.61	7.3	0.05	0	1.39	Jeff C	7:00 AM	
23	Wed	63.4	8.16	3,863, 708	0.51	0.63	7.3	0.04	0	1.38	Jeff C	9:00 AM	
24	Thurs	64.5	7.72	3,863, 708	0.48	0.54	7.3	0.04	0	1.37	Jeff C	2:00 PM	
25	Fri	65.4	9.90	3,879, 276	0.46	0.50	7.3	0.04	0	1.04	Jeff C	11:00 AM	
26	SAT												
27	SUN												
28	Mon	68.0	8.03	3,879, 276	0.48	0.53	7.3	0.02	0	1.01	Jeff C	11:30 AM	
29	Tues	66.9	9.09	3,889, 968	0.51	0.60	7.3	0.02	0	1.09	Jeff C	9:00 AM	
30	WED	65.0	9.57	3,895, 916	0.87	1.01	7.2	0.00	0	0.65	Jeff C	1:30 PM	
31													

August 31 2020 Meter Reading 3,725, 152

SEWAGE Samples WATER Samples





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 September 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0090387**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 704**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	0090387-01	Drinking Water	09/03/2020 12:20	9/3/20 14:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
Project Manager







1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/11/2020 08:41

**Lab Sample ID#:** 0090387-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 09/03/2020 12:20  
**Receipt Date:** 09/03/2020 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.940	mg/L		0.200	PFS	09/03/20 12:20	09/03/20 12:20
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	09/03/20 15:45	09/04/20 16:34
E. Coli	Absent	per 100 mL		1	DAA	09/03/20 15:45	09/04/20 16:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-8376



0090387

FAX: (570) 321-1957  
FOR INTERNAL LABORATORY USE ONLY

# SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

ORTHWEST DIVISION  
50 Main Street  
Harpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

Sample Identification CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK		ESL# 0090387	Sample Type Date: 9-3-20 Time: 12:00	Matrix DW	# of Bottles 1	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC/EC Free Chlorine 94
704: Jan, Mar, May, Jul, Sept, Nov 802: Feb, Apr, Jun, Aug, Oct, Dec							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) Relinquished By: (Signature)		Date/ Time 9-3-20 12:00 9-3-20 14:05		Date/ Time 9/3/20 1430		Received By: (Signature) Received By: (Signature) Received By: (Signature)	
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Receipt Temperature		Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Monthly	
Company/Name: MONITEAU SCHOOL DISTRICT Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 Contact Person: JEFFREY CAMPBELL Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.k12.pa.us Billing Address: PWSID: 5100324							

4.1 #4 1430 D97

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	090320	704		090320	D	1220	32382	0090387-01	BROWNKA_59
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	704		090320	D	1220	32382	0090387-01	BROWNKA_60
5100324	1013	FREE CHLORINE	301	1.72	091020	802		091020	D	1205	32382	0090930-01	BROWNKA_61



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Monloursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 September 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0090930**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0090930-01	Drinking Water	09/10/2020 12:05	9/10/20 14:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/11/2020 09:33

**Lab Sample ID#:** 0090930-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink

**Sample Date:** 09/10/2020 12:05  
**Receipt Date:** 09/10/2020 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	1.72	mg/L		0.200	PFS	09/10/20 12:05	09/10/20 12:05

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 0090930	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: 802	01	Date: 9/10/20 Time: 1205	DW	Field	Field	Free Chlorine 1.72 mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>		Notes/Special Instructions:
<p>Drinking Water Moniteau Jr/Sr - Weekly</p>		
Company/Name:	MONITEAU SCHOOL DISTRICT	
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061	
Contact Person:	JEFFREY CAMPBELL	
Phone Number:	724-406-4426	
Cell Phone:	jcampbell@moniteau.k12.pa.us	
Email Address:	jcampbell@moniteau.k12.pa.us	
Billing Address:	51D0324	
PWSID:		
Received By: (Signature)	Date/ Time	Received By: (Signature)
Received By: (Signature)	Date/ Time	Received By: (Signature)
Received By: (Signature)	Date/ Time	Received By: (Signature)
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature



E-Government Application for Drinking Water Program  
 SAFE DRINKING WATER ACT  
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL  
 SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	090320	704		090320	D	1220	32382	0090387-01	BROWNKA_59
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	704		090320	D	1220	32382	0090387-01	BROWNKA_60
5100324	1013	FREE CHLORINE	301	1.72	091020	802		091020	D	1205	32382	0090930-01	BROWNKA_61



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

17 September 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0091548**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	0091548-01	Drinking Water	09/17/2020 12:05	9/17/20 14:27	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/17/2020 16:26

Lab Sample ID#: 0091548-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 803 Admin Sink

Sample Date: 09/17/2020 12:05  
 Receipt Date: 09/17/2020 14:27

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.790	mg/L		0.200	PFS	09/17/20 12:05	09/17/20 12:05

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



ORTHWEST DIVISION  
50 Main Street  
Harpsville, PA 16  
724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# <i>0091548</i>	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>		Date: <u>9-17-05</u>	Time: <u>1205</u>	DW	Field	Field	Free Chlorine <u>.79</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

Notes/Special Instructions:

Drinking Water *Moniteau Jr/Sr - Weekly*

Sampled By: (Signature) [Signature] Date/ Time 9-17-05 1205

Relinquished By: (Signature) [Signature] Date/ Time 9-17-05 1355

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) [Signature] Date/ Time 9-17-05 1420

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature \_\_\_\_\_

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD**

**WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.k12.pa.us**

Billing Address: **5100324**

PWSID: **5100324**



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	090320	704		090320	D	1220	32382	0090387-01	BROWNKA_59
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	704		090320	D	1220	32382	0090387-01	BROWNKA_60
5100324	1013	FREE CHLORINE	301	1.72	091020	802		091020	D	1205	32382	0090930-01	BROWNKA_61
5100324	1013	FREE CHLORINE	301	0.79	091720	803		091720	D	1205	32382	0091548-01	BROWNKA_643



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

25 September 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 0092118  
Project: Drinking Water Moniteau Jr/Sr - Weekly  
Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0092118-01	Drinking Water	09/24/2020 10:30	9/24/20 13:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/25/2020 09:51

**Lab Sample ID#:** 0092118-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 09/24/2020 10:30  
**Receipt Date:** 09/24/2020 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.440	mg/L		0.200	PFS	09/24/20 10:30	09/24/20 10:30

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-9376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 0092118	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 804	01	Date	Time	DW	Field	Field	Free Chlorine . 94 mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

Sampled By: (Signature) *[Signature]* Date/ Time 9/24/20 10:30  
 Relinquished By: (Signature) *[Signature]* Date/ Time 9/24/20 1:50  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) *[Signature]* Date/ Time 9/24/20 13:00  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Notes/Special Instructions: **Drinking Water Moniteau Jr/Sr - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**  
 Contact Person: \_\_\_\_\_  
 Phone Number: **724-406-4426**  
 Cell Phone: **jcampbell@moniteau.k12.pa.us**  
 Billing Address: \_\_\_\_\_  
 PWSID: **5100324**

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_



E-Government Application for Drinking Water Program  
 SAFE DRINKING WATER ACT  
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.94	090320	704		090320	D	1220	32382	0090387-01	BROWNKA_59
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090420	704		090320	D	1220	32382	0090387-01	BROWNKA_60
5100324	1013	FREE CHLORINE	301	1.72	091020	802		091020	D	1205	32382	0090930-01	BROWNKA_61
5100324	1013	FREE CHLORINE	301	0.79	091720	803		091720	D	1205	32382	0091548-01	BROWNKA_643
5100324	1013	FREE CHLORINE	301	0.44	092420	804		092420	D	1030	32382	0092118-01	BROWNKA_961