

**Moniteau School District**  
**Maintenance Department**  
**Dassa McKinney Elementary School**  
**Water Treatment Facility**  
**Monthly Operations Report for**  
**August 2021**

Dassa McKinney Elementary School Water Treatment Facility										
Month	Aug	2021								
Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sun									
2	Mon	8.7	0.04	0.42	0.48	2.23	12701600	Jeff R	3:30P	800
3	Tues	8.7	0.02	0.40	0.44	2.88	12702200	Jeff R	3:30P	600
4	Wed	8.7	0.03	0.52	0.61	2.52	12702300	Jeff R	8:00A	106
5	Thurs	8.7	0.03	0.57	0.66	2.67	12703200	Jeff R	8:30A	900
6	Fri									
7	Sat									
8	Sun									
9	Mon	8.7	0.04	0.50	0.57	2.81	12704400	Jeff R	3:30P	1200
10	Tues	8.7	0.04	0.48	0.55	3.04	12705400	Jeff R	3:00P	1000
11	Wed	8.7	0.03	0.49	0.58	3.13	12705900	Jeff R	3:30P	500
12	Thurs	8.7	0.03	0.48	0.56	2.34	12706700	Jeff R	3:30P	800
13	Fri									
14	Sat									
15	Sun									
16	Mon	8.7	0.04	0.46	0.53	2.55	12707000	Jeff R	3:30P	300
17	Tues	8.7	0.05	0.47	0.53	2.48	12707400	Jeff R	3:30P	400
18	Wed	8.7	0.02	0.90	0.96	2.27	12707600	Jeff R	1:00P	200
19	Thurs	8.7	0.07	0.72	0.77	3.28	12708000	Jeff R	3:30P	400
20	Fri	8.7	0.04	0.74	0.81	3.11	12708100	Jeff R	3:30P	100
21	Sat									
22	Sun									
23	Mon	8.7	0.02	0.37	0.45	2.12	12709100	Jeff R	3:30P	1000
24	Tues	8.7	0.03	0.36	0.43	2.38	12709600	Jeff R	3:30P	500
25	Wed	8.7	0.02	0.40	0.47	2.40	12711000	Jeff R	3:00P	1400
26	Thurs	8.7	0.00	0.40	0.45	2.32	12714200	Jeff R	1:00P	3200
27	Fri	8.7	0.02	0.38	0.46	3.94	12720500	Jeff R	3:00P	6300
28	Sat									
29	Sun									
30	Mon	8.7	0.01	0.50	0.58	3.82	12724900	Jeff R	2:30P	4400
31	Tues	8.7	0.02	0.53	0.59	3.05	12729400	Jeff R	2:30P	4500

July 29, Meter Reading - 12,699,800



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 August 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1080920**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	1080920-01	Drinking Water	08/09/2021 10:00	8/9/21 17:14	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpshville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/11/2021 20:00

Lab Sample ID#: 1080920-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 801 Kitchen Sink

Sample Date: 08/09/2021 10:00  
 Receipt Date: 08/09/2021 17:14

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.830	mg/L		0.200	PS	08/09/21 10:00	08/09/21 10:00

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

**SAMPLE REQUEST & CHAIN OF CUSTODY**

SE   1   OF   1  

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	 <b>1080920</b>	SOUTHERN DIVISIC 1276 Bentleyville Rc Van Voorhis, PA 15: (724) 258-TEST FAX: (724) 258-83:		NORTHWEST DIVISION 950 Main Street Sharpville, PA 16 (724) 463-TEST FAX: (724) 465-4209	
--	---	---	---	---	---

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>SD</u>	<u>1080920</u>	<u>8-9-21</u>	<u>1000</u>	DW	Field	Field	Free Chlorine <u>.53</u> mg/L

- ROTATION**
- Wk 1 - 801 Kitchen Sink
  - Wk 2 - 802 Room 617 Sink
  - Wk 3 - 803 Room 606 Sink
  - Wk 4 - 804 Room 408 Sink
  - Wk 5 - 802 Room 617 Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

***Drinking Water Dassa McKinney - Weekly***

Sampled By: (Signature) 	Date/ Time <u>8-9-21 1000</u>	Relinquished By: (Signature) 	Date/ Time <u>8-9-21 17:04</u>	Received By: (Signature) <u>XS 00382</u>	Date/ Time <u>8-9-21 17:14</u>
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Relinquished By: (Signature)	Date/ Time

Company/Name:	<b>MONITEAU SCHOOL DISTRICT</b>
Address:	<b>391 HOOKER ROAD WEST SUNBURY, PA 16061</b>
Contact Person:	<b>JEFFREY CAMPBELL</b>
Phone Number:	
Cell Phone:	<b>724-406-4426</b>
Email Address:	<b>jcampbell@moniteau.org</b>
Billing Address:	
PWSID:	<b>5100316</b>

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_



# Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT VIEW/EDIT RECORDS

#### 5100316: DASSA MCKINNEY ELEM SCHOOL

##### SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	080921	801		080921	D	1000	32382	1080920-01	BROWNKA_266
5100316	1013	FREE CHLORINE	301	0.53	080521	802		080521	D	1220	32382	1080632-01	BROWNKA_264
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1220	32382	1080632-01	BROWNKA_265

#### 5100316: DASSA MCKINNEY ELEM SCHOOL

##### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_33
5100316	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_34



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpshville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 August 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1080632**  
**Project: Drinking Water Dassa McKinney - Monthly 802**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1080632-01	Drinking Water	08/05/2021 12:20	8/5/21 15:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/11/2021 20:02

**Lab Sample ID#:** 1080632-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 08/05/2021 12:20  
**Receipt Date:** 08/05/2021 15:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.530	mg/L		0.200	PS	08/05/21 12:20	08/05/21 12:20
<b>Microbiology</b>	<b>Analytical Method: SM9223 B-04</b>				<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	08/05/21 16:37	08/06/21 18:42
E. Coli	Absent	per 100 mL		1	DAA	08/05/21 16:37	08/06/21 18:42

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIV.  
1276 Bentleyville  
Van Voorhis, PA  
(724) 258-TEST  
FAX: (724) 258-



1080632

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
801 KITCHEN SINK 802 ROOM 617 SINK	1080632 01	8-5-21	12:20	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine <u>53</u> mg/L

**Rotation:**

801: Jan, Mar, May, Jul, Sep,  
Nov  
802: Feb, Apr, Jun, Aug, Oct,  
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

**Notes/Special Instructions::**

*Drinking Water Dass McKinney - Monthly*

Sampled By: (Signature)	Date/ Time 8-5-21 12:20	Received By: (Signature)	Date/ Time 8-5-21 15:30
Relinquished By: (Signature)	Date/ Time 8-5-21 15:05	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time

Company/Name:	<b>MONITEAU SCHOOL DISTRICT</b>
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061
Contact Person:	JEFFREY CAMPBELL
Phone Number:	
Cell Phone:	724-406-4426
Email Address:	jcampbell@moniteau.org
Billing Address:	
PWSID:	5100316

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature 6.2°C #4

# Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT VIEW/EDIT RECORDS

#### 5100316: DASSA MCKINNEY ELEM SCHOOL

##### SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	080921	801		080921	D	1000	32382	1080920-01	BROWNKA_266
5100316	1013	FREE CHLORINE	301	0.53	080521	802		080521	D	1220	32382	1080632-01	BROWNKA_264
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1220	32382	1080632-01	BROWNKA_265

#### 5100316: DASSA MCKINNEY ELEM SCHOOL

##### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_33
5100316	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_34



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

24 August 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 1082136  
Project: Drinking Water Dassa McKinney - Weekly  
Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	1082136-01	Drinking Water	08/19/2021 11:15	8/19/21 15:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions


RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/24/2021 10:04

**Lab Sample ID#:** 1082136-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Room 606 Sink

**Sample Date:** 08/19/2021 11:15  
**Receipt Date:** 08/19/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.820	mg/L		0.200	PS	08/19/21 11:15	08/19/21 11:15

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Roa  
Van Voorhis, PA 1536  
(724) 258-TEST  
FAX: (724) 258-8376



NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>803</u>	<u>1082136</u>	<u>SPM</u>	<u>1115</u>	DW	Field	Field	Free Chlorine <u>.82</u> mg/L

**ROTATION**

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

**Drinking Water Dassa McKinney - Weekly**

Sampled By: (Signature)	Date/ Time <u>8/19/21 1115</u>	Received By: (Signature) <u>SPM 8/19/21 1500 (03582)</u>	Date/ Time
Relinquished By: (Signature)	Date/ Time <u>8/19/21 1430</u>	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: \_\_\_\_\_

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.org**

Billing Address: \_\_\_\_\_

PWSID: **5100316**



# Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT VIEW/EDIT RECORDS

#### 5100316: DASSA MCKINNEY ELEM SCHOOL

##### SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.83	080921	801		080921	D	1000	32382	1080920-01	BROWNKA_266
5100316	1013	FREE CHLORINE	301	0.53	080521	802		080521	D	1220	32382	1080632-01	BROWNKA_264
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1220	32382	1080632-01	BROWNKA_265
5100316	1013	FREE CHLORINE	301	0.82	081921	803		081921	D	1115	32382	1082136-01	BROWNKA_1687

#### 5100316: DASSA MCKINNEY ELEM SCHOOL

##### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1010	BARIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1159
5100316	1015	CADMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1161
5100316	1020	CHROMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1163
5100316	1025	FLUORIDE (IOC)	120	0.119	0.05000		081621	101		080521	E	1210	32382	1080610-01	BROWNKA_1169
5100316	1035	MERCURY (IOC)	103	0.0	0.00020		081321	101		080521	E	1210	32382	1080610-01	BROWNKA_1165
5100316	1036	NICKEL (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1167
5100316	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_33
5100316	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_34
5100316	2378	1,2,4-TRICHLOROENZE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA_729
5100316	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA_730
5100316	2955	XYLENES (TOTAL)	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA_731

# PENNSYLVANIA Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT VIEW/EDIT RECORDS

## 5100316: DASSA MCKINNEY ELEM SCHOOL

### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 732
5100316	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 733
5100316	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 734
5100316	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 735
5100316	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 736
5100316	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 737
5100316	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 738
5100316	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 739
5100316	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 740
5100316	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 741
5100316	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 742
5100316	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 743
5100316	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 744
5100316	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 745
5100316	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 746
5100316	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 747
5100316	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 748
5100316	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 749



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

27 August 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1082755**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804	1082755-01	Drinking Water	08/26/2021 12:00	8/26/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/27/2021 09:09

**Lab Sample ID#:** 1082755-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** John Belaniar  
**Client Sample ID:** 804

**Sample Date:** 08/26/2021 12:00  
**Receipt Date:** 08/26/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.400	mg/L		0.200	SPM	08/26/21 12:00	08/26/21 12:00

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

<b>HEADQUARTER</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<b>SOUTHEAST DIVISION</b> 1276 Ben Van Voorst (724) 258 FAX: (724) 258-	 1082755	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209
---	---	--	---

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>804</u>	<u>1082755</u>	<u>8-26-21</u>	<u>12:00</u>	DW	Field	Field	Free Chlorine <u>0.40</u> mg/L

- ROTATION**
- Wk 1 - 801 Kitchen Sink
  - Wk 2 - 802 Room 617 Sink
  - Wk 3 - 803 Room 606 Sink
  - Wk 4 - 804 Room 408 Sink**
  - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

**Drinking Water Dassa McKinney - Weekly**

Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>8-26-21 12:00</u>	Received By: (Signature) <u>SPM 8/26/21 1:50 (cess)</u> Date/ Time <u>8-26-21 14:35</u>
Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>8-26-21 14:35</u>	
Relinquished By: (Signature) _____ Date/ Time _____	
Relinquished By: (Signature) _____ Date/ Time _____	

Correct Preservations Y/N/NA      Correct Containers Y/N/NA      Receipt Temperature \_\_\_\_\_

Company/Name:	<b>MONITEAU SCHOOL DISTRICT</b>
Address:	<b>391 HOOKER ROAD WEST SUNBURY, PA 16061</b>
Contact Person:	<b>JEFFREY CAMPBELL</b>
Phone Number:	<b>724-406-4426</b>
Email Address:	<b>jcampbell@moniteau.org</b>
Billing Address:	
PWSID:	<b>5100316</b>





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNSKA_1773
5100316	2451	DICHLOROACETIC ACID	206	0.00227	081921	703		080921	D	0955	32382	1080924-01	BROWNSKA_1794
5100316	2452	TRICHLOROACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNSKA_1815
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNSKA_1836
5100316	2454	DIBROMOACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNSKA_1857
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00227	081921	703		080921	D	0955	32382	1080924-01	BROWNSKA_1878
5100316	2941	CHLOROFORM (THM)	221	0.00332	081521	703		080921	D	0955	32382	1080924-01	BROWNSKA_1899
5100316	2942	BROMOFORM (THM)	221	0.0	081521	703		080921	D	0955	32382	1080924-01	BROWNSKA_1920
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00252	081521	703		080921	D	0955	32382	1080924-01	BROWNSKA_1942
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00188	081521	703		080921	D	0955	32382	1080924-01	BROWNSKA_1963
5100316	2950	TRIHALOMETHANES	221	0.00772	081521	703		080921	D	0955	32382	1080924-01	BROWNSKA_1984
5100316	2450	MONOCHLOROACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNSKA_1774
5100316	2451	DICHLOROACETIC ACID	206	0.00242	081921	704		080921	D	0950	32382	1080924-02	BROWNSKA_1795
5100316	2452	TRICHLOROACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNSKA_1816
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNSKA_1837
5100316	2454	DIBROMOACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNSKA_1858
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00242	081921	704		080921	D	0950	32382	1080924-02	BROWNSKA_1879
5100316	2941	CHLOROFORM (THM)	221	0.00334	081521	704		080921	D	0950	32382	1080924-02	BROWNSKA_1900
5100316	2942	BROMOFORM (THM)	221	0.0	081521	704		080921	D	0950	32382	1080924-02	BROWNSKA_1921



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00241	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1941
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00159	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1962
5100316	2950	TRihalOMETHANES	221	0.00734	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1983
5100316	1013	FREE CHLORINE	301	0.83	080921	801		080921	D	1000	32382	1080920-01	BROWNKA_266
5100316	1013	FREE CHLORINE	301	0.53	080521	802		080521	D	1220	32382	1080632-01	BROWNKA_264
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1220	32382	1080632-01	BROWNKA_265
5100316	1013	FREE CHLORINE	301	0.82	081921	803		081921	D	1115	32382	1082136-01	BROWNKA_1687
5100316	1013	FREE CHLORINE	301	0.4	082621	804		082621	D	1200	32382	1082755-01	BROWNKA_2118

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1010	BARIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1159
5100316	1015	CADMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1161
5100316	1020	CHROMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1163
5100316	1025	FLUORIDE (IOC)	120	0.119	0.05000		081621	101		080521	E	1210	32382	1080610-01	BROWNKA_1169
5100316	1035	MERCURY (IOC)	103	0.0	0.00020		081321	101		080521	E	1210	32382	1080610-01	BROWNKA_1165
5100316	1036	NICKEL (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1167
5100316	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_33
5100316	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA_34

# Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT VIEW/EDIT RECORDS

## 5100316: DASSA MCKINNEY ELEM SCHOOL

### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2378	1,2,4-TRICHLOROBENZE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 729
5100316	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 730
5100316	2955	XYLENES (TOTAL)	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 731
5100316	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 732
5100316	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 733
5100316	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 734
5100316	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 735
5100316	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 736
5100316	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 737
5100316	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 738
5100316	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 739
5100316	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 740
5100316	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 741
5100316	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 742
5100316	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 743
5100316	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 744
5100316	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 745
5100316	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 746
5100316	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 747
5100316	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 748



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA749

**Moniteau School District  
Maintenance Department  
Moniteau High School  
Water Treatment Facility  
Monthly Operations Report for  
August 2021**



MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT										
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
1	SUN											
2	Mon	69.0	11.78	4,945,349	1.47	1.66	7.2	0.02	0	2.65	Jeff C 9:30 AM	
3	Tues	71.7	10.90	4,945,349	1.38	1.40	7.2	0.01	0	2.62	Jeff C 4:00 PM	
4	Wed	72.1	10.32	4,945,349	1.21	1.25	7.2	0.01	0	2.60	Jeff C 9:00 AM	
5	Thurs	74.3	9.88	4,945,349	1.25	1.34	7.2	0.02	0	1.35	Jeff R 11:00 AM	
6	FRI	75.1	9.00	4,945,349	1.22	1.25	7.2	0.01	0	1.37	Jeff C 6:00 PM	
7	SAT											
8	SUN											
9	Mon	75.1	7.82	4,945,349	0.95	1.09	7.2	0.01	0	2.12	Jeff C 4:00 PM	
10	Tues	76.3	7.04	4,945,349	0.96	1.10	7.2	0.01	0	2.11	Jeff C 2:30 PM	
11	Wed	77.4	11.03	4,961,035	1.68	1.79	7.1	0.02	0	1.85	Jeff C 1:00 PM	
12	Thurs	77.7	10.12	4,961,035	1.65	1.79	7.1	0.03	0	1.83	Jeff C 4:30 AM	
13	Fri	78.8	9.58	4,961,035	1.64	1.77	7.1	0.03	0	1.83	Jeff C 7:50 AM	
14	SAT											
15	Sun											
16	Mon	78.6	9.17	4,961,035	1.63	1.75	7.1	0.03	0	1.84	Jeff C 11:00 AM	
17	Tues	78.1	8.00	4,961,035	1.57	1.62	7.1	0.02	0	1.80	Jeff C 1:00 PM	
18	Wed	66.1	10.64	5,005,346	1.24	1.27	7.2	0.00	0	0.99	Jeff C 4:00 PM	
19	Thurs	67.7	8.48	5,005,346	1.24	1.25	7.2	0.00	0	0.98	Jeff C 2:30 PM	
20	Fri	69.0	7.21	5,005,346	1.22	1.25	7.2	0.00	0	1.01	Jeff C 5:00 AM	
21	SAT											
22	Sun											
23	Mon	68.7	4.20	5,078,479	0.84	0.93	7.3	0.03	0	1.68	Jeff C 11:30 AM	
24	Tues	63.0	11.46	5,118,212	1.20	1.23	7.2	0.00	0	1.01	Jeff C 10:30 AM	
25	Wed	66.7	7.08	5,130,043	0.98	1.01	7.2	0.00	0	0.98	Jeff C 2:00 PM	
26	Thurs	60.1	9.29	5,148,106	0.97	1.00	7.2	0.00	0	0.98	Jeff C 9:00 AM	
27	Fri	65.0	10.40	5,180,119	0.98	1.06	7.2	0.00	0	0.99	Jeff C 2:00 PM	
28	SAT											
29	Sun											
30	mon	66.1	9.81	5,228,688	1.24	1.36	7.2	0.04	0	1.15	Jeff C 8:00 AM	
31	Tues											

WATER Samples

Sewage Samples





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

27 August 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1082756**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804	1082756-01	Drinking Water	08/26/2021 12:25	8/26/21 15:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/27/2021 09:09

**Lab Sample ID#:** 1082756-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** John Belaniar  
**Client Sample ID:** 804

**Sample Date:** 08/26/2021 12:25  
**Receipt Date:** 08/26/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.960	mg/L		0.200	SPM	08/26/21 12:25	08/26/21 12:25

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

DE   1   OF   1  

<b>HEADQUARTER</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<b>SOUTHERN DIVISION</b> 1276 Bentley Van Voorhis, (724) 258-TE FAX: (724) 2-	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209
---	---	---



Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>804</u>	<u>1032756</u> <u>91</u>	<u>8-26-21</u>	<u>1225</u>	DW	Field	Field	Free Chlorine <u>96</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

**Drinking Water Moniteau Jr/Sr - Weekly**

Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>8-26-21 1225</u>	Received By: (Signature) <u>[Signature]</u> Date/ Time <u>8/26/21 1200 (0-55)</u>	
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____		Received By: (Signature) _____ Date/ Time _____

Correct Preservations   Y   /   N   /   NA        Correct Containers   Y   /   N   /   NA        Receipt Temperature \_\_\_\_\_

Company/Name:	<b>MONITEAU SCHOOL DISTRICT</b>
Address:	<b>391 HOOKER ROAD WEST SUNBURY, PA 16061</b>
Contact Person:	<b>JEFFREY CAMPBELL</b>
Phone Number:	
Cell Phone:	<b>724-406-4426</b>
Email Address:	<b><u>campbell@moniteau.org</u></b>
Billing Address:	
PWSID:	<b>5100324</b>

# Department of Environmental Protection

E-Government Application for Drinking Water Program

**SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS**

## 5100324: MONITEAU JR/SR HIGH SCHOOL

### SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.08	080921	704		080921	D	1020	32382	1080919-01	BROWNSKA_271
5100324	1013	FREE CHLORINE	301	1.05	080521	802		080521	D	1255	32382	1080630-01	BROWNSKA_269
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1255	32382	1080630-01	BROWNSKA_270
5100324	1013	FREE CHLORINE	301	1.18	081921	803		081921	D	1127	32382	1082135-01	BROWNSKA_1593
5100324	1013	FREE CHLORINE	301	0.96	082621	804		082621	D	1225	32382	1082756-01	BROWNSKA_2119

## 5100324: MONITEAU JR/SR HIGH SCHOOL

### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1010	BARIUM (IOC)	169	0.109	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNSKA_1034
5100324	1015	CADMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNSKA_1044
5100324	1020	CHROMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNSKA_1054
5100324	1025	FLUORIDE (IOC)	120	0.134	0.05000		081521	101		080521	E	1255	32382	1080609-01	BROWNSKA_1064
5100324	1035	MERCURY (IOC)	103	0.0	0.00020		081321	101		080521	E	1255	32382	1080609-01	BROWNSKA_1074
5100324	1036	NICKEL (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNSKA_1084
5100324	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNSKA_35
5100324	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNSKA_36
5100324	2378	1,2,4-TRICHLOROENZE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNSKA_750
5100324	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNSKA_751



# Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT

#### VIEW/EDIT RECORDS

## 5100324: MONITEAU JR/SR HIGH SCHOOL

### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2955	XYLENES (TOTAL)	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 752
5100324	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 753
5100324	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 754
5100324	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 755
5100324	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 756
5100324	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 757
5100324	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 758
5100324	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 759
5100324	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 760
5100324	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921		1017	32382	1080929-01	BROWNKA 761
5100324	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 762
5100324	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 763
5100324	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921		1017	32382	1080929-01	BROWNKA 764
5100324	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 765
5100324	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 766
5100324	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 767
5100324	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 768
5100324	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 769
5100324	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 770



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

23 August 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1082135**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	1082135-01	Drinking Water	08/19/2021 11:27	8/19/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE   1   OF   1  

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SC  
12  
Va  
(7  
Fi



EASTERN DIVISION  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16151  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>803</u>	<u>1082135</u>	<u>8-19-21</u>	<u>1127</u>	DW	Field	Field	Free Chlorine <u>1.18</u> mg/L

- ROTATION

  - Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

**Drinking Water Moniteau Jr/Sr - Weekly**

Sampled By: (Signature)		Date/ Time	<u>8-19-21</u> <u>1127</u>	
Relinquished By: (Signature)		Date/ Time	<u>8-19-21</u> <u>1430</u>	Received By: (Signature)
Relinquished By: (Signature)		Date/ Time		Date/ Time
Relinquished By: (Signature)		Date/ Time		Date/ Time
Relinquished By: (Signature)		Date/ Time		Date/ Time

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number:

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.org**

Billing Address:

PWSID: **5100324**

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 753
5100324	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 754
5100324	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 755
5100324	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 756
5100324	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 757
5100324	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 758
5100324	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 759
5100324	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 760
5100324	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 761
5100324	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 762
5100324	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 763
5100324	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 764
5100324	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 765
5100324	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 766
5100324	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 767
5100324	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 768
5100324	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 769
5100324	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 770



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 August 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1080919**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	1080919-01	Drinking Water	08/09/2021 10:20	8/9/21 17:12	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/11/2021 20:00

**Lab Sample ID#:** 1080919-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 08/09/2021 10:20  
**Receipt Date:** 08/09/2021 17:12

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	1.08	mg/L		0.200	PS	08/09/21 10:20	08/09/21 10:20

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

**SAMPLE REQUEST & CHAIN OF CUSTODY**

SE   1   OF   1  

<b>HEADQUARTER</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<input checked="" type="checkbox"/>	<b>SOUTHERN DIVISION</b> 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	 <b>1080919</b>	<input type="checkbox"/>	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209	<input type="checkbox"/>
---	-------------------------------------	--	--	--------------------------	---	--------------------------

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
Distribution: <u>704</u>	<u>01</u>	<u>Stm</u>	<u>1020</u>	DW	Field	Field	Free Chlorine <u>1.08</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

**Drinking Water Moniteau Jr/Sr - Weekly**

Sampled By: (Signature) 	Date/ Time <u>8:21 10:20</u>	Received By: (Signature) <u>Xs</u>	Date/ Time <u>00389 8.9.21 17:12</u>
Relinquished By: (Signature) 	Date/ Time <u>8:21 1704</u>	Received By: (Signature) _____	Date/ Time _____
Relinquished By: (Signature) _____	Date/ Time _____	Received By: (Signature) _____	Date/ Time _____
Relinquished By: (Signature) _____	Date/ Time _____	Received By: (Signature) _____	Date/ Time _____

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: \_\_\_\_\_

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.org**

Billing Address: \_\_\_\_\_

PWSID: **5100324**

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_

# Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT VIEW/EDIT RECORDS

#### 5100324: MONITEAU JR/SR HIGH SCHOOL

##### SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.08	080921	704		080921	D	1020	32382	1080919-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	1.05	080521	802		080521	D	1255	32382	1080630-01	BROWNKA_269
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1255	32382	1080630-01	BROWNKA_270

#### 5100324: MONITEAU JR/SR HIGH SCHOOL

##### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA_35
5100324	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA_36



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 August 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1080630**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 802**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	1080630-01	Drinking Water	08/05/2021 12:55	8/5/21 15:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/11/2021 20:02

**Lab Sample ID#:** 1080630-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink

**Sample Date:** 08/05/2021 12:55  
**Receipt Date:** 08/05/2021 15:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-CIG-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	1.05	mg/L		0.200	PS	08/05/21 12:55	08/05/21 12:55
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	08/05/21 16:37	08/06/21 18:42
E. Coli	Absent	per 100 mL		1	DAA	08/05/21 16:37	08/06/21 18:42

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

BE   1   OF   1  

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab					
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN-SINK 802 ROOM 204 SINK	1080630 01	8-5-21	12:55	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine <u>1-05</u>

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

**Drinking Water Moniteau Jr/Sr - Monthly**

Sampled By: (Signature)

8-5-21 12:55  
Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

XS 00382  
Received By: (Signature)

8-5-21 15:30  
Date/ Time

Received By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Company/Name:

**MONITEAU SCHOOL DISTRICT**

Address:

1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061

Contact Person:

**JEFFREY CAMPBELL**

Phone Number:

Cell Phone:

724-406-4426

Email Address:

[jcampbell@moniteau.org](mailto:jcampbell@moniteau.org)

Billing Address:

PWSID:

5100324

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature 6-70C ± 0.4

# Department of Environmental Protection

## E-Government Application for Drinking Water Program

### SAFE DRINKING WATER ACT VIEW/EDIT RECORDS

#### 5100324: MONITEAU JR/SR HIGH SCHOOL

##### SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.08	080921	704		080921	D	1020	32382	1080919-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	1.05	080521	802		080521	D	1255	32382	1080630-01	BROWNKA_269
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1255	32382	1080630-01	BROWNKA_270

#### 5100324: MONITEAU JR/SR HIGH SCHOOL

##### SDWA4

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA_35
5100324	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA_36

**Moniteau School District  
Maintenance Department  
Moniteau High School  
Wastewater Treatment Facility  
Monthly Operations Report for  
August 2021**



JEFFREY CAMPBELL <jcampbell@moniteau.org>

## Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Fri, Sep 10, 2021 at 1:58 PM

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL  
**Permit Number:** PA0091341  
**Report Frequency:** Monthly  
**Report Type:** DMR  
**Reporting Period:** 08/01/2021-08/31/2021  
**Report Due Date:** 09/28/2021

**Submitted By:** Jeffrey Campbell  
**Submission Id:** 284515  
**Submission Status:** Received  
**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220  
 FACILITY: MONITEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220  
 STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2021  
 DMR Effective To: 08/31/2021  
 Permit Expires: 05/31/2022  
 Permit Application Due: 12/02/2021  
 No Discharge:

MONITORING PERIOD							
YEAR	MO	DAY		YEAR	MO	DAY	
2021	08	01	FROM	2021	08	31	TO

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***	***		5.90	***	***	mg/L	1/week	Grab
	PERMIT REQUIREMENT	***	***		4.0 Min	***	***		1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***	***		7.65	***	8.93	S.U.	1/week	Grab
	PERMIT REQUIREMENT	***	***		6.0 Min	***	9.0 Max		1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***	***		***	<5.0	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	30 Avg Mo	***		2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***	***		***	12.98	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	Monitor & Report Avg Mo	***		2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***	***		***	.965	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	Monitor & Report Avg Mo	***		2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***	***		***	6.22	***	µw/cm²	1/week	Grab
	PERMIT REQUIREMENT	***	***		***	Monitor & Report Avg Mo	***		1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.011075	***	MGD	***	***	***		1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***		***	***	***		1/week	Measured





**COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER**

**DISCHARGE MONITORING REPORT (DMR)**

PARAMETER		QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		***	<3.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	200 Geo Mean	1000 MAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		***	3.925	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	25 Avg Mo	***		2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------

Moniteau School District  
Moniteau High School  
WASTEWATER TREATMENT FACILITY  
MONTHLY OPERATIONS REPORT WORKSHEET  
August 2021

Flow  $343,339 \div 31 = 11,075$  Daily

U.V. 6.22

PH Low 7.65

High 8.93

D.O. Low 5.90

High 10.03

TOTAL Nitrogen -  $< 1.66 + 24.3 = 25.96 \div 2 = 12.98$

TSS -  $5 + < 5 = < 5$

TKN -  $< 0.625 + < 0.625 = 1.25 \div 2 = 0.625$

Nitrate/Nitrite -  $< 1.04 + 24.3 = 25.34 \div 2 = 12.67$

Phos -  $0.43 + 1.5 = 1.93 \div 2 = 0.965$

CBOD -  $< 2.00 + 5.85 = 7.85 \div 2 = 3.925$

Fecal -  $< 5 + < 1 = < 6 \div 2 = < 3$

Moniteau High School Sewage Treatment Plant						Daily Operations Worksheet			
Permit # PA0091341						Month	August 2021		
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	UV	Meter Reading	Time	Operator
8/2	Mon	8.75	9.40	8.35	5.90	8.5	4,945,349	9:00 AM	JEFF C
8/3	Tues	8.73	9.35	8.47	6.11	5.9		10:00 AM	JEFF C
8/4	Wed	8.67	9.85	7.80	6.55	5.7		10:00 AM	JEFF C
8/5	Thurs	8.90	9.85	Aeration		6.2		10:30 AM	JEFF R.
8/6	Fri	8.93	9.85	7.85	6.70	6.0		10:00 AM	JEFF C
8/9	Mon	8.93	9.83	7.89	6.75	6.1		9:00 AM	JEFF C
8/10	Tues	9.05	9.87	Aeration		6.2		11:00 AM	JEFF C
8/11	Wed.	8.70	9.37	7.70	8.49	4.0		8:00 AM	JEFF C
8/12	Thurs	8.75	9.33	7.72	8.38	4.9		4:00 AM	JEFF C
8/13	Fri	8.78	9.47	7.74	8.33	4.7		7:00 AM	JEFF C
8/16	Mon	8.80	9.63	7.78	8.30	4.5		8:00 AM	JEFF C
8/17	Tues	8.83	9.65	7.81	8.29	5.1		2:00 PM	JEFF C
8/18	Wed	8.83	9.66	7.85	8.20	5.0		2:30 AM	JEFF C
8/19	Thurs	8.70	9.68	7.88	8.18	5.0		11:30 AM	JEFF C
8/20	Fri	8.53	9.58	7.90	8.20	5.7		5:00 AM	JEFF C
8/23	Mon	8.49	9.30	7.97	8.23	6.5		4:00 PM	JEFF C
8/24	Tues	8.20	9.26	8.00	8.28	6.9		2:00 PM	JEFF C
8/25	Wed	8.65	10.03	7.60	8.18	8.7		7:00 AM	JEFF C
8/26	Thurs	8.59	NO AERATION		—	7.9		9:00 AM	JEFF C
8/27	Fri	8.01	9.17	7.65	8.21	7.8		5:00 AM	JEFF C
8/30	Mon	7.77	9.01	7.67	8.42	7.7		3:00 PM	JEFF C
8/31	Tues	7.73	8.80	7.71	8.40	7.9	5,288,688	8:00 AM	JEFF C
							343,339	= 31	11,075.45
							136.9	= 22	= 6.22





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

17 August 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1080612**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1080612-01	Waste Water	08/05/2021 10:45	8/5/21 15:15	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/17/2021 16:20

**Lab Sample ID#:** 1080612-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001

**Sample Date:** 08/05/2021 10:45  
**Receipt Date:** 08/05/2021 15:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	24.3	mg/L		1.66	DAA	08/16/21 15:33	08/16/21 15:33
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	08/10/21 11:50	08/10/21 15:00
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NH3 D-11</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	08/14/21 07:25	08/15/21 07:38
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	24.3	mg/L		1.04	AW	08/16/21 15:33	08/16/21 15:33
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	1.5	mg/L		0.50	AW	08/13/21 13:00	08/13/21 13:00
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	5.85	mg/L	BB, SS	2.00	AS	08/06/21 14:55	08/11/21 09:40
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	08/05/21 15:59	08/06/21 13:50



**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

**SAMPLE REQUEST & CHAIN OF CUSTODY**

PAGE 1 OF 1

Page 3 of 4

<b>HEADQUARTERS</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<input checked="" type="checkbox"/>	<b>SOUTHERN DIVISION</b> 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	 1080612	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpsville, PA 16150 (724) 463-TEST FAX: (724) 465-4209	<input type="checkbox"/>
--	-------------------------------------	--	---	--	--------------------------

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite		Grab					
		Date on/off	Time on/off	Date	Time				
Effluent Outfall 001	1080612	/	/	8/5/21	10:45 AM	WW	1	Poly 1000mL None	CBOD, TSS
		/	/			WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
		/	/			WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT THIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

**Project Notes:**  
Wastewater

X Jeffrey Rosellini 8/5/21 10:45am <small>Sampled By: (Signature) Date/ Time</small>	[Signature] 8-5-21 1:30 <small>Received By: (Signature) Date/ Time</small>
X Jeffrey Rosellini 8/5/21 10:45am <small>Relinquished By: (Signature) Date/ Time</small>	[Signature] 8/5/21 1:30 <small>Received By: (Signature) Date/ Time</small>
[Signature] 8/5/21 1:30 <small>Relinquished By: (Signature) Date/ Time</small>	[Signature] 8/5/21 1:30 <small>Received By: (Signature) Date/ Time</small>
[Signature] 8/5/21 1:30 <small>Relinquished By: (Signature) Date/ Time</small>	[Signature] 8/5/21 1:30 <small>Received By: (Signature) Date/ Time</small>

**Company/Name:** MONITEAU SCHOOL DISTRICT

---

**Contact Person:** JEFFREY CAMPBELL

**Address:** 1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061

**Phone / Cell:** 724-406-4426

**Email:** [jcampbell@moniteau.org](mailto:jcampbell@moniteau.org)

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_

Jeffrey Rosellini 8/5/21



# SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monterey</u>	Work Order <div style="text-align: center;">                   1080612             </div>
-------------------------	--

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	Received on Ice? YES <input type="checkbox"/> NO <input type="checkbox"/>
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: Fecal <input type="checkbox"/> TC/EC <input type="checkbox"/> TC MPN <input type="checkbox"/> EC MPN <input type="checkbox"/> TC/EC MPN <input checked="" type="checkbox"/> <u>N/A</u>	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JIMINSKY</u>	Samples Received on Ice? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Date/Time Received: <u>8/5/17 15:15</u>	Date Sampled: <u>8/5/17</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input type="checkbox"/> <del>ESL courier</del> <input type="checkbox"/> Other: _____	
Sample Receipt Temperature: <u>3.4</u> °C	IR Gun ID: <u>44</u>
Sample State of Collection: <input checked="" type="checkbox"/> PA <input type="checkbox"/> NY <input type="checkbox"/> OH <input type="checkbox"/> WV <input type="checkbox"/> Other: _____	PWSID Compliance Drinking Water Samples: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

## PART C: Receipt Details Completed (if different from above): \_\_\_\_\_ / / \_\_\_\_\_

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES	NO	Comments:
COC form is properly signed in relinquished/received sections?	YES	NO	Comments:
Sample containers intact and sealed?	YES	NO	Circle Applicable: Damaged Container <input type="checkbox"/> Leaking Container <input type="checkbox"/> Custody Seal Broken <input type="checkbox"/> Other: _____
Number of containers received matches number indicated on COC?	YES	NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES	NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES	NO	Sample IDs and Containers Affected:
Samples received within holding time?	YES	NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES	NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES	NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES	NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	NO <input checked="" type="checkbox"/>	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

Effective Date: \_\_\_\_\_



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

10 September 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1082117**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	1082117-01	Waste Water	08/19/2021 11:30	8/19/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
 Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/10/2021 08:59

**Lab Sample ID#:** 1082117-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Jeffrey Campbell  
**Client Sample ID:** Effluent Grab

**Sample Date:** 08/19/2021 11:30  
**Receipt Date:** 08/19/2021 15:00


Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	<1.66	mg/L		1.66	DAA	08/30/21 11:20	08/31/21 08:30
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	5	mg/L		5	LMB	08/25/21 10:54	08/25/21 11:20
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NH3 D-11</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	08/22/21 08:30	08/22/21 16:54
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	<1.04	mg/L		1.04	AW	08/30/21 11:20	08/31/21 08:30
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	0.43	mg/L		0.10	AW	09/09/21 16:15	09/09/21 16:15
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, SS	2.00	AS	08/20/21 14:50	08/25/21 09:50
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<5	MPN/100 mL		5	DAA	08/19/21 15:05	08/20/21 10:56

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Page 3 of 4

<b>HEADQUARTERS</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<input checked="" type="checkbox"/>	<b>SOUTHERN DIVI</b> 1276 Bentleyville f Van Voorhis, PA 1 (724) 258-TEST FAX: (724) 258-8.	 1082117	<input type="checkbox"/>	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpsville, PA 16150 (724) 463-TEST FAX: (724) 465-4209	<input type="checkbox"/>
FOR INTERNAL LABORATORY USE ONLY						

Sample Identification	ESL#	Sample Type				Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Composite		Grab					
		Date on/off	Time on/off	Date	Time				
Effluent Outfall 001	082117 <i>Q1</i>	<del> </del>	<del> </del>	<i>8/19/21</i>	<i>11:30 AM</i>	WW	1	Poly 1000mL None	CBOD, TSS
		<del> </del>	<del> </del>			WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
		<del> </del>	<del> </del>			WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) <i>[Signature]</i> Date/ Time <i>8/19/21 11:30 AM</i>	
Relinquished By: (Signature) <i>[Signature]</i> Date/ Time <i>8/19/21 11:31</i>	Received By: (Signature) <i>[Signature]</i> Date/ Time <i>8/19/21 11:31</i>
Relinquished By: (Signature) <i>[Signature]</i> Date/ Time <i>8-19-21 1430</i>	Received By: (Signature) <i>[Signature]</i> Date/ Time <i>8/19/21 15:00 (KRS382)</i>
Relinquished By: (Signature) _____ Date/ Time _____	Received By: (Signature) _____ Date/ Time _____

**Project Notes:**

Wastewater

**Company/Name:** MONITEAU SCHOOL DISTRICT

---

**Contact Person:** JEFFREY CAMPBELL

**Address:** 1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061

**Phone / Cell:** 724-406-4426

**Email:** [jcampbell@moniteau.org](mailto:jcampbell@moniteau.org)

Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature _____
----------------------------------	-------------------------------	---------------------------





# SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monstean</u>	Work Order:  1082117
-------------------------	----------------------

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: <u>  /  /  </u>
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	Received on Ice? YES <input type="checkbox"/> NO <input type="checkbox"/>
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>SP4KNS8</u>	Samples Received on Ice? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Date/Time Received: <u>8/19/17 1500</u>	Date Sampled: <u>8/19/17</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input type="checkbox"/> <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.9</u> °C	IR Gun ID: <u>420</u>
Sample State of Collection: <input checked="" type="checkbox"/> PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

## PART C: Receipt Details Completed (if different from above): \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES	NO	Comments: _____
COC form is properly signed in relinquished/received sections?	YES	NO	Comments: _____
Sample containers intact and sealed?	YES	NO	Circle Applicable: Damaged Container _____ Leaking Container _____ Custody Seal Broken _____ Other: _____
Number of containers received matches number indicated on COC?	YES	NO	Sample IDs and Containers Affected: _____
Sample IDs on COC match IDs on bottles?	YES	NO	Sample IDs and Containers Affected: _____
Date and time on COC match date and time on bottles?	YES	NO	Sample IDs and Containers Affected: _____
Samples received within holding time?	YES	NO	Sample IDs and Containers Affected: _____
Samples received at appropriate pH for analysis requested?	YES	NO	Sample IDs and Containers Affected and Observed pH: _____
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES	NO	For non-WW samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES	NO	Analyses Affected: _____
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	<input checked="" type="checkbox"/> NO	Sample IDs and Containers Affected: _____
Other Comments: _____			Deficiency Log Created: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

Effective Date: \_\_\_\_\_