

**Moniteau School District
Maintenance Department
Dassa McKinney Elementary
School**

**Monthly Water Treatment
Facility Report for February
2021**

Dassa McKinney Elementary School Water Treatment Facility											
Month	Date	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
	1	Mon	8.7	0.01	0.76	0.83	2.26	12320200	Jeff R	2:30P	400
	2	Tues	8.7	0.02	0.86	0.62	2.17	12320300	Jeff R	3:00P	100
	3	Wed	8.7	0.02	0.51	0.57	2.65	12321800	Jeff R	4:00P	1500
	4	Thurs	8.7	0.02	0.50	0.55	2.23	12321800	Jeff R	4:00P	0
	5	Fri	8.7	0.01	0.36	0.41	2.89	12323200	Jeff R	3:00P	1400
	6	Sat									
	7	Sun									
	8	Mon	8.7	0.03	0.85	0.94	2.21	12323600	Jeff R	4:30P	400
	9	Tues	8.7	0.02	0.83	0.91	2.35	12327900	Jeff R	3:30P	4300
	10	Wed	8.7	0.04	0.75	0.84	3.01	12332100	Jeff R	3:30P	4200
	11	Thurs	8.7	0.02	0.65	0.75	2.23	123332700	Jeff R	3:00P	600
	12	Fri	8.7	0.03	0.87	0.95	2.66	123337400	Jeff R	4:00P	4700
	13	Sat									
	14	Sun									
	15	Mon	8.7	0.02	0.93	0.98	1.85	12341500	Jeff R	4:00P	4100
	16	Tues	8.7	0.03	0.88	0.96	1.91	12341600	Jeff R	3:00P	100
	17	Wed	8.7	0.02	0.58	0.64	1.44	12341900	Jeff R	5:00P	300
	18	Thurs	8.7	0.01	0.52	0.60	1.57	12350000	Jeff R	4:00P	8900
	19	Fri	8.7	0.01	0.00	0.18	1.59	12350300	Jeff R	1:00P	300
	20	Sat			0.18	0.18					
	21	Sun									
	22	Mon	8.7	0.01	0.72	0.88	1.61	12354400	Jeff R	2:00P	300
	23	Tues	8.7	0.02	0.73	0.78	1.66	12354700	Jeff R	2:30P	300
	24	Wed	8.7	0.02	0.69	0.75	1.72	12358800	Jeff R	2:30P	4100
	25	Thurs	8.7	0.06	0.74	0.82	2.76	12363100	Jeff R	2:30P	4300
	26	Fri	8.7	0.03	0.83	0.97	2.25	12347900	Jeff R	2:30P	4800
	27	Sat									
	28	Sun									
	29										
	30										
	31										

* Installed new Cl2 pump
* see comments on back

Meter Reading 1/29/21 - 12319800



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1020418
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1020418-01	Drinking Water	02/04/2021 11:25	2/4/21 13:57	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/11/2021 08:14

Lab Sample ID#: 1020418-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 02/04/2021 11:25
Receipt Date: 02/04/2021 13:57

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.650	mg/L		0.200	PS	02/04/21 11:25	02/04/21 11:25
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KEL	02/04/21 14:11	02/05/21 15:42
E. Coli	Absent	per 100 mL		1	KEL	02/04/21 14:11	02/05/21 15:42

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



1020418

N DIVISION
Street
ile, PA 17754
9003
J 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN-SINK 802 ROOM 617 SINK	1020418	2421	1125	DW	49 2/4/21	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 165 mg/L

1357 KCL

Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) Date/ Time 2421 1125
Relinquished By: (Signature) Date/ Time 2421 1350

Relinquished By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

Notes/Special Instructions::

Drinking Water Dassa McKinney - Monthly

Company/Name:

Address:

Contact Person:

Phone Number:

Cell Phone:

Email Address:

Billing Address:

PWSID:

MONITEAU SCHOOL DISTRICT

391 HOOKER ROAD

WEST SUNBURY, PA 16061

JEFFREY CAMPBELL

724-406-4426

icampbell@moniteau.org

5100316

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.65	020421	802		020421	D	1125	32382	1020418-01	BROWNKA_45
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1125	32382	1020418-01	BROWNKA_46



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1021038
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	1021038-01	Drinking Water	02/11/2021 12:05	2/11/21 15:20	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/13/2021 09:13

Lab Sample ID#: 1021038-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 02/11/2021 12:05
Receipt Date: 02/11/2021 15:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.370	mg/L		0.200	SPM	02/11/21 12:05	02/11/21 12:05

ENVIRONMENTAL SERVICE LABORATORIES INC

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208



1021038

FAX: (724) 465-4208


FOR INTERNAL LABORATORY USE ONLY

HERN DIVISION
Road Street
Hershey, PA 17033
321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Hershey, PA 17033
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>801</u>	1021038	2/11/21	1205	DW	Field	Field	Free Chlorine <u>37</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) </p> <p>Date/ Time: <u>2-11-21 1205</u></p>		<p>Received By: (Signature) <u>SPM</u></p> <p>Date/ Time: <u>2/11/21 1520</u></p>		<p>Relinquished By: (Signature) <u>SPM</u></p> <p>Date/ Time: <u>2-11-21 1417</u></p>		<p>Received By: (Signature)</p> <p>Date/ Time</p>	
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Received By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Received By: (Signature)</p> <p>Date/ Time</p>	
<p>Correct Preservations Y/N/NA</p>		<p>Correct Containers Y/N/NA</p>		<p>Receipt Temperature</p>			
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>							
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD</p> <p>WEST SUNBURY, PA 16061</p> <p>JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Billing Address:</p> <p>PWSID: 5100316</p>							

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.37	021121	801		021121	D	1205	32382	1021038-01	BROWNKA_254
5100316	1013	FREE CHLORINE	301	0.65	020421	802		020421	D	1125	32382	1020418-01	BROWNKA_45
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1125	32382	1020418-01	BROWNKA_46



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

18 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Project: Drinking Water Da
Project Descri

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date
802 Room 617 Sink	1021591-01	Drinking Water	02/18/2021 11:30	2/18/21

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reporte

Lab Sample ID#: 1021591-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 0:
Receipt Date: 0:

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Tir
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep			
Chlorine, Free	0.550	mg/L		0.200	PS	02/18/21 1

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	La
5100316	1013	FREE CHLORINE	301	0.37	021121	801		021121	D	1205	32
5100316	1013	FREE CHLORINE	301	0.65	020421	802		020421	D	1125	32
5100316	1013	FREE CHLORINE	301	0.55	021821	802		021821	D	1130	32
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1125	32

ENVIRONMENTAL SERVICE LABORATORIES, INC

HEADQUARTER

1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



1021591

(P/U) 321-9003
FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY

NORTHWEST DIVISION
950 Main Street
Sharpville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type
		Grab	Time			
Distribution: <u>802</u>	<u>1021591</u>			DW	Field	Preservative
	<u>01</u>		<u>1130</u>		Field	Field

ROTATION
 Wk 1 - 801 Kitchen Sink
 Wk 2 - 802 Room 617 Sink
 Wk 3 - 803 Room 606 Sink
 Wk 4 - 804 Room 408 Sink
 Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa

Sampled By: (Signature) [Signature] Date/ Time 27021 1130
 Relinquished By: (Signature) [Signature] Date/ Time 27821 1357

Company/Name:

MONITI

Address:

391 HOO
WEST SL

Continued on p. 2



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

26 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1022124
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	1022124-01	Drinking Water	02/25/2021 10:50	2/25/21 13:36	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/26/2021 09:44

Lab Sample ID#: 1022124-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 02/25/2021 10:50
Receipt Date: 02/25/2021 13:36

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.710	mg/L		0.200	PS	02/25/21 10:50	02/25/21 10:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benlleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



1022124

FOR INTERNAL LABORATORY USE ONLY
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>604</u>	<u>1022124</u>	Date: <u>2/25/11</u>	Time: <u>1050</u>	DW	Field	Field	Free Chlorine <u>.71</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>2/25/11 1050</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>2/25/11 1310</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>			
<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>2/25/11 1336 (RUSD)</u></p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: _____ Phone Number: 724-406-4426 Cell Phone: jcampbell@moniteau.org Billing Address: _____ PWSID: 5100316</p>			
Correct Preservations Y / N (NA)		Correct Containers Y / N (NA)		Receipt Temperature _____			

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.37	021121	801		021121	D	1205	32382	1021038-01	BROWNKA_254
5100316	1013	FREE CHLORINE	301	0.65	020421	802		020421	D	1125	32382	1020418-01	BROWNKA_45
5100316	1013	FREE CHLORINE	301	0.55	021821	802		021821	D	1130	32382	1021591-01	BROWNKA_841
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1125	32382	1020418-01	BROWNKA_46
5100316	1013	FREE CHLORINE	301	0.71	022521	804		022521	D	1050	32382	1022124-01	BROWNKA_1140

**Moniteau School District
Maintenance Department
Moniteau High School
Monthly Water Treatment
Facility Report for February
2021**

MONITEAU HIGH SCHOOL WATER TREATMENT PLANT													
MONTH	FEB	2021	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	Mon		44.0	8.06	4,236,277	0.85	0.91	7.1	0.01	0	1.17	Jeff C	9:00 AM
2	Tues		47.0	8.97	4,241,574	0.66	0.76	7.3	0.01	0	0.98	Jeff C	2:30 PM
3	Wed		47.9	7.26	4,242,812	0.70	0.82	7.3	0.00	0	0.99	Jeff C	1:00 PM
4	Thur		48.0	7.00	4,242,812	0.68	0.78	7.3	0.01	0	0.97	Jeff C	1:00 PM
5	FRI		48.0	7.41	4,252,581	0.63	0.76	7.4	0.03	0	0.91	Jeff C	9:00 AM
6	SAT												
7	SUN												
8	Mon		43.2	7.84	4,263,041	0.62	0.68	7.4	0.01	0	0.90	Jeff C	10:00 AM
9	Tues		45.7	8.59	4,268,176	0.62	0.69	7.4	0.01	0	0.89	Jeff C	1:00 PM
10	Wed		43.2	8.16	4,268,176	0.60	0.71	7.5	0.02	0	1.28	Jeff C	8:00 AM
11	Thur		46.8	8.12	4,271,831	0.62	0.71	7.5	0.02	0	1.75	Jeff C	8:00 AM
12	FRI		46.1	7.29	4,278,621	0.51	0.61	7.4	0.00	0	0.76	Jeff C	1:00 PM
13	SAT												
14	SUN												
15	Mon		43.2	8.37	4,283,286	0.52	0.62	7.4	0.00	0	0.78	Jeff C	8:00 AM
16	Tues		42.6	7.89	4,283,286	0.52	0.61	7.4	0.00	0	0.77	Jeff C	3:00 PM
17	Wed		47.0	7.75	4,290,014	0.47	0.57	7.4	0.00	0	0.75	Jeff C	4:00 PM
18	Thur		45.2	7.55	4,292,909	0.49	0.58	7.5	0.02	0	1.57	Jeff C	11:00 AM
19	FRI		45.0	6.96	4,292,909	0.50	0.58	7.5	0.01	0	0.59	Jeff C	3:00 PM
20	SAT												
21	SUN												
22	Mon		49.0	8.89	4,306,725	0.52	0.62	7.4	0.03	0	0.77	Jeff C	1:00 PM
23	Tues		47.3	7.95	4,306,725	0.52	0.62	7.4	0.02	0	0.77	Jeff C	5:00 AM
24	Wed		46.1	7.32	4,306,725	0.52	0.63	7.4	0.02	0	0.79	Jeff C	8:00 AM
25	Thur		50.3	8.51	4,313,108	0.83	0.84	7.4	0.00	0	0.85	Jeff C	8:00 AM
26	FRI		54.4	8.18	4,320,767	0.79	1.09	7.5	0.02	0	0.84	Jeff C	2:30 PM
27	SAT												
28	SUN												
29													
30													
31													

 WATER TEST'S DUE
  SEWAGE TEST'S DUE



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1020415
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	1020415-01	Drinking Water	02/04/2021 11:45	2/4/21 13:57	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/11/2021 08:14

Lab Sample ID#: 1020415-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 02/04/2021 11:45
Receipt Date: 02/04/2021 13:57

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.870	mg/L		0.200	PS	02/04/21 11:45	02/04/21 11:45
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KEL	02/04/21 14:11	02/05/21 15:42
E. Coli	Absent	per 100 mL		1	KEL	02/04/21 14:11	02/05/21 15:42

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208

SOUTHERN
1276 Bentley
Van Voorhis,
(724) 258-TE
FAX: (724) 258-4208



1020415

ION
7754

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification

ESL#

1020415

CIRCLE ONE:
704 KITCHEN-MAIN SINK
882 ROOM 204 SINK

01

Sample Type

Grab

Time

Date

2-4-21

1145

Matrix

DW

of Bottles

3.5
14
1.0

Container Type

Preservative

STERILE PLASTIC
NA THIO

Analysis Requested

TC / EC
Free Chlorine .87

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)

Date/ Time

2-4-21 1145

Relinquished By: (Signature)

Date/ Time

2-4-21 1350

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Correct Preservations Y / N / NA

Correct Containers Y / N / NA

Receipt Temperature

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Monthly

Company/Name:

MONITEAU SCHOOL DISTRICT

Address:

1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

Contact Person:

JEFFREY CAMPBELL

Phone Number:

724-406-4426

Cell Phone:

jcampbell@moniteau.org

Email Address:

jcampbell@moniteau.org

Billing Address:

JEFFREY CAMPBELL

PWSID:

5100324

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.87	020421	802		020421	D	1145	32382	1020415-01	BROWNKA_49
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1145	32382	1020415-01	BROWNKA_50



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15386
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

13 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1021039
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	1021039-01	Drinking Water	02/11/2021 12:20	2/11/21 15:20	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/13/2021 09:12

Lab Sample ID#: 1021039-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 02/11/2021 12:20
Receipt Date: 02/11/2021 15:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.550	mg/L		0.200	PS	02/11/21 12:20	02/11/21 12:20

ENVIRONMENTAL SERVICE LABORATORY

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4208

SO 12: Va (72)
FAX: (724) 258-8376



1021039

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

NORTHWEST DIVISION
950 Main Street
Sharpshville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: 704	1021039	2/11/21	1200	DW	Field	Field	Free Chlorine 1.55 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 2-11-21 1200

Relinquished By: (Signature) *[Signature]* Date/ Time 2-11-21 1417

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) *[Signature]* Date/ Time 2/11/21 1520

Received By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: jcampbell@moniteau.org

Billing Address: 5100324

PWSID: 5100324

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.55	021121	704		021121	D	1220	32382	1021039-01	BROWNKA_255
5100324	1013	FREE CHLORINE	301	0.87	020421	802		020421	D	1145	32382	1020415-01	BROWNKA_49
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1145	32382	1020415-01	BROWNKA_50



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

18 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Project: Drinking Water M
Project Descri

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date
803 Admin Sink	1021592-01	Drinking Water	02/18/2021 11:50	2/18/21

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reporte

Lab Sample ID#: 1021592-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 0:
Receipt Date: 0:

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Tir
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep	
Chlorine, Free	0.520	mg/L		0.200	PS	02/18/21 1

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	La
5100324	1013	FREE CHLORINE	301	0.55	021121	704		021121	D	1220	32
5100324	1013	FREE CHLORINE	301	0.87	020421	802		020421	D	1145	32
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1145	32
5100324	1013	FREE CHLORINE	301	0.52	021821	803		021821	D	1150	32

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



1021592

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

DE 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type
		Date	Time			
Distribution: <u>803</u>	<u>1021592</u>	<u>2/28/1</u>	<u>11:50</u>	DW	Field	Field

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Monit

Sampled By: (Signature) [Signature] Date/ Time 2/28/1 13:57

Company Name: MONITI
Address: 391 HOO WEST ST

OX 2/28/21 14:07



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

26 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1022125
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	1022125-01	Drinking Water	02/25/2021 11:10	2/25/21 13:37	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 02/26/2021 09:44

Lab Sample ID#: 1022125-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 02/25/2021 11:10
Receipt Date: 02/25/2021 13:37

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.980	mg/L		0.200	PS	02/25/21 11:10	02/25/21 11:10

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NO 43:
Montour
(570) 321-9003
FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY

CHAIN OF CUSTODY

3E 1 OF 1

DIVISION
16

1022125

FAX: (724) 465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>804</u>	<u>1022125</u>	<u>20521</u>	<u>1110</u>	DW	Field	Field	Free Chlorine <u>.98</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p>				<p>Notes/Special Instructions:</p> <p>Drinking Water Moniteau Jr/Sr - Weekly</p>			
<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>0111 18:58</u> <u>1110</u></p>		<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>20521 15:30</u></p>		<p>Company/Name: MONITEAU SCHOOL DISTRICT</p>		<p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p>	
<p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time</p>		<p>Received By: (Signature) <u>[Signature]</u> Date/ Time</p>		<p>Phone Number: 724-406-4426</p>		<p>Cell Phone: jcampbell@moniteau.org</p>	
<p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time</p>		<p>Received By: (Signature) <u>[Signature]</u> Date/ Time</p>		<p>Billing Address: 5100324</p>		<p>PWSID: 5100324</p>	
<p>Correct Preservations Y/N (NA)</p>		<p>Correct Containers Y/N (NA)</p>		<p>Receipt Temperature</p>			



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL
 SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.55	021121	704		021121	D	1220	32382	1021039-01	BROWNKA_255
5100324	1013	FREE CHLORINE	301	0.87	020421	802		020421	D	1145	32382	1020415-01	BROWNKA_49
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	020521	802		020421	D	1145	32382	1020415-01	BROWNKA_50
5100324	1013	FREE CHLORINE	301	0.52	021821	803		021821	D	1150	32382	1021592-01	BROWNKA_842
5100324	1013	FREE CHLORINE	301	0.98	022521	804		022521	D	1110	32382	1022125-01	BROWNKA_1141

**Moniteau School District
Maintenance Department
Moniteau High School
Monthly WasteWater
Treatment Facility Report for
February 2021**

School Closed

Moniteau High School Sewage Treatment Plant Permit # PA0091341				Daily Operations Worksheet			
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Operator
FEB 1	Mon	7.63	12.12	6.80	12.29	FEB 2021	Jeff C
2	Tues	7.65	12.10	6.85	12.12		4,236,277
3	wed	8.12	12.96	6.93	8.01		Jeff C
4	Thurs	7.63	11.30	6.80	8.61		Jeff C
5	Fri	7.72	11.28	6.91	8.70		Jeff C
FEB 8	Mon	7.75	11.10	7.05	9.80		Jeff C
9	Tues	7.79	11.09	7.10	9.82		Jeff C
10	Ned	6.23	5.21	7.71	12.48		Jeff C
11	Thurs	6.30	6.37	7.75	11.92		Jeff C
12	Fri	AERATION		7.76	11.86		Jeff C
FEB 15	Mon	7.63	12.15	7.07	10.29		Jeff C
16	Tues	7.65	12.01	7.17	10.02		Jeff C
17	Ned	7.67	11.27	7.27	9.71		Jeff C
18	Thurs	7.74	11.71	7.34	9.65		Jeff C
19	Fri	7.57	12.11	6.06	5.070		Jeff C
FEB 22	Mon	7.89	12.87	7.07	7.57		Jeff C
23	Tues	7.62	12.02	7.08	7.59		Jeff C
24	Ned	7.57	11.29	7.06	7.62		Jeff C
25	Thurs	7.81	12.12	6.21	9.19		Jeff C
26	Fri	7.79	12.02	6.32	8.10		Jeff C
						4,320,767	Jeff C
						96	

TEST DAY *

TEST DAY *



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 STAGE: Final Effluent

PA0081341	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 02/01/2021
 DMR Effective To: 02/28/2021
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2021	02	01	2021	02	28

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	5.07	...	1/week	Grab
	PERMIT REQUIREMENT	4.0 Min	...	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	6.21	...	1/week	Grab
	PERMIT REQUIREMENT	6.0 Min	8.12 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	<5.0	2/month	Grab
	PERMIT REQUIREMENT	30 Avg Mo	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	1.23	2/month	Grab
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT18	2/month	Grab
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	4.8	1/week	Grab
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.002725	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	MGD	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		***	<1.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	2000 Geo Mean	10000 IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		***	4.77	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		***	25 Avg Mo	***		2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------

Moniteau High School
WASTE WATER TREATMENT FACILITY
Monthly Work Sheet for Feb 2021

Flow $84,490 \div 31 = 2,725.48$ GPD Avg.

UV Light $96 \div 20 = 4.8$ Daily Avg.

PH High 8.12 #1 Basin 2/3/21

Low 6.21 #2 Basin 2/25/21

D.O. High 12.96 #1 Basin 2/3/21

Low 5.07 #2 Basin 2/19/21

Total Nitrogen - $1.01 + 1.46 = 2.47 \div 2 = 1.235$ Avg.

TSS - $< 5 + < 5 = < 5$ Avg.

Nitrate/Nitrite - $1.01 + 1.46 = 2.47 \div 2 = 1.235$ Avg.

Phosphorus - $0.15 + 0.21 = 0.36 \div 2 = 0.18$ Avg.

C BOD - $4.93 + 4.61 = 9.54 \div 2 = 4.77$ Avg.

Fecal Coliforms - $< 1 + < 1 = < 1$ Avg.

New eDMR Report Available For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us (depgreenporthelpdesk@state.pa.us)

To: mcafoose92@hotmail.com; monwarrior2003@yahoo.com

Date: Tuesday, March 2, 2021, 09:23 AM EST

A new eDMR report is available for your facility:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Type: DMR

Report Frequency: Monthly

Reporting Period: 03/01/2021 - 03/31/2021

Report Due Date: 04/28/2021

To begin working on this report, access the eDMR system through DEP's Greenport. If you have any technical questions, please contact 717-787-HELP.

Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Thursday, March 4, 2021, 09:05 AM EST

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 02/01/2021-02/28/2021

Report Due Date: 03/28/2021

Submitted By: Jeffrey Campbell

Submission Id: 255017

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

17 February 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1020410
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1020410-01	Waste Water	02/04/2021 11:00	2/4/21 14:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
RL Reporting Limit
CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 02/17/2021 17:05

Lab Sample ID#: 1020410-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 02/04/2021 11:00
Receipt Date: 02/04/2021 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	1.01	mg/L		0.104	DAA	02/09/21 15:31	02/10/21 13:14
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	02/10/21 11:59	02/10/21 13:00
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	1.01	mg/L		0.104	DAA	02/09/21 15:31	02/10/21 13:14
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.15	mg/L		0.10	JPD	02/15/21 11:28	02/16/21 09:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	4.93	mg/L	BB	3.00	AW	02/05/21 13:00	02/10/21 08:00
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	02/04/21 14:53	02/05/21 12:32



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information

Client: <u>Montevideo</u>		Work Order: <u>1020410</u>	
Received by: <u>Jo</u>		Date/Time Received: <u>2/4/21 11:00</u>	Date Sampled: <u>2/4/21</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>1.9</u>		Samples Received on Ice: <input checked="" type="checkbox"/> YES NO	
IR Gun # Used: 1 2 3 <u>4</u>		Containers removed by Satellite Lab for analysis of: TCMPN Fecal Coliform TC/EC ECMPN	
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)		PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <input checked="" type="checkbox"/> NO	
Sample State of Collection: <input checked="" type="checkbox"/> PA NY OH WV Other: _____			

PART B: Receipt Details

Completed (if different from above): _____ / ____ / ____
Signature
Date
Time

Sample Receipt Criteria				Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1 Chain of custody documents included with samples?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Comments:	YES <input checked="" type="checkbox"/> NO
2 COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Comments:	YES <input checked="" type="checkbox"/> NO
3 Sample containers intact and sealed?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES <input checked="" type="checkbox"/> NO
4 Number of containers received match number indicated on COC?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Sample ID's affected:	YES <input checked="" type="checkbox"/> NO
5 Sample ID's on COC match ID's on bottles?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Sample ID's and containers affected:	YES <input checked="" type="checkbox"/> NO
6 Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Sample ID's affected:	YES <input checked="" type="checkbox"/> NO
7 Samples received within holding time?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	ID's and tests affected:	YES <input checked="" type="checkbox"/> NO
8 Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Sample ID's, containers affected and observed pH:	YES <input checked="" type="checkbox"/> NO
9 Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES <input checked="" type="checkbox"/> NO
11 Adequate sample volume received?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	N/A	Analyses Affected:	YES <input checked="" type="checkbox"/> NO
10 VOA vials free of headspace (defined as < 6mm bubble)?	<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	<input checked="" type="checkbox"/> N/A	Sample ID's and containers affected:	YES <input checked="" type="checkbox"/> NO
Other Comments:					Deficiency Log Created: Yes <input checked="" type="checkbox"/> No



Results Report

Order ID: 1B01935

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 1B01935-01	Site: 1020410-01	Sample ID: 1020410
Collector: Client	Collect Date: 02/04/2021 11:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
<u>Inorganics</u>									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	02/09/21	CJ	02/12/21 11:35	ZJH

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 02/12/2021 4:20 pm 1B01935
STL_Results Revision #1.9 Effective: 04/16/2020



SUBCONTRACT C
Environmental Service Lab
1020410



1B01935
 Lisa F. Care

Please report all results to reports@envlabs.co

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
 1803 Philadelphia Street
 Indiana, PA 15701
 Phone: 724-463-8378
 Fax: 724-465-4209
 Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
 1037F MacArthur Road
 Reading, PA 19605
 Phone : (610) 375-8378
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 1020410-01			
Matrix: Water	Sampled: 02/04/2021 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	02/16/2021 23:00	03/04/2021 11:00	
<i>Containers Supplied:</i>			
Poly 250mL, H2SO4 (D)			

(1) 250 mL P H₂SO₄
 PHCZ 7-P 2-5-21

Suburban Testing Labs

Lab Date/Time: 2-5-21 12:15 Lab Temp: 0.7
 Number of containers/coolers match number on COC? Y/N
 Sample labels and COC are free of discrepancies? Y/N
 All containers in tact? Y/N
 Received in lab within acceptable temperature limits? Y/N
 40mL VOA vials free of headspace? Y/N
 Relinquished by: Delivery
 Received in Lab by: CMV 2-8-21 1320

Released By: GA Date: 2/5/21 Received By: _____ Date: _____

Released By: _____ Date: _____ Received By: _____ Date: _____





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

02 March 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1021606
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	1021606-01	Waste Water	02/18/2021 11:00	2/18/21 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/02/2021 15:16

Lab Sample ID#: 1021606-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 02/18/2021 11:00
Receipt Date: 02/18/2021 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	1.46	mg/L		0.104	DAA	02/25/21 14:43	03/02/21 09:32
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	02/24/21 14:18	02/24/21 14:45
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	1.46	mg/L		0.104	DAA	02/25/21 14:43	03/02/21 09:32
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.21	mg/L		0.10	JPD	02/24/21 12:25	02/24/21 13:20
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	4.61	mg/L	BB, SS	2.00	AW	02/19/21 12:10	02/24/21 09:20
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	KEL	02/18/21 15:45	02/19/21 13:08



Results Report

Order ID: 1B03643

Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701	Project: TKN Testing
Attn: Accounts Payable	Regulatory ID:

Sample Number: 1B03643-01	Site: 1021606-01	Sample ID: 1021606
Collector: Client	Collect Date: 02/18/2021 11:00 am	Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
-------------------------------	--------	-------	--------	------	----	-----------	----	---------------	----

<u>Inorganics</u>									
Total Kjeldahl Nitrogen (TKN)	< 0.50	mg/L	EPA 351.2	0.50	1	02/23/21	ZJH	02/24/21 10:57	ZJH

Sample Receipt Conditions:
All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 02/24/2021 3:25 pm 1B03643
STL_Results Revision #1.9 Effective: 04/16/2020



SUBCONTRACT O
Environmental Service Lab
1021606



1B03643
 Lisa F. Care

Please report all results to reports@envlabs.com

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
 1803 Philadelphia Street
 Indiana, PA 15701
 Phone: 724-463-8378
 Fax: 724-465-4209
 Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
 1037F MacArthur Road
 Reading, PA 19605
 Phone: (610) 375-8378
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 1021606-01 Matrix: Water Total Kjeldahl Nitrogen Containers Supplied: Poly 250mL, H2SO4 (D) PHC2 ANB	Sampled: 02/18/2021 11:00	Sample Type: Grab 03/02/2021 23:00 03/18/2021 11:00	Sampled By: Client

Suburban Testing Labs

Lab Date/Time: 2-19-21 1455 Lab Temp: 20°C
 Number of containers/coolers match number on COC? Y N
 Sample labels and COC are free of discrepancies? Y N
 All containers in tact? Y N
 Received in lab within acceptable temperature limits? Y N
 40mL VOA vials free of headspace? Y N
 Relinquished by: [Signature]
 Received in Lab by: [Signature] ①

Released By: [Signature] Date: 2/19/21
 Received By: [Signature] Date: 2/19/21
 Released By: [Signature] Date: 2/19/21
 Received By: [Signature] Date: 2-19-21

