

**Moniteau School District
Dassa McKinney Elementary
School**

**Monthly Water Treatment
Facility Operations Report for
October 2021**

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
Oct	2021									
1	Fri	8.7	0.00	0.75	0.85	3.12	12817300	Jeff R	3:30P	4500
2	Sat									
3	Sun									
4	Mon	8.7	0.00	0.73	0.82	2.45	12821600	Jeff R	2:30P	4300
5	Tues	8.7	0.01	0.75	0.85	2.63	12821100	Jeff R	3:30P	5500
6	Wed	8.7	0.00	0.79	0.90	2.57	12831700	Jeff R	3:00P	4600
7	Thurs		Sick Day							
8	Fri	8.7	0.01	0.65	0.72	2.82	12841100	Jeff R	3:30P	9400
9	Sat									
10	Sun									
11	Mon	8.7	0.00	0.60	0.68	3.15	12846500	Jeff R	3:30P	5400
12	Tues	8.7	0.00	0.61	0.75	1.85	12850700	Jeff R	3:30P	4200
13	Wed	8.7	0.01	0.75	0.82	1.97	12855200	Jeff R	3:00P	4500
14	Thurs	8.7	0.00	0.76	0.82	1.88	12860200	Jeff R	4:00P	5000
15	Fri									
16	Sat									
17	Sun									
18	Mon	8.7	0.00	0.98	1.01	2.32	12865500	Jeff C	5:00P	
19	Tues	7.9	0.00	0.70	0.83	2.41	12872900	Jeff C	7:00P	
20	Wed	8.0	0.00	0.71	0.83	2.42	12874400	Jeff C	10:00A	
21	Thurs	8.7	0.03	0.85	0.93	3.38	12880400	Jeff R	12:00P	6000
22	Fri	8.0	0.00	0.96	1.07	2.94	12887300	Jeff C	4:00P	
23	Sat									
24	Sun									
25	Mon	8.7	0.02	0.85	0.94	2.88	12891600	Jeff R	4:00P	4300
26	Tues	8.7	0.00	0.70	0.78	3.26	12895900	Jeff R	4:00P	4300
27	Wed	8.7	0.03	0.76	0.84	2.25	12900100	Jeff R	3:30P	4200
28	Thurs	8.7	0.02	0.80	0.88	2.45	12904100	Jeff R	2:30P	4000
29	Fri	8.7	0.02	0.81	0.88	2.42	12908400	Jeff C	3:30P	
30	Sat									
31	Sun									

Meter Reading 9/30/21 - 12812800



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1100597
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	1100597-01	Drinking Water	10/07/2021 11:30	10/7/21 14:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Client Services Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/11/2021 08:57

Lab Sample ID#: 1100597-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Vance Byram
Client Sample ID: 801 Kitchen Sink

Sample Date: 10/07/2021 11:30
Receipt Date: 10/07/2021 14:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.370	mg/L		0.200	VB	10/07/21 11:30	10/07/21 11:30

SAMPLE REQUEST & CHAIN OF CUSTODY

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	NORTHWEST DIVISION 150 Main Street Harpsville, PA 16 (724) 463-TEST FAX: (724) 465-4209
---	--	--

Sample Identification	ESL#	Matrix	# of Bottles	Container Type	Analysis Requested
	1100597	DW	Field	Preservative	Free Chlorine 0.37 mg/L
Distribution:	Date	Time			
	10/17/21	11:30			

ROTATION Wk 1 - 804 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink	Sample Type Grab Date Time
---	-------------------------------------

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:
Drinking Water Dassa McKinney - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcampbell@moniteau.org**

Cell Phone: **5100316**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Received By: (Signature) Date/ Time 10/17/21 11:15	Received By: (Signature) Date/ Time 10/17/21 11:15
Relinquished By: (Signature) Date/ Time 10/17/21 11:30	Relinquished By: (Signature) Date/ Time 10/17/21 13:55

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.37	100721	801		100721	D	1130	32382	1100597-01	BROWNKA_33



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

29 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1101246
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1101246-01	Drinking Water	10/14/2021 12:30	10/14/21 15:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Client Services Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/29/2021 09:58

Lab Sample ID#: 1101246-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Vance Byram
Client Sample ID: 802 Room 617 Sink

Sample Date: 10/14/2021 12:30
Receipt Date: 10/14/2021 15:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.820	mg/L		0.200	VB	10/14/21 12:30	10/14/21 12:30
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KD	10/14/21 15:50	10/15/21 16:28
E. Coli	Absent	per 100 mL		1	KD	10/14/21 15:50	10/15/21 16:28

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

1101246
FOR INTERNAL LABORATORY USE ONLY

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification	ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
801 KITCHEN SINK 802 ROOM 617 SINK	1101246 01	Grab Date: 10/14/21 Time: 12:30	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.82 mg/L

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Monthly

Company/Name: MONITEAU SCHOOL DISTRICT
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
724-406-4426
jcampbell@moniteau.org
Billing Address: 5100316

Received By: (Signature) *Paula Dawson* Date/ Time 10/14/21 1515 (063827)
Relinquished By: (Signature) Date/ Time
Relinquished By: (Signature) Date/ Time
Relinquished By: (Signature) Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature 5.9(2) °C

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.37	100721	801		100721	D	1130	32382	1100597-01	BROWNKA_33
5100316	1013	FREE CHLORINE	301	0.82	101421	802		101421	D	1230	32382	1101246-01	BROWNKA_624
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	101521	802		101421	D	1230	32382	1101246-01	BROWNKA_625



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

25 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1101971
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	1101971-01	Drinking Water	10/22/2021 09:55	10/22/21 16:51	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Client Services Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/25/2021 17:53

Lab Sample ID#: 1101971-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Vance Byram
Client Sample ID: 803 Room 606 Sink

Sample Date: 10/22/2021 09:55
Receipt Date: 10/22/2021 16:51

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	<0.200	mg/L		0.200	VB	10/22/21 09:55	10/22/21 09:55

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
42
M
(5)
F
1101971

WEST DIVISION
16
T
5-4209

FOR INTERNAL LABORATORY USE

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL# 1101971	Sample Type Grab	Matrix DW	# of Bottles Field	Container Type Preservative	Analysis Requested Free Chlorine 0.13 mg/L
Distribution:	02	Date 10/22/21	Time 0955	Field	Field	
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>						
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
<p>Received By: (Signature) <i>[Signature]</i></p> <p>Date/ Time 10/22/21 1010</p>		<p>Received By: (Signature) <i>[Signature]</i></p> <p>Date/ Time 10/22/21 10:51 (WJS)</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		
<p>Correct Preservations Y / N / NA</p>		<p>Correct Containers Y / N / NA</p>		<p>Receipt Temperature</p>		
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>						
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Billing Address:</p> <p>PWSID: 5100316</p>						



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.37	100721	801		100721	D	1130	32382	1100597-01	BROWNKA_33
5100316	1013	FREE CHLORINE	301	0.82	101421	802		101421	D	1230	32382	1101246-01	BROWNKA_624
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	101521	802		101421	D	1230	32382	1101246-01	BROWNKA_625
5100316	1013	FREE CHLORINE	301	0.13	102221	803		102221	D	0955	32382	1101971-01	BROWNKA_1229



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

29 October 2021

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 1102344
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	1102344-01	Drinking Water	10/28/2021 11:40	10/28/21 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
 Client Services Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/29/2021 09:33

Lab Sample ID#: 1102344-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 10/28/2021 11:40
Receipt Date: 10/28/2021 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.870	mg/L		0.200	PS	10/28/21 11:40	10/28/21 11:40

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.37	100721	801		100721	D	1130	32382	1100597-01	BROWNKA_33
5100316	1013	FREE CHLORINE	301	0.82	101421	802		101421	D	1230	32382	1101246-01	BROWNKA_624
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	101521	802		101421	D	1230	32382	1101246-01	BROWNKA_625
5100316	1013	FREE CHLORINE	301	0.13	102221	803		102221	D	0955	32382	1101971-01	BROWNKA_1229
5100316	1013	FREE CHLORINE	301	0.87	102821	804		102821	D	1140	32382	1102344-01	BROWNKA_1686

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN
1276 Ber
Van Voor
(724) 25E
FAX: (7)

VISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

<p>Sample Identification</p> <p>ESL# 1102344</p>		<p>Sample Type</p> <p>Grab</p>		<p>Matrix</p> <p>DW</p>		<p># of Bottles</p> <p>Field</p>		<p>Container Type</p> <p>Preservative</p>		<p>Analysis Requested</p> <p>Free Chlorine 07 mg/L</p>					
<p>Distribution: SA</p>		<p>Date 10/28/11</p> <p>Time 1400</p>		<p>Date/Time</p>		<p>Date/Time</p>		<p>Date/Time</p>		<p>Date/Time</p>					
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>															
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>															
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>															
<p>Sampled By: (Signature)</p> <p>Date/Time 10/28/11 1400</p>				<p>Received By: (Signature)</p> <p>Date/Time 10/28/11 1430</p>				<p>Relinquished By: (Signature)</p> <p>Date/Time</p>				<p>Relinquished By: (Signature)</p> <p>Date/Time</p>			
<p>Relinquished By: (Signature)</p> <p>Date/Time</p>				<p>Relinquished By: (Signature)</p> <p>Date/Time</p>				<p>Relinquished By: (Signature)</p> <p>Date/Time</p>				<p>Relinquished By: (Signature)</p> <p>Date/Time</p>			
<p>Correct Preservations Y/N/NA</p>				<p>Correct Containers Y/N/NA</p>				<p>Receipt Temperature</p>							
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Billing Address: 5100316</p> <p>PWSID:</p>															


Moniteau School District
Moniteau High School
Monthly Water Treatment
Facility Operations Report for
October 2021

MONITEAU HIGH SCHOOL WATER TREATMENT PLANT												
MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
OCT	FRI	64.9	9.67	5,214,059	0.56	0.64	7.3	0.02	0	2.08	JEFF C	8:00 AM
	SAT											
	SUN											
	MON	65.0	11.34	5,227,942	0.62	0.70	7.4	0.00	0	1.40	JEFF C	8:00 AM
	Tues	66.3	9.07	5,227,942	0.62	0.69	7.4	0.00	0	1.42	JEFF C	9:00 AM
	Wed	66.7	10.02	5,238,298	1.01	1.05	7.4	0.00	0	1.40	JEFF C	4:30 AM
	Thurs	65.4	10.53	5,244,270	1.21	1.22	7.2	0.02	0	1.29	JEFF C	11:15 AM
	FRI	67.1	8.43	5,244,278	1.07	1.11	7.2	0.02	0	1.33	JEFF R	11:45A
	SAT											
	SUN											
	MON	66.0	10.52	5,247,697	1.10	1.15	7.4	0.00	0	1.44	JEFF R	11:30A
	Tues	63.2	8.58	5,247,697	1.08	1.21	7.5	0.03	0	1.01	JEFF R	11:15A
	Wed	69.1	8.48	5,251,930	1.11	1.18	7.4	0.02	0	0.99	JEFF R	11:30A
	Thurs	65.2	10.60	5,264,739	1.02	1.12	7.2	0.04	0	1.25	JEFF R	11:45A
	FRI	VACATION DAY -		No	Coverage							
	SAT											
	SUN											
	MON	61.2	7.79	5,279,268	1.00	1.02	7.2	0.02	0	1.19	JEFF C	9:00 PM
	Tues	62.1	7.75	5,281,392	0.98	1.02	7.2	0.02	0	1.17	JEFF C	9:00 AM
	Wed	61.4	11.21	5,297,931	0.81	0.90	7.2	0.02	0	1.12	JEFF C	9:00 AM
	Thurs	61.3	8.47	5,297,931	0.83	0.89	7.2	0.01	0	1.83	JEFF R	11:30A
	FRI	61.9	11.54	5,315,074	0.75	0.81	6.9	0.02	0	2.39	Seth C	4:30P
	SAT											
	SUN											
	MON	59.9	8.57	5,315,074	0.71	0.79	7.1	0.01	0	2.12	JEFF C	9:00 AM
	Tues	60.1	7.75	5,318,681	0.75	0.81	7.1	0.01	0	1.98	JEFF C	2:00 AM
	Wed	59.0	11.60	5,332,795	0.67	0.76	7.1	0.02	0	1.05	JEFF C	8:00 AM
	Thurs	58.0	8.85	5,332,795	0.69	0.78	7.1	0.02	0	1.03	JEFF C	3:00 PM
	FRI	58.9	7.74	5,332,795	0.65	0.72	7.1	0.01	0	1.05	JEFF C	11:00 AM
	SAT											
	SUN											

OPERATOR
NOTE
1

WATER SAMPLES SEWAGE SAMPLES

NOTE # 1 - 10/7/31 - AFTER MIXING EL2 MIX WAS STRONGER THAN PREVIOUS.
ADJUSTED THE PUMP FROM 50/40 TO 44/40.



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1100595
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	1100595-01	Drinking Water	10/07/2021 11:55	10/7/21 14:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Client Services Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/11/2021 08:57

Lab Sample ID#: 1100595-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Vance Byram
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 10/07/2021 11:55
Receipt Date: 10/07/2021 14:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.710	mg/L		0.200	VB	10/07/21 11:55	10/07/21 11:55

RE 1 OF 1

SAMPLE REQUEST & CHAIN OF CUSTODY

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

FOR INTERNAL LABORATORY USE

ST DIVISION

reel
PA 16
EST
465-4209

1100595

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: _____	1100595	10/07/21	1155	DW	Field	Field	Free Chlorine <u>0.71</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly</p>							
<p>Received By: (Signature) <i>[Signature]</i> Date/ Time 10/07/21 1355</p> <p>Relinquished By: (Signature) <i>[Signature]</i> Date/ Time 10/07/21 1415</p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Email Address: jcampbell@moniteau.org</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>			
<p>Correct Preservations Y / N (NA)</p>				<p>Correct Containers Y / N (NA)</p>			
<p>Correct Temperature _____</p>				<p>Receipt Temperature _____</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.71	100721	704		100721	D	1155	32382	1100595-01	BROWNKA_34



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

29 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1101249
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	1101249-01	Drinking Water	10/14/2021 12:50	10/14/21 15:15	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Client Services Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/29/2021 09:58

Lab Sample ID#: 1101249-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Vance Byram
Client Sample ID: 802 Room 204 Sink

Sample Date: 10/14/2021 12:50
Receipt Date: 10/14/2021 15:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.220	mg/L		0.200	VB	10/14/21 12:50	10/14/21 12:50
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	KD	10/14/21 15:50	10/15/21 16:28
E. Coli	Absent	per 100 mL		1	KD	10/14/21 15:50	10/15/21 16:28

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

**ENVIRONMENTAL SERVICE
LABORATORIES, INC.**

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



1101249

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	1101249 01	10/14/21	1250	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.22

704: Jan, Mar, May, Jul, Sept, Nov

802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 10/14/21 1250
Relinquished By: (Signature) *[Signature]* Date/ Time 10/14/21 14.45

Received By: (Signature) *[Signature]* Date/ Time 10/14/21 1515
Received By: (Signature) *[Signature]* Date/ Time
Received By: (Signature) *[Signature]* Date/ Time

Correct Preservations Y / N / NA
Correct Containers Y / N / NA
Receipt Temperature 7.14°C

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Monthly

Company Name: MONITEAU SCHOOL DISTRICT
Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.org
Billing Address: 5100324
PWSID: 5100324



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.71	100721	704		100721	D	1155	32382	1100595-01	BROWNKA_34
5100324	1013	FREE CHLORINE	301	0.22	101421	802		101421	D	1250	32382	1101249-01	BROWNKA_626
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	101521	802		101421	D	1250	32382	1101249-01	BROWNKA_627



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

25 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1101970
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	1101970-01	Drinking Water	10/22/2021 10:15	10/22/21 16:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Client Services Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/25/2021 17:53

Lab Sample ID#: 1101970-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Vance Byram
Client Sample ID: 803 Admin Sink


Sample Date: 10/22/2021 10:15
Receipt Date: 10/22/2021 16:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	<0.200	mg/L		0.200	VB	10/22/21 10:15	10/22/21 10:15

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



1101970

(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

OF CUSTODY

SE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: _____	1101970		10/22/11 10:15	DW	Field	Field	Free Chlorine <u>0.12</u> mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Weekly

Notes/Special Instructions::

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**

Billing Address: **5100324**

PWSID: **5100324**

Received By: (Signature) [Signature] Date/ Time 10/22/11 10:15

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations **Y / N / NA** Correct Containers **Y / N / NA** Receipt Temperature _____



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.71	100721	704		100721	D	1155	32382	1100595-01	BROWNKA_34
5100324	1013	FREE CHLORINE	301	0.22	101421	802		101421	D	1250	32382	1101249-01	BROWNKA_626
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	101521	802		101421	D	1250	32382	1101249-01	BROWNKA_627
5100324	1013	FREE CHLORINE	301	0.12	102221	803		102221	D	1015	32382	1101970-01	BROWNKA_1230



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

29 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1102339
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	1102339-01	Drinking Water	10/28/2021 12:00	10/28/21 14:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Client Services Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934


Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 10/29/2021 09:33

Lab Sample ID#: 1102339-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 10/28/2021 12:00
Receipt Date: 10/28/2021 14:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.700	mg/L		0.200	PS	10/28/21 12:00	10/28/21 12:00



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.71	100721	704		100721	D	1155	32382	1100595-01	BROWNKA_34
5100324	1013	FREE CHLORINE	301	0.22	101421	802		101421	D	1250	32382	1101249-01	BROWNKA_626
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	101521	802		101421	D	1250	32382	1101249-01	BROWNKA_627
5100324	1013	FREE CHLORINE	301	0.12	102221	803		102221	D	1015	32382	1101970-01	BROWNKA_1230
5100324	1013	FREE CHLORINE	301	0.7	102821	804		102821	D	1200	32382	1102339-01	BROWNKA_1687

ENVIRONMENTAL SERVICE LABORATORIES, INC

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIV
1276 Bentleyville
Van Voorhis, PA
(724) 258-TEST
FAX: (724) 258-8370

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E ___1___ OF ___1___

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: 804		Date: 10/28/21	Time: 12:00	DW	Field	Field	Free Chlorine 70 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

Notes/Special Instructions: **Drinking Water Moniteau Jr/Sr - Weekly**

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION-REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426
jcampbell@moniteau.org**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100324**

PWSID: **5100324**

Received By: (Signature) *[Signature]* Date/ Time: 10/28/21 14:30 (06382)

Relinquished By: (Signature) *[Signature]* Date/ Time: 10/28/21 140

Relinquished By: (Signature) Date/ Time

Relinquished By: (Signature) Date/ Time

Relinquished By: (Signature) Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature

**Moniteau School District
Moniteau High School
Monthly Waste Water
Treatment Facility Operations
Report for October 2021**



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONITEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220
 FACILITY: MONITEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA., 16061-1220
 STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 10/01/2021
 DMR Effective To: 10/31/2021
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2021	10	01	2021	10	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	5.19		5.19	***	***	1/week	Grab
	PERMIT REQUIREMENT	4.0 Min		4.0 Min	***	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	6.53		6.53	8.01	8.01	1/week	Grab
	PERMIT REQUIREMENT	6.0 Min		6.0 Min	9.0 Max	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	<5.0		<5.0	***	***	2/month	Grab
	PERMIT REQUIREMENT	30 Avg Mo		30 Avg Mo	***	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	18.56		18.56	***	***	2/month	Grab
	PERMIT REQUIREMENT	Monitor & Report Avg Mo		Monitor & Report Avg Mo	***	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	1.47		1.47	***	***	2/month	Grab
	PERMIT REQUIREMENT	Monitor & Report Avg Mo		Monitor & Report Avg Mo	***	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	5.25		5.25	***	***	1/week	Grab
	PERMIT REQUIREMENT	Monitor & Report Avg Mo		Monitor & Report Avg Mo	***	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.00383		.00383	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	MGD	Monitor & Report Avg Mo	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	...		<1.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	...		2000	10000		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	...		Geo Mean	IMAX		2/month	Grab
	PERMIT REQUIREMENT	...		<2.00	...		2/month	Grab
Facility Comments	...		25	Avg Mo	...		2/month	Grab

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Tue, Nov 16, 2021 at 11:31 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 10/01/2021-10/31/2021
Report Due Date: 11/28/2021

Submitted By: Jeffrey Campbell
Submission Id: 295472
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

PH Low	6.53 #1 TANK 10/18
High	8.01 #2 TANK 10/12
D.O. Low	5.19 #2 TANK 10/12
UV Light	104.9 TOTAL \div 20 DAYS = 5.245 DAILY Avg.
TOTAL NIT.	$< 0.729 + 36.4 = 37.129 \div 2 = 18.56$ Avg.
TSS	$< 5 + < 5 = < 5$ Avg.
TOTAL-K-NIT.	$< 0.625 + < 0.625 = < 0.625$ Avg.
NITRATE/Nitrite	$0.516 + 36.4 = 36.916 \div 2 = 18.458$ Avg.
PHOS.	$0.13 + 2.8 = 2.93 \div 2 = 1.465$ Avg.
CBOD	$< 2.00 + < 2.00 = < 2.00$ Avg.
Fecal	$< 1 + < 1 = < 1$ Avg.

Moniteau High School Sewage Treatment Plant Permit # PA0091341				Daily Operations Worksheet			
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Operator
10/11	Fri	7.40	9.01	7.71	9.19	Oct 2021	Jeff C
10/14	Mon	7.21	9.03	7.95	9.70	Meter Reading	Jeff C
10/15	Tues	7.23	9.05	7.97	9.73	5,214,059	Jeff C
10/16	Wed	7.25	9.15	8.00	9.75		Jeff C
10/17	Thurs	6.99	8.64	7.84	8.92		Jeff C
10/18	Fri	7.22	9.20	7.67	9.15		Jeff C
10/19	Mon	7.00	8.00	7.12	8.65		Jeff R.
10/20	Tues	6.86	7.74	8.01	8.19		Jeff R.
10/21	Wed	6.75	6.90	7.96	5.22		Jeff R.
10/22	Thurs	7.22	8.34	7.95	8.42		Jeff R.
10/23	Fri	VACATION	VACATION	- NO	REPORT		Jeff R.
10/24	Mon	6.53	6.17	7.95	9.02		Jeff C
10/25	Tues	AERATION	AERATION	7.70	9.60		Jeff C
10/26	Wed	6.80	8.19	7.57	9.59		Jeff C
10/27	Thurs	6.64	7.81	7.82	6.78		Jeff R.
10/28	Fri	6.91	7.34	Aeration			Seth C
10/29	Mon	6.99	8.52	8.01	6.19		Jeff R.
10/30	Tues	6.74	7.59	7.84	6.21		Jeff C
10/31	Wed	6.68	7.42	7.82	6.28		Jeff C
10/32	Thurs	6.65	7.40	7.80	6.28		Jeff C
10/33	Fri	6.63	5.84	7.75	7.45		Jeff C
						5,332,795	
						104.9	
						7.20	
						118,736	
						5.245	
						3,830	
						DAILY Avg.	

TEST DAY

TEST DAY



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

03 November 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1101849
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	1101849-01	Waste Water	10/21/2021 11:00	10/21/21 15:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units


Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Client Services Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 11/03/2021 07:26

Lab Sample ID#: 1101849-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Grab

Sample Date: 10/21/2021 11:00
Receipt Date: 10/21/2021 15:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	36.4	mg/L		1.66	DAA	10/30/21 08:35	11/01/21 17:38
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	10/27/21 09:06	10/27/21 12:35
General Chemistry	Analytical Method: SM4500 NH3 F-11				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	10/30/21 08:35	11/01/21 17:38
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	36.4	mg/L		1.04	AW	10/29/21 16:49	10/29/21 16:49
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	2.8	mg/L		0.50	AW	11/01/21 12:55	11/01/21 12:55
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G	2.00	JAW	10/22/21 17:30	10/27/21 11:30
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	VSJ	10/21/21 15:35	10/22/21 10:09



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monteau</u>	Work Ord 1101849
------------------------	-------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>30 100382</u>	Samples Received on Ice? <input checked="" type="radio"/> YES <input type="radio"/> NO
Date/Time Received: <u>10/21/21 15:10</u>	Date Sampled: <u>10/21/21</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.8</u> °C	IR Gun ID: <u>4</u>
Sample State of Collection: <input checked="" type="radio"/> PA <input type="radio"/> NY <input type="radio"/> OH <input type="radio"/> WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input checked="" type="radio"/> NO

PART C: Receipt Details Completed (if different from above): _____ / / _____

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES NO			Comments:
COC form is properly signed in relinquished/received sections?	YES NO			Comments:
Sample containers intact and sealed?	YES NO			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	YES NO			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES NO			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES NO			Sample IDs and Containers Affected:
Samples received within holding time?	YES NO			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES NO			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES NO			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES NO			Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES NO			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: <input type="radio"/> YES <input checked="" type="radio"/> NO

Effective Date: _____



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 October 2021

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 1100535
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	1100535-01	Waste Water	10/07/2021 11:00	10/7/21 14:20	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

SS Seed Control did not meet reference method acceptance criteria.
 G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
 RL Reporting Limit
 CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Client Services Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 10/19/2021 15:52

Lab Sample ID#: 1100535-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Grab

Sample Date: 10/07/2021 11:00
Receipt Date: 10/07/2021 14:20

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	<0.729	mg/L		0.729	DAA	10/18/21 14:31	10/18/21 14:31
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	10/12/21 10:05	10/12/21 11:45
General Chemistry	Analytical Method: SM4500 NH3 F-11				Prep Method: SM 4500-Norg B		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	10/16/21 07:45	10/16/21 14:34
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	0.516	mg/L		0.104	AW	10/18/21 14:31	10/18/21 14:31
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	0.13	mg/L		0.10	AW	10/13/21 13:40	10/13/21 13:40
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	G, SS	2.00	AS	10/08/21 14:15	10/13/21 09:25
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	VSJ	10/07/21 14:22	10/08/21 10:38



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work Or 1100535
-------------------------	------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>(N/A)</u>	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>Jim Lovis</u>	Samples Received on Ice? <u>(YES)</u> NO
Date/Time Received: <u>10/7/17 14:20</u>	Date Sampled: <u>10/7/17</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL-courier</u> Other: _____	
Sample Receipt Temperature: <u>3.7</u> °C	IR Gun ID: <u>h</u>
Sample State of Collection: <u>(PA)</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>(NO)</u>

PART C: Receipt Details Completed (if different from above): _____ / / _____ Signature Date Time

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>(YES)</u>	NO	Comments:
COC form is properly signed in relinquished/received sections?	<u>(YES)</u>	NO	Comments:
Sample containers intact and sealed?	<u>(YES)</u>	NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Samples received within holding time?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>(YES)</u>	NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>(YES)</u>	NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>(YES)</u>	NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<u>(YES)</u>	<u>(NO)</u>	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created: YES <u>(NO)</u>

Effective Date:

GP.25.A-1 Sample Receipt Log