

**Moniteau School District  
Dassa Elementary School  
Water Treatment Facility  
Monthly Operations Report  
September 2021**

Dassa McKinney Elementary School Water Treatment Facility

Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Wed	8.7	0.03	0.58	0.66	3.12	12730900	JEFF R	4:00P	1500
2	Thurs	8.7	0.02	0.60	0.70	3.18	12732100	JEFF R	5:00P	1200
3	Fri			SICK	Day					
4	Sat									
5	Sun									
6	Mon	8.7	0.02	0.67	0.73	2.82	12736700	JEFF R	3:30P	4600
7	Tues	8.7	0.01	0.67	0.74	2.68	12740900	JEFF R	2:30P	4200
8	Wed	8.7	0.04	0.68	0.74	2.91	12745700	JEFF R	4:00P	4600
9	Thurs	8.7	0.01	0.64	0.70	2.68				
10	Fri	8.7	0.00	0.62	0.69	2.73	12749000	JEFF R	2:30P	3300
11	Sat									
12	Sun									
13	Mon	8.7	0.02	0.63	0.68	2.61	12754100	JEFF R	4:30P	5100
14	Tues	8.7	0.00	0.64	0.70	2.47	12758400	JEFF R	3:30P	4300
15	Wed	8.7	0.01	0.67	0.72	2.54	12763200	JEFF R	3:30P	4800
16	Thurs	8.7	0.04	0.65	0.70	2.88	12768000	JEFF R	3:30P	4800
17	Fri	8.7	0.02	0.64	0.70	3.14	12772000	JEFF R	2:30P	4000
18	Sat									
19	Sun									
20	Mon									
21	Tues	8.7	0.00	0.58	0.66	3.21	12782100	JEFF R	3:00P	10100
22	Wed	8.7	0.02	0.69	0.77	3.44	12787500	JEFF R	4:00P	8400
23	Thurs	8.7	0.00	0.74	0.79	3.35	12792200	JEFF R	3:30P	4700
24	Fri	8.7	0.01	0.84	0.92	3.87	12797200	JEFF R	3:30P	5000
25	Sat									
26	Sun									
27	Mon	8.7	0.00	0.71	0.80	2.82	12802300	JEFF R	3:30P	5100
28	Tues	8.7	0.00	0.65	0.74	3.37	12806800	JEFF R	2:30P	4500
29	Wed	8.7	0.01	0.71	0.79	3.50	12808000	JEFF R	2:00P	1200
30	Thurs									
31										

Aug. 31 meter reading - 12729400



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

24 September 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1092267**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	1092267-01	Drinking Water	09/23/2021 11:22	9/23/21 14:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/24/2021 08:57

**Lab Sample ID#:** 1092267-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 Room 408 Sink

**Sample Date:** 09/23/2021 11:22  
**Receipt Date:** 09/23/2021 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.830	mg/L		0.200	PS	09/23/21 11:22	09/23/21 11:22



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

**HEADQUARTER**  
 1803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209



**SOUTHERN DIVI'**  
 1276 Bentleyville  
 Van Voorhis, PA  
 (724) 258-TEST  
 FAX: (724) 258-




**NORTHWEST DIVISION**  
 950 Main Street  
 Sharpsville, PA 16  
 (724) 463-TEST  
 FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

DATE   1   OF   1  

Sample Identification Distribution: <u>804</u>		ESL# <u>1092267</u>	Sample Type Date: <u>9-23-21</u> Time: <u>11:22</u>	Matrix DW	# of Bottles Field	Container Type Preservative Field	Analysis Requested Free Chlorine <u>83</u> mg/L
ROTATION Wk 1 - 801 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink							
Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD. 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW). 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) 	Date/ Time <u>9-23-21 11:22</u>	Relinquished By: (Signature) 	Date/ Time <u>9-23-21 13:35</u>	Received By: (Signature) 	Date/ Time <u>9-23-21 14:00</u>	Company/Name: MONITEAU SCHOOL DISTRICT	Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL
Relinquished By: (Signature)	Date/ Time	Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Phone Number: 724-406-4426	Cell Phone: jcampbell@moniteau.org
Relinquished By: (Signature)	Date/ Time	Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Billing Address: 5100316	PWSID:
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature					




E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.54	091621	803		091621	D	1200	32382	1091706-01	BROWNKA_493
5100316	1013	FREE CHLORINE	301	0.83	092321	804		092321	D	1122	32382	1092267-01	BROWNKA_872



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

20 September 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1091706**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	1091706-01	Drinking Water	09/16/2021 12:00	9/16/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions


RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/20/2021 09:13

**Lab Sample ID#:** 1091706-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Room 606 Sink

**Sample Date:** 09/16/2021 12:00  
**Receipt Date:** 09/16/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.540	mg/L		0.200	PS	09/16/21 12:00	09/16/21 12:00

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIV  
1276 Bentleyville  
Van Voorhis, PA  
(724) 258-TEST  
FAX: (724) 258-

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

3E \_\_\_1\_\_\_ OF \_\_\_1\_\_\_

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	1091706	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	Distribution: 803	01				

Sample Type	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	Date	Time				
ROTATION	9/16/21	1200	DW	Field	Field	Free Chlorine .54 mg/L
Wk 1 - 801 Kitchen Sink						
Wk 2 - 802 Room 617 Sink						
Wk 3 - 803 Room 606 Sink						
Wk 4 - 804 Room 408 Sink						
Wk 5 - 802 Room 617 Sink						

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Dassa McKinney - Weekly

Company/Name: MONITEAU SCHOOL DISTRICT

Address: 391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL

Contact Person: 724-406-4426  
Phone Number: jcampbell@moniteau.org  
Cell Phone:  
Email Address:  
Billing Address:  
PWSID: 5100316

Received By: (Signature) Date/ Time  
SPM 9/16/21 1200 (202382)

Relinquished By: (Signature) Date/ Time  
9/16/21 1408

Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.54	091621	803		091621	D	1200	32382	1091706-01	BROWNKA_493



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

12 September 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1090931**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1090931-01	Drinking Water	09/09/2021 12:45	9/9/21 16:08	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/12/2021 21:15

**Lab Sample ID#:** 1090931-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 09/09/2021 12:45  
**Receipt Date:** 09/09/2021 16:08

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>							
<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.730	mg/L		0.200	PS	09/09/21 12:45	09/09/21 12:45



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209



1090931

SOUTHERN DIVISION  
1276 Bentleyville Rr  
Van Voorhis, PA 152  
(724) 258-TEST  
FAX: (724) 258-837

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

F-UK INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>SD</u>	<u>1090931</u>	<u>9-9-21</u>	<u>1245</u>	DW	Field	Field	Free Chlorine <u>.73</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>9-9-21 1245</u>		Received By: (Signature) <u>[Signature]</u> Date/ Time <u>9/9/21 16:05</u>		Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly			
Relinquished By: (Signature) <u>[Signature]</u> Date/ Time _____		Relinquished By: (Signature) _____ Date/ Time _____		Company/Name: <b>MONITEAU SCHOOL DISTRICT</b> Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061</b> Contact Person: <b>JEFFERY CAMPBELL</b> Phone Number: _____ Cell Phone: <b>724-406-4426</b> Email Address: <b>jcampbell@moniteau.org</b> Billing Address: _____ PWSID: <b>5100316</b>			
Relinquished By: (Signature) _____ Date/ Time _____		Relinquished By: (Signature) _____ Date/ Time _____		Correct Preservations Y / N / NA _____ Correct Containers Y / N / NA _____ Receipt Temperature _____			

E-Government Application for Drinking Water  
Program  
**SAFE DRINKING WATER ACT**  
VIEW/EDIT RECORDS

## 5100316: DASSA MCKINNEY ELEM SCHOOL SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1773
5100316	2451	DICHLOROACETIC ACID	206	0.00227	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1794
5100316	2452	TRICHLOROACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1815
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1836
5100316	2454	DIBROMOACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1857
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00227	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1878
5100316	2941	CHLOROFORM (THM)	221	0.00332	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1899
5100316	2942	BROMOFORM (THM)	221	0.0	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1920
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00252	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1942
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00188	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1963
5100316	2950	TRICHALOMETHANES	221	0.00772	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1984
5100316	2450	MONOCHLOROACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1774
5100316	2451	DICHLOROACETIC ACID	206	0.00242	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1795
5100316	2452	TRICHLOROACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1816
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1837
5100316	2454	DIBROMOACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1858
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00242	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1879
5100316	2941	CHLOROFORM (THM)	221	0.00334	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1900
5100316	2942	BROMOFORM (THM)	221	0.0	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1921



E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00241	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1941
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00159	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1962
5100316	2950	TRIHALOMETHANES	221	0.00734	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1983
5100316	1013	FREE CHLORINE	301	0.83	080921	801		080921	D	1000	32382	1080920-01	BROWNKA_266
5100316	1013	FREE CHLORINE	301	0.8	090221	801		090221	D	1130	32382	1090267-01	BROWNKA_3068
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090321	801		090221	D	1130	32382	1090267-01	BROWNKA_3069
5100316	1013	FREE CHLORINE	301	0.53	080521	802		080521	D	1220	32382	1080632-01	BROWNKA_264
5100316	1013	FREE CHLORINE	301	0.73	090921	802		090921	D	1245	32382	1090931-01	BROWNKA_3070
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1220	32382	1080632-01	BROWNKA_265
5100316	1013	FREE CHLORINE	301	0.82	081921	803		081921	D	1115	32382	1082136-01	BROWNKA_1687
5100316	1013	FREE CHLORINE	301	0.4	082621	804		082621	D	1200	32382	1082755-01	BROWNKA_2118

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1010	BARIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1159
5100316	1015	CADMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1161
5100316	1020	CHROMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1163
5100316	1025	FLUORIDE (IOC)	120	0.119	0.05000		081621	101		080521	E	1210	32382	1080610-01	BROWNKA_1169
5100316	1035	MERCURY (IOC)	103	0.0	0.00020		081321	101		080521	E	1210	32382	1080610-01	BROWNKA_1165

E-Government Application for Drinking Water Program  
SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1036	NICKEL (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA 1167
5100316	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA 33
5100316	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA 34
5100316	2378	1,2,4-TRICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 729
5100316	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 730
5100316	2955	XYLENES (TOTAL)	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 731
5100316	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 732
5100316	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 733
5100316	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 734
5100316	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 735
5100316	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 736
5100316	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 737
5100316	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 738
5100316	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 739
5100316	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 740
5100316	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 741
5100316	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 742
5100316	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 743
5100316	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 744
5100316	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 745



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 746
5100316	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 747
5100316	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 748
5100316	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 749



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/12/2021 21:49

**Lab Sample ID#:** 1090267-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Vance Byram  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 09/02/2021 11:30  
**Receipt Date:** 09/02/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-CI G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.800	mg/L		0.200	VB	09/02/21 11:30	09/02/21 11:30
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	09/02/21 15:36	09/03/21 15:43
E. Coli	Absent	per 100 mL		1	DAA	09/02/21 15:36	09/03/21 15:43

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209



1090267



FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

SE 1 OF 1

## SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK 802 ROOM 617 SINK	1090267			DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.80 mg/L

**Rotation:**  
801: Jan, Mar, May, Jul, Sep,  
Nov  
802: Feb, Apr, Jun, Aug, Oct,  
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 09/21/13 1130  
Relinquished By: (Signature) [Signature] Date/ Time 09/21/14 1440

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature 3.4 °C

Notes/Special Instructions::

Drinking Water Dassa McKinney - Monthly

Company/Name: **MONITEAU SCHOOL DISTRICT**  
Address: 391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
Contact Person: JEFFREY CAMPBELL  
Phone Number:  
Cell Phone: 724-406-4426  
Email Address: jcambell@moniteau.org  
Billing Address:  
PWSID: 5100316

Received By: (Signature) [Signature] Date/ Time 09/21/13 1500  
Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

E-Government Application for Drinking Water  
Program  
**SAFE DRINKING WATER ACT**  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1773
5100316	2451	DICHLOROACETIC ACID	206	0.00227	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1794
5100316	2452	TRICHLOROACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1815
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1836
5100316	2454	DIBROMOACETIC ACID	206	0.0	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1857
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00227	081921	703		080921	D	0955	32382	1080924-01	BROWNKA_1878
5100316	2941	CHLOROFORM (THM)	221	0.00332	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1899
5100316	2942	BROMOFORM (THM)	221	0.0	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1920
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00252	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1942
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00188	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1963
5100316	2950	TRICHALOMETHANES	221	0.00772	081521	703		080921	D	0955	32382	1080924-01	BROWNKA_1984
5100316	2450	MONOCHLOROACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1774
5100316	2451	DICHLOROACETIC ACID	206	0.00242	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1795
5100316	2452	TRICHLOROACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1816
5100316	2453	MONOBROMOACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1837
5100316	2454	DIBROMOACETIC ACID	206	0.0	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1858
5100316	2456	HALOACETIC ACIDS (FIVE)	206	0.00242	081921	704		080921	D	0950	32382	1080924-02	BROWNKA_1879
5100316	2941	CHLOROFORM (THM)	221	0.00334	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1900
5100316	2942	BROMOFORM (THM)	221	0.0	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1921





E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00241	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1941
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.00159	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1962
5100316	2950	TRIHALOMETHANES	221	0.00734	081521	704		080921	D	0950	32382	1080924-02	BROWNKA_1983
5100316	1013	FREE CHLORINE	301	0.83	080921	801		080921	D	1000	32382	1080920-01	BROWNKA_266
5100316	1013	FREE CHLORINE	301	0.8	090221	801		090221	D	1130	32382	1090267-01	BROWNKA_3068
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	090321	801		090221	D	1130	32382	1090267-01	BROWNKA_3069
5100316	1013	FREE CHLORINE	301	0.53	080521	802		080521	D	1220	32382	1080632-01	BROWNKA_264
5100316	1013	FREE CHLORINE	301	0.73	090921	802		090921	D	1245	32382	1090931-01	BROWNKA_3070
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1220	32382	1080632-01	BROWNKA_265
5100316	1013	FREE CHLORINE	301	0.82	081921	803		081921	D	1115	32382	1082136-01	BROWNKA_1687
5100316	1013	FREE CHLORINE	301	0.4	082621	804		082621	D	1200	32382	1082755-01	BROWNKA_2118

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1010	BARIIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1159
5100316	1015	CADMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1161
5100316	1020	CHROMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA_1163
5100316	1025	FLUORIDE (IOC)	120	0.119	0.05000		081621	101		080521	E	1210	32382	1080610-01	BROWNKA_1169
5100316	1035	MERCURY (IOC)	103	0.0	0.00020		081321	101		080521	E	1210	32382	1080610-01	BROWNKA_1165

E-Government Application for Drinking Water Program  
SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1036	NICKEL (IOC)	169	0.0	0.00500		081221	101		080521	E	1210	32382	1080610-01	BROWNKA 1167
5100316	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA 33
5100316	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1210	32382	1080611-01	BROWNKA 34
5100316	2378	1,2,4-TRICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 729
5100316	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 730
5100316	2955	XYLENES (TOTAL)	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 731
5100316	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 732
5100316	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 733
5100316	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 734
5100316	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 735
5100316	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 736
5100316	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 737
5100316	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 738
5100316	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 739
5100316	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 740
5100316	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 741
5100316	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 742
5100316	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 743
5100316	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 744
5100316	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 745



E-Government Application for Drinking Water Program  
 SAFE DRINKING WATER ACT  
 VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 746
5100316	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 747
5100316	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 748
5100316	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	0945	32382	1080923-01	BROWNKA 749



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

01 October 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1092879**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	1092879-01	Drinking Water	09/30/2021 10:50	9/30/21 16:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 10/01/2021 11:43

**Lab Sample ID#:** 1092879-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Vance Byram  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 09/30/2021 10:50  
**Receipt Date:** 09/30/2021 16:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.300	mg/L		0.200	VB	09/30/21 10:50	09/30/21 10:50

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**


HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209



1092879

SOUTHE  
1276 Ben  
Van Voor  
(724) 258  
FAX: (724) 465-4209

VISION  
950 Main Street  
Sharpville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



NORTHWEST DIVISION  
950 Main Street  
Sharpville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: _____	1092879			DW	Field	Field	Free Chlorine 0.30 mg/L
	01		01/30/21 1050				
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>							
<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>jcampbell@moniteau.k12.pa.us</b></p> <p>Email Address: <b>jcampbell@moniteau.k12.pa.us</b></p> <p>Billing Address: <b>5100316</b></p> <p>PWSID: <b>5100316</b></p>							
<p>Received By: (Signature) <i>[Signature]</i></p> <p>Date/ Time: <i>09/30/21 1600 (25580)</i></p>		<p>Received By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Received By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Received By: (Signature) _____</p> <p>Date/ Time _____</p>	
<p>Relinquished By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Relinquished By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Relinquished By: (Signature) _____</p> <p>Date/ Time _____</p>		<p>Relinquished By: (Signature) _____</p> <p>Date/ Time _____</p>	
<p>Correct Preservations Y / N / NA</p>		<p>Correct Containers Y / N / NA</p>		<p>Receipt Temperature _____</p>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**


PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.3	093021	802		093021	D	1050	32382	1092879-01	BROWNKA_1594
5100316	1013	FREE CHLORINE	301	0.54	091621	803		091621	D	1200	32382	1091706-01	BROWNKA_493
5100316	1013	FREE CHLORINE	301	0.83	092321	804		092321	D	1122	32382	1092267-01	BROWNKA_872

**Moniteau School District**  
**Moniteau High School**  
**Water Treatment Facility**  
**Monthly Operations Report**  
**September 2021**



MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT										
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
1	Wed	69.8	8.34	5, 228, 688	1.25	1.35	7.2	0.03	0	1.14	Jeff C	8:00A
2	Thurs	71.1	7.50	5, 228, 688	1.24	1.31	7.2	0.03	0	1.13	Jeff C	8:15A
3	Fri	65.7	11:05	5, 241, 570	1.12	1.18	7.2	0.01	0	1.17	Jeff C	8:30A
4	SAT											
5	SUN											
6	Mon			LABOR DAY								
7	Tues	66.1	10.18	5, 254, 611	1.15	1.25	7.2	0.03	0	0.92	Jeff C	9:00A
8	Wed	66.1	11.18	5, 254, 611	1.17	1.23	7.2	0.02	0	0.90	Jeff C	1:30P
9	Thurs	66.9	10.38	5, 254, 611	1.12	1.20	7.2	0.02	0	0.89	Jeff C	8:30A
10	Fri	67.5	8.90	5, 254, 611	1.13	1.21	7.1	0.02	0	1.39	Jeff C	1:30P.
11	SAT											
12	SUN											
13	Mon	79.0	9.89	5, 269, 118	1.10	1.17	7.2	0.01	0	1.21	Jeff C	9:00Am
14	Tues	79.5	8.72	5, 269, 118	1.03	1.12	7.2	0.01	0	1.20	Jeff C	9:00A
15	Wed	80.0	7.85	5, 269, 118	0.98	1.05	7.2	0.01	0	1.20	Jeff C	9:00A
16	Thurs	67.4	10.87	5, 284, 005	0.86	0.94	7.2	0.02	0	1.21	Jeff C	10:30A
17	Fri	72.0	9.01	5, 284, 005	0.85	0.94	7.2	0.02	0	1.18	Jeff C	7:00 AM
18	SAT											
19	SUN											
20	Mon	70.8	9.90	5, 297, 868	0.81	0.88	7.2	0.02	0	1.45	Jeff C	2:30 PM
21	Tues	70.5	8.58	5, 297, 868	0.80	0.88	7.2	0.02	0	1.13	Jeff C	10:00 AM
22	Wed	67.0	9.03	5, 307, 460	0.79	0.85	7.2	0.02	0	1.17	Jeff C	1:00 PM
23	Thurs	66.7	11.21	5, 316, 117	0.64	0.69	7.2	0.01	0	1.05	Jeff C	10:00 AM
24	Fri	65.8	9.21	5, 316, 117	0.64	0.70	7.2	0.01	0	1.09	Jeff C	9:00 AM
25	SAT											
26	SUN											
27	Mon	64.2	10.60	5, 331, 050	0.55	0.62	7.1	0.03	0	1.51	Jeff C	10:00 AM
28	Tues	65.0	9.01	5, 331, 050	0.50	0.55	7.1	0.02	0	1.50	Jeff C	9:00 AM
29	Wed	65.5	7.37	5, 331, 050	0.48	0.52	7.1	0.02	0	1.49	Jeff C	9:00 AM
30	Thurs	65.2	10.46	5, 214, 059	0.54	0.57	7.1	0.01	0	1.27	Jeff C	4:00 AM
31												

Water Sample Test Day Sewage Sample Test Day



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

24 September 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1092268**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	1092268-01	Drinking Water	09/23/2021 11:40	9/23/21 14:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/24/2021 08:56

**Lab Sample ID#:** 1092268-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 09/23/2021 11:40  
**Receipt Date:** 09/23/2021 14:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.640	mg/L		0.200	PS	09/23/21 11:40	09/23/21 11:40

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209



1092268

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time			
Distribution: 804	1092268	Date: 9/23/21	Time: 1140	Field	Field	Free Chlorine 0.64 mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804-400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
	9/23/21 1140	Spm 9/23/21 1140 (655)	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
	9/23/21 1335		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature	
Company/Name:	MONITEAU SCHOOL DISTRICT		
Address:	391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL		
Contact Person:	724-406-4426		
Phone Number:	jcampbell@moniteau.org		
Cell Phone:	5100324		
Email Address:			
Billing Address:			
PWSID:			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.93	091621	803		091621	D	1217	32382	1091704-01	BROWNKA_494
5100324	1013	FREE CHLORINE	301	0.64	092321	804		092321	D	1140	32382	1092268-01	BROWNKA_873



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

20 September 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 1091704  
 Project: Drinking Water Moniteau Jr/Sr - Weekly  
 Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	1091704-01	Drinking Water	09/16/2021 12:17	9/16/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions


RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/20/2021 09:13

**Lab Sample ID#:** 1091704-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Admin Sink

**Sample Date:** 09/16/2021 12:17  
**Receipt Date:** 09/16/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.930	mg/L		0.200	PS	09/16/21 12:17	09/16/21 12:17

# ENVIRONMENTAL SERVICE LABORATORIES INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN  
1276 Benite  
Van Voorh  
(724) 258-  
FAX: (724) 258-  
FOR...



NORTHERN DIVISION  
957  
17754  
1957  
LY

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

RE 1 OF 1

Sample Identification	ESL# 1091704	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: 803	01	DW	Field	Field	Free Chlorine: 93 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>					
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>					
Sampled By: (Signature)	Date/ Time 9/16/24 12:17	Received By: (Signature)	Date/ Time 9/16/24 15:00	Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly	
Relinquished By: (Signature)	Date/ Time 9/16/24 14:08	Received By: (Signature)	Date/ Time	Company/Name: MONITEAU SCHOOL DISTRICT	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Address: 391 HOOKER ROAD	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Contact Person: WEST SUNBURY, PA 16061	
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Phone Number: JEFFREY CAMPBELL	
Correct Preservations Y / N / NA	Correct Containers Y / N / NA	Receipt Temperature	Cell Phone: 724-406-4426		
			Email Address: jcambell@moniteau.org		
			Billing Address: 5100324		
			PWSID:		





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.93	091621	803		091621	D	1217	32382	1091704-01	BROWNKA_494



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

12 September 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1090935**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	1090935-01	Drinking Water	09/09/2021 13:05	9/9/21 16:11	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/12/2021 21:15

**Lab Sample ID#:** 1090935-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink


**Sample Date:** 09/09/2021 13:05  
**Receipt Date:** 09/09/2021 16:11

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	1.17	mg/L		0.200	PS	09/09/21 13:05	09/09/21 13:05

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN  
1276 Bentik  
Van Voorh  
(724) 258-1  
FAX: (724)



1090935

SION  
17754  
.957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

DATE    OF   

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>802</u>	<u>1090935</u>	<u>9-9-21</u>	<u>1305</u>	DW	Field	Field	Free Chlorine: <u>1.1</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Moniteau Jr/Sr - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.org**

Billing Address: **5100324**

PWSID: **5100324**

Sampled By: (Signature) [Signature] Date/ Time 9-9-21 1305

Relinquished By: (Signature) [Signature] Date/ Time 9-9-21 1455

Received By: (Signature) [Signature] Date/ Time 9/9/21 16:11

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.08	080921	704		080921	D	1020	32382	1080919-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.6	090221	704		090221	D	1210	32382	1090261-01	BROWNKA_3073
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090321	704		090221	D	1210	32382	1090261-01	BROWNKA_3074
5100324	1013	FREE CHLORINE	301	1.05	080521	802		080521	D	1255	32382	1080630-01	BROWNKA_269
5100324	1013	FREE CHLORINE	301	1.17	090921	802		090921	D	1305	32382	1090935-01	BROWNKA_3075
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1255	32382	1080630-01	BROWNKA_270
5100324	1013	FREE CHLORINE	301	1.18	081921	803		081921	D	1127	32382	1082135-01	BROWNKA_1593
5100324	1013	FREE CHLORINE	301	0.96	082621	804		082621	D	1225	32382	1082756-01	BROWNKA_2119

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1010	BARIUM (IOC)	169	0.109	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1034
5100324	1015	CADMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1044
5100324	1020	CHROMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1054
5100324	1025	FLUORIDE (IOC)	120	0.134	0.05000		081521	101		080521	E	1255	32382	1080609-01	BROWNKA_1064
5100324	1035	MERCURY (IOC)	103	0.0	0.00020		081321	101		080521	E	1255	32382	1080609-01	BROWNKA_1074
5100324	1036	NICKEL (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1084
5100324	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA_35



E-Government Application for Drinking Water Program  
SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA 36
5100324	2378	1,2,4-TRICHLOROBENZE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 750
5100324	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 751
5100324	2955	XYLENES (TOTAL)	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 752
5100324	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 753
5100324	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 754
5100324	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 755
5100324	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 756
5100324	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 757
5100324	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 758
5100324	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 759
5100324	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 760
5100324	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 761
5100324	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 762
5100324	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 763
5100324	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 764
5100324	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 765
5100324	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 766
5100324	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 767
5100324	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 768

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 769
5100324	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 770



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpshville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 September 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1090261**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 704**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	1090261-01	Drinking Water	09/02/2021 12:10	9/2/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
Project Manager







1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/12/2021 21:49

**Lab Sample ID#:** 1090261-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Vance Byram  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 09/02/2021 12:10  
**Receipt Date:** 09/02/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.600	mg/L		0.200	VB	09/02/21 12:10	09/02/21 12:10
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	09/02/21 15:36	09/03/21 15:43
E. Coli	Absent	per 100 mL		1	DAA	09/02/21 15:36	09/03/21 15:43

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN D  
435 Broad St  
Montoursville, F  
(570) 321-9003  
FAX: (570) 321-1957



1090261

1749 403-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 1090261	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	02	01/02/21	12:10	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine <u>0.60</u>

704: Jan, Mar, May, Jul, Sept, Nov  
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) [Signature] Date/ Time 12:10  
Relinquished By: (Signature) [Signature] Date/ Time 14:40

Received By: (Signature) [Signature] Date/ Time 2/2/21 1500  
Relinquished By: (Signature) [Signature] Date/ Time 1500

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature 3:24 i/c

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Monthly

Company/Name: **MONITEAU SCHOOL DISTRICT**  
Address: **1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061**  
Contact Person: **JEFFREY CAMPBELL**  
Phone Number: \_\_\_\_\_  
Cell Phone: **724-496-4426**  
Email Address: **jcambell@moniteau.org**  
Billing Address: \_\_\_\_\_  
PWSID: **5100324**



E-Government Application for Drinking Water  
Program  
**SAFE DRINKING WATER ACT**  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.08	080921	704		080921	D	1020	32382	1080919-01	BROWNKA_271
5100324	1013	FREE CHLORINE	301	0.6	090221	704		090221	D	1210	32382	1090261-01	BROWNKA_3073
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	090321	704		090221	D	1210	32382	1090261-01	BROWNKA_3074
5100324	1013	FREE CHLORINE	301	1.05	080521	802		080521	D	1255	32382	1080630-01	BROWNKA_269
5100324	1013	FREE CHLORINE	301	1.17	090921	802		090921	D	1305	32382	1090935-01	BROWNKA_3075
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080621	802		080521	D	1255	32382	1080630-01	BROWNKA_270
5100324	1013	FREE CHLORINE	301	1.18	081921	803		081921	D	1127	32382	1082135-01	BROWNKA_1593
5100324	1013	FREE CHLORINE	301	0.96	082621	804		082621	D	1225	32382	1082756-01	BROWNKA_2119

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1010	BARIUM (IOC)	169	0.109	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1034
5100324	1015	CADMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1044
5100324	1020	CHROMIUM (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1054
5100324	1025	FLUORIDE (IOC)	120	0.134	0.05000		081521	101		080521	E	1255	32382	1080609-01	BROWNKA_1064
5100324	1035	MERCURY (IOC)	103	0.0	0.00020		081321	101		080521	E	1255	32382	1080609-01	BROWNKA_1074
5100324	1036	NICKEL (IOC)	169	0.0	0.00500		081221	101		080521	E	1255	32382	1080609-01	BROWNKA_1084
5100324	1040	NITRATE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA_35

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1041	NITRITE	120	0.0	0.10000		080721	101		080521	E	1255	32382	1080608-01	BROWNKA 36
5100324	2378	1,2,4-TRICHLOROBENZE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 750
5100324	2380	cis-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 751
5100324	2955	XYLENES (TOTAL)	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 752
5100324	2964	DICHLOROMETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 753
5100324	2968	o-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 754
5100324	2969	PARA-DICHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 755
5100324	2976	VINYL CHLORIDE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 756
5100324	2977	1,1-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 757
5100324	2979	trans-1,2-DICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 758
5100324	2980	1,2-DICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 759
5100324	2981	1,1,1-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 760
5100324	2982	CARBON TETRACHLORIDE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 761
5100324	2983	1,2-DICHLOROPROPANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 762
5100324	2984	TRICHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 763
5100324	2985	1,1,2-TRICHLOROETHANE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 764
5100324	2987	TETRACHLOROETHYLENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 765
5100324	2989	CHLOROBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 766
5100324	2990	BENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 767
5100324	2991	TOLUENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 768



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2992	ETHYLBENZENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 769
5100324	2996	STYRENE	221	0.0	0.00050		081121	101		080921	E	1017	32382	1080929-01	BROWNKA 770



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 September 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 1090267  
Project: Drinking Water Dassa McKinney - Monthly 801  
Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	1090267-01	Drinking Water	09/02/2021 11:30	9/2/21 15:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

01 October 2021

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 1092880**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	1092880-01	Drinking Water	09/30/2021 11:25	9/30/21 16:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 10/01/2021 11:43

**Lab Sample ID#:** 1092880-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Vance Byram  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 09/30/2021 11:25  
**Receipt Date:** 09/30/2021 16:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.540	mg/L		0.200	VB	09/30/21 11:25	09/30/21 11:25



**SAMPLE REQUEST & CHAIN OF CUSTODY**

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

**HEADQUARTER**  
 1803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209

**SOUTHERN I**  
 1276 Bentley  
 Van Voorhis, I  
 (724) 258-TE  
 FAX: (724) 2

**NORTHWEST DIVISION**  
 950 Main Street  
 Sharpsville, PA 16  
 (724) 463-TEST  
 FAX: (724) 465-4209

ON 7754



1092880

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: _____	01	09/30/21	1125	DW	Field	Field	Free Chlorine 0.54 mg/L
<p><b>ROTATION</b></p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Received By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>			
<p>Correct Preservations Y / N / NA</p>				<p>Correct Containers Y / N / NA</p>			
<p>Receipt Temperature _____</p>				<p>Receipt Temperature _____</p>			

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

**MONITEAU SCHOOL DISTRICT**  
 391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 JEFFREY CAMPBELL  
 724-406-4426  
 jcambell@moniteau.k12.pa.us  
 5100324

Company Name:  
 Address:  
 Contact Person:  
 Phone Number:  
 Cell Phone:  
 Email Address:  
 Billing Address:  
 PWSID:

Received By: (Signature) \_\_\_\_\_ Date/ Time 09/30/21 1125  
 Relinquished By: (Signature) \_\_\_\_\_ Date/ Time 09/30/21 1315

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.93	091621	803		091621	D	1217	32382	1091704-01	BROWNKA_494
5100324	1013	FREE CHLORINE	301	0.64	092321	804		092321	D	1140	32382	1092268-01	BROWNKA_873
5100324	1013	FREE CHLORINE	301	0.54	093021	804		093021	D	1125	32382	1092880-01	BROWNKA_1595

**COMMONWEALTH OF PENNSYLVANIA  
 DEPARTMENT OF ENVIRONMENTAL PROTECTION  
 BUREAU OF CLEAN WATER**

**DISCHARGE MONITORING REPORT (DMR)**

**NAME:** MONITEAU SCH DIST  
**ADDRESS:** 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
**FACILITY:** MONITEAU JR SR HIGH SCHOOL  
**LOCATION:** 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
**STAGE:** Final Effluent

**PA0091341**  
 PERMIT NUMBER

**001**  
 OUTFALL NUMBER

**Reporting Frequency:** Monthly  
**DMR Effective From:** 09/01/2021  
**DMR Effective To:** 09/30/2021  
**Permit Expires:** 05/31/2022  
**Permit Application Due:** 12/02/2021  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2021	09	01	2021	09	30

FROM

PARAMETER	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***	7.05	***	***	***	1/week	Grab
	PERMIT REQUIREMENT	***	4.0 Min	***	***	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***	7.34	***	8.88	***	1/week	Grab
	PERMIT REQUIREMENT	***	6.0 Min	***	9.0 Max	***	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***	***	<5.0	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	30 Avg Mo	***	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***	***	2.12	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	Monitor & Report Avg Mo	***	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***	***	.13	***	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	Monitor & Report Avg Mo	***	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***	***	7.13	***	***	1/week	Grab
	PERMIT REQUIREMENT	***	***	Monitor & Report Avg Mo	***	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.003412	***	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<3.0	<1.0	No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***		***	200 Geo Mean	1000 IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	3.38	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		***	25 Avg Mo	***		2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------

**Moniteau School District**  
**Moniteau High School**  
**Wastewater Treatment Facility**  
**Monthly Operations Report**  
**September 2021**

---



JEFFREY CAMPBELL <jcampbell@moniteau.org>

---

## Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

---

**depgreenporthelpdesk@state.pa.us** <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Mon, Oct 4, 2021 at 9:34 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL

**Permit Number:** PA0091341

**Report Frequency:** Monthly

**Report Type:** DMR

**Reporting Period:** 09/01/2021-09/30/2021

**Report Due Date:** 10/28/2021

**Submitted By:** Jeffrey Campbell

**Submission Id:** 288075

**Submission Status:** Received

**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District  
 Moniteau High School  
 WASTEWATER TREATMENT PLANT  
 Monthly Operations Worksheet  
 SEPT 2021

Flow  $102,362 \div 30 = 3,412$  Daily Avg.

U.V.  $149.8 \div 21 = 7.13$  Daily Avg.

PH Low 7.34 #2 BASIN 9/21

High 8.88 #1 BASIN 9/13

D.O. Low 7.05 #2 BASIN 9/13

High 9.08 #2 BASIN 9/12

Total Nitrogen  $2.42 + 1.82 = 4.24 \div 2 = 2.12$

TSS  $< 5 + < 5 = < 5$

Total K-Nitrogen  $< 0.625 + < 0.625$

Nitrate / Nitrite  $2.42 + 1.82 = 4.24 \div 2 = 2.12$

Phos.  $0.16 + < 0.10 = 0.26 \div 2 = 0.13$

CBOD  $4.76 + < 2.00 = 6.76 \div 2 = 3.38$

Fecal  $< 1 + < 5 = < 6 \div 2 = < 3$







1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

17 September 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1090253**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	1090253-01	Waste Water	09/02/2021 11:30	9/2/21 14:50	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/17/2021 14:35

**Lab Sample ID#:** 1090253-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Jeffrey Campbell  
**Client Sample ID:** Effluent Grab

**Sample Date:** 09/02/2021 11:30  
**Receipt Date:** 09/02/2021 14:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	2.42	mg/L		0.729	DAA	09/15/21 15:08	09/15/21 15:08
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	09/08/21 09:42	09/08/21 13:00
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NH3 D-11</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	09/11/21 09:50	09/11/21 15:22
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	2.42	mg/L		0.104	AW	09/15/21 15:08	09/15/21 15:08
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	0.16	mg/L		0.10	AW	09/14/21 16:10	09/14/21 16:10
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	4.76	mg/L	G, SS	2.00	JAW	09/03/21 16:00	09/08/21 10:55
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	09/02/21 16:18	09/03/21 10:24





# SAMPLE RECEIPT AND REVIEW FORM

<b>Client:</b> <u>Moniteau</u>	<b>Work C</b> 1090253
--------------------------------	--------------------------

### PART A: GENERAL INFORMATION- SATELLITE LABORATORY

<b>Received by/Lab ID:</b> _____	<b>Date/Time Received:</b> /    /    _____
<b>Method of Delivery:</b> Client Drop-Off    ESL Courier    Other: _____	<b>Received on Ice?</b> YES    NO
<b>Sample Receipt Temperature:</b> _____ °C	<b>IR Gun ID:</b> _____
<b>Containers Removed by Satellite Lab for Analysis of:</b> FECAL    TC/EC    TC MPN    EC MPN    TC/EC MPN <input checked="" type="checkbox"/> N/A	

### PART B: GENERAL INFORMATION- INDIANA LABORATORY

<b>Received by/Lab ID:</b> <u>SP1 PWS2</u>	<b>Samples Received on Ice?</b> <input checked="" type="checkbox"/> YES    NO
<b>Date/Time Received:</b> <u>01 &gt; 17 1450</u>	<b>Date Sampled:</b> <u>01 &gt; 17</u>
<b>Method of Delivery:</b> FedEx    UPS    Client Drop off <del>ESL courier</del> Other: _____	
<b>Sample Receipt Temperature:</b> <u>3.6</u> °C	<b>IR Gun ID:</b> <u>44</u>
<b>Sample State of Collection:</b> <input checked="" type="checkbox"/> PA    NY    OH    WV    Other: _____	<b>PWSID Compliance Drinking Water Samples:</b> YES <input checked="" type="checkbox"/> NO

### PART C: Receipt Details    Completed (if different from above): \_\_\_\_\_

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	YES	NO	Comments:
COC form is properly signed in relinquished/received sections?	YES	NO	Comments:
Sample containers intact and sealed?	YES	NO	Circle Applicable:    Damaged Container    Leaking Container Custody Seal Broken    Other: _____
Number of containers received matches number indicated on COC?	YES	NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	YES	NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	YES	NO	Sample IDs and Containers Affected:
Samples received within holding time?	YES	NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	YES	NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES	NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	YES	NO	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	<input checked="" type="checkbox"/> NO	Sample IDs and Containers Affected:
<b>Other Comments:</b>			<b>Deficiency Log Created:</b>
			YES <input checked="" type="checkbox"/> NO

Effective Date:



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

28 September 2021

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 1091703**  
**Project: Wastewater**  
**Project Description: Wastewater**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	1091703-01	Waste Water	09/16/2021 11:00	9/16/21 15:00	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

### Approved By

*Rebecca Erwin*

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/28/2021 08:54

**Lab Sample ID#:** 1091703-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Jeffrey Campbell  
**Client Sample ID:** Effluent Grab

**Sample Date:** 09/16/2021 11:00  
**Receipt Date:** 09/16/2021 15:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	1.82	mg/L		0.729	DAA	09/25/21 07:25	09/26/21 09:01
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	09/22/21 12:33	09/22/21 15:30
<b>General Chemistry</b>	<b>Analytical Method: SM4500 NH3 F-11</b>				<b>Prep Method: SM 4500-Norg B</b>		
Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	09/25/21 07:25	09/26/21 09:01
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	1.82	mg/L		0.104	AW	09/24/21 14:01	09/24/21 14:01
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	<0.10	mg/L		0.10	AW	09/23/21 13:25	09/23/21 13:25
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L		2.00	AS	09/17/21 16:50	09/22/21 11:20
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<5	MPN/100 mL		5	DAA	09/16/21 15:00	09/17/21 12:00







# SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Monikaw</u>	Work C	1091703
------------------------	--------	---------

### PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: <u>  /  /  </u>
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	Received on Ice?: YES <input type="checkbox"/> NO <input type="checkbox"/>
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL <input type="checkbox"/> TC/EC <input type="checkbox"/> TC MPN <input type="checkbox"/> EC MPN <input type="checkbox"/> TC/EC MPN <input checked="" type="checkbox"/> N/A	

### PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>SPM TNSRV</u>	Samples Received on Ice? YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>
Date/Time Received: <u>9/18/12 1500</u>	Date Sampled: <u>9/18/12</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input type="checkbox"/> <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.0</u> °C	IR Gun ID: <u>  </u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

### PART C: Receipt Details Completed (if different from above): \_\_\_\_\_

Sample Receipt Criteria			Comments/Qualifiers (Required for Non-Conforming Items)	Signature	Date	Time
Chain of custody documents included with samples?	YES	NO	Comments:			
COC form is properly signed in relinquished/received sections?	YES	NO	Comments:			
Sample containers intact and sealed?	YES	NO	Circle Applicable: Damaged Container <input type="checkbox"/> Leaking Container <input type="checkbox"/> Custody Seal Broken <input type="checkbox"/> Other: _____			
Number of containers received matches number indicated on COC?	YES	NO	Sample IDs and Containers Affected:			
Sample IDs on COC match IDs on bottles?	YES	NO	Sample IDs and Containers Affected:			
Date and time on COC match date and time on bottles?	YES	NO	Sample IDs and Containers Affected:			
Samples received within holding time?	YES	NO	Sample IDs and Containers Affected:			
Samples received at appropriate pH for analysis requested?	YES	NO	Sample IDs and Containers Affected and Observed pH:			
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	YES	NO	For non-WV samples outside of thermal preservation range, sampled same day and received on ice are considered acceptable as long as the cooling process has begun.			
Adequate sample volume received?	YES	NO	Analyses Affected:			
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	NO <input checked="" type="checkbox"/>	Sample IDs and Containers Affected:			
Other Comments:				Deficiency Log Created:		
				YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>		

Effective Date: \_\_\_\_\_