

Moniteau School District  
Maintenance Department  
Moniteau High School  
Wastewater Treatment Facility  
Monthly Report for August 2023



COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONTEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341  
PERMIT NUMBER

001  
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 08/01/2023  
 DMR Effective To: 08/31/2023  
 Permit Expires: 01/31/2028  
 Permit Application Due: 08/04/2027  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2023	08	01	2023	08	31

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	7.53		***	***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	4.0		***	***	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	7.17		***	8.21	Daily when Discharging	Grab
	PERMIT REQUIREMENT	6.0		***	9.0	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***	Daily Max	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		5.0	7.0	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***		30.0	60.0	2/month	Grab
	PERMIT REQUIREMENT	***		Avg Mo	IMAX	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	<.165	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report	mg/L	2/month	Grab
Flow (50050)	SAMPLE MEASUREMENT	***		***	4.93	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		Monitor & Report	µm/cm²	Daily when Discharging	Grab
Fecal Coliform (74055)	SAMPLE MEASUREMENT	.003608		***	***	1/week	Measured
	PERMIT REQUIREMENT	***		Monitor & Report	***	1/week	Measured
	SAMPLE MEASUREMENT	***		***	<1.0	2/month	Grab
	PERMIT REQUIREMENT	***		200	1000	2/month	Grab
		***		Geo Mean	IMAX	2/month	Grab

**DISCHARGE MONITORING REPORT (DMR)**

PARAMETER	SAMPLE MEASUREMENT PERMIT REQUIREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)		***		<2.00	<2.00		2/month	Grab
	Facility Comments	***		25.0 Avg Mo	50.0 IMAX	mg/L	2/month	Grab
<b>COMMENT DETAILS</b>								
COMMENTS		OPERATOR NAME			OPERATOR CERTIFICATION NUMBER		OPERATOR CONTACT NUMBER	

High 8.74 #2 8/17

Nitrogen	$\frac{8.13}{14.5}$	$\frac{8.17}{0.751}$	$15.251 \div 2 = 7.6255$
Ammonia	$< 0.165$	$< 0.165$	$< 0.165$
TKN	0.710	$< 0.625$	$1.335 \div 2 = 0.6675$
TSS	7	$< 3$	$10 \div 2 = 5$
Nitrate/Nit.	13.8	0.751	$14.551 \div 2 = 7.2755$
Phos	1.1	0.39	$1.49 \div 2 = 0.745$
COD	$< 2.00$	$< 2.00$	$< 2.00$
Fecal	$< 1$	$< 1$	$< 1$

UV 4.93 Aug.

Moniteau High School Sewage Treatment Plant  
 Permit # PA0091341

Daily Operations Worksheet

Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Meter Reading	Time	Operator
8/1	Tues	7.35	7.95			UV	August	2023	
8/2	WED	AERATION		AERATION		5.2		10:30 A	JEFF C
8/3	Thurs	7.20	7.86	7.46	8.03	5.2		8:30 P	JEFF C
8/7	Mon	7.17	7.53	7.31	7.97	5.0		9:00 A	JEFF C
8/8	Tues	7.27	8.04	7.26	8.05	5.2		1:00 P	JEFF C
8/9	WED	7.32	8.11	7.35	8.08	4.9		2:00 P	JEFF C
8/10	Thurs	7.47	8.15	7.38	8.10	4.8		10:00 A	JEFF C
8/14	Mon	7.53	8.29	7.42	8.11	5.0		9:30 A	JEFF C
8/15	Tues	AERATION		AERATION		5.0		8:00 A	JEFF C
8/16	WED	8.06	8.21	7.67	8.21	4.9		10:30 A	JEFF C
8/17	Thurs	8.21	8.13	7.89	8.52	5.0		9:00 A	JEFF C
8/21	Mon	8.00	8.23	8.05	8.76	5.3		8:30 A	JEFF C
8/22	Tues	8.01	8.17	7.99	8.61	4.7		10:00 A	JEFF C
8/23	Wed	AERATION		AERATION		4.9		10:15 A	JEFF C
8/24	Thurs	7.90	8.21	8.01	8.58	4.9		1:00 AM	JEFF C
8/25	Fri	8.02	8.19	7.97	8.46	4.7		9:00 AM	JEFF C
8/28	Mon	8.18	8.02	8.21	8.18	4.8		6:00 AM	JEFF C
8/29	Tues	8.12	7.99	7.95	7.86	4.8		9:00 AM	JEFF C
8/30	Wed	8.01	7.98	7.93	7.90	4.8		8:00 AM	JEFF C
8/31	Thurs	7.95	8.00	AERATION	4.8	4.8		10:00 AM	JEFF C
				7.97	8.03	4.8		10:30 AM	JEFF C
							4.93	Aug.	
							98.7		

\*

\*



JEFFREY CAMPBELL <jcampbell@moniteau.org>

## Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Mon, Sep 11, 2023 at 2:07 PM

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL  
**Permit Number:** PA0091341  
**Report Frequency:** Monthly  
**Report Type:** DMR  
**Reporting Period:** 08/01/2023-08/31/2023  
**Report Due Date:** 09/28/2023

**Submitted By:** Jeffrey Campbell  
**Submission Id:** 413422  
**Submission Status:** Received  
**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

17 August 2023

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 23H0634**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23H0634-01	Waste Water	08/03/2023 10:00	8/3/23 14:40	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- Q Duplicate analysis did not meet laboratory acceptance criteria.
- LL Laboratory control sample below acceptance criteria, result may be biased low.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By


*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





# SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Minitec</u>	Work Order	 23H0634
------------------------	------------	--

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>(N/A)</u>	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JD / COSSU</u>	Samples Received on Ice? <u>(YES)</u> NO
Date/Time Received: <u>8/3 123</u>	Date Sampled: <u>8/3 123</u>
Method of Delivery: FedEx UPS Client Drop off <u>(ESL courier)</u> Other: _____	
Sample Receipt Temperature: <u>3.9</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>(PA)</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>(NO)</u>

## PART C: Receipt Details

Completed (if different from above): \_\_\_\_\_ Signature \_\_\_\_\_ Date / / Time \_\_\_\_\_

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<u>(YES)</u>	NO	Comments:
COC form is properly signed in relinquished/received sections?	<u>(YES)</u>	NO	Comments:
Sample containers intact and sealed?	<u>(YES)</u>	NO	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Samples received within holding time?	<u>(YES)</u>	NO	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<u>(YES)</u>	NO	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<u>(YES)</u>	NO	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<u>(YES)</u>	NO	Analyses Affected:
VOA vial headspace < 6 mm?	YES NO <u>(N/A)</u>		Sample IDs and Containers Affected:
Other Comments:			
			Deficiency Log Created: YES <u>(NO)</u>


For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.




**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

**SAMPLE REQUEST & CHAIN OF CUSTODY**


3 of 4  
 ADDQUARTERS  
 13 Philadelphia St.  
 ana, PA 15701  
 (412) 465-TEST  
 FAX: (724) 465-4209




SOUTHERN DIVISION  
 1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 (724) 258-TEST  
 FAX: (724) 258-8376



NORTHERN DIVISION  
 435 Broad  
 Montbours  
 (570) 321-  
 FAX: (570



EST DIVISION  
 Street  
 PA 16150  
 EST  
 (724) 465-4209



FOR INTERNAL LABORATORY USE

Sample Identification	ESL#	Composite		Date	Grab Time	Matrix	# of Containers	Container Type	Analysis Requested
		Date on/off	Time on/off						
Effluent Outfall 001	23H0634			8/3/03	10:00 AM	WW	1	Poly 1000mL Preservative	CBOD, TSS NH
						WW	1	Poly 500mL H2SO4	
						WW	1	Sterile Plastic 125mL Na2S2O3	Amonia, Total Nitrogen, Total Phosphorus FC
									Fecal Coliform

UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
 THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.  
 IF UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY  
 TORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Project Notes:

Wastewater

Company/Name: MONTEAU SCHOOL DISTRICT

Contact Person: JEFFREY CAMPBELL

Address: 1810 WEST SUNBURY ROAD  
 WEST SUNBURY, PA 16061  
 724-406-4426  
 Email: jcampbell@monteau.org

Signed By: (Signature) [Signature] Date/ Time 8/3/03 10:00 AM  
 Witnessed By: (Signature) [Signature] Date/ Time 8/3/03 10:00 AM  
 Submitted By: (Signature) [Signature] Date/ Time 8/3/03 10:00 AM

Received By: (Signature) [Signature] Date/ Time 8/3/03 10:00 AM  
 Received By: (Signature) [Signature] Date/ Time 8/3/03 10:00 AM  
 Received By: (Signature) [Signature] Date/ Time 8/3/03 10:00 AM  
 Received By: (Signature) [Signature] Date/ Time 8/3/03 10:00 AM

Correct Containers Y/N/NA  
 Receipt Temperature  
 Date/ Time



**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/17/2023 16:30

Lab Sample ID#: 23H0634-01  
 Sample Type: Waste Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Effluent Outfall 001

Sample Date: 08/03/2023 10:00  
 Receipt Date: 08/03/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time	
General Chemistry Total Nitrogen	14.5	mg/L			1.66	AW	08/16/23 09:52	08/16/23 09:52	
Analytical Method: *** DEFAULT SPECIFIC METHOD									
General Chemistry Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	08/08/23 15:01	08/09/23 01:25	
Analytical Method: ASTM6919-17									
General Chemistry Total Kjeldahl Nitrogen	0.710	mg/L			0.625	AW	08/12/23 08:36	08/12/23 08:36	
Analytical Method: EPA 351.2 2.0									
General Chemistry Total Suspended Solids	7	mg/L	LL, Q		5	AH	08/08/23 12:15	08/09/23 14:12	
Analytical Method: SM2540 D-15									
General Chemistry Nitrate/Nitrite	13.8	mg/L			1.04	AW	08/16/23 09:52	08/16/23 09:52	
Analytical Method: SM4500-NO3 E-16 (discrete)									
General Chemistry Phosphorus	1.1	mg/L			1.0	JMS	08/15/23 13:54	08/15/23 13:54	
Analytical Method: SM4500-P E-11									
General Chemistry Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, SS		2.00	ATJ/TW	08/04/23 15:35	08/09/23 09:25	
Analytical Method: SM5210 B-16									
Microbiology Fecal Coliforms	<1	MPN/100 mL			1	JP	08/03/23 14:54	08/04/23 11:30	
Analytical Method: Colilert-18									



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

30 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 23H2496  
Project: Wastewater  
Project Description: Wastewater

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23H2496-01	Waste Water	08/17/2023 11:00	8/17/23 14:45	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- LL Laboratory control sample below acceptance criteria, result may be biased low.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/30/2023 11:41

Lab Sample ID#: 23H2496-01  
Sample Type: Waste Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Effluent Outfall 001

Sample Date: 08/17/2023 11:00  
Receipt Date: 08/17/2023 14:45

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: *** DEFAULT SPECIFIC METHOD</b>							
Total Nitrogen	0.751	mg/L			0.729	AW	08/25/23 09:41	08/25/23 09:41
	<b>Prep Method: [CALC]</b>							
<b>General Chemistry</b>	<b>Analytical Method: ASTM6919-17</b>							
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	08/23/23 09:41	08/23/23 09:41
	<b>Prep Method: No Prep - WetChem</b>							
<b>General Chemistry</b>	<b>Analytical Method: EPA 351.2 2.0</b>							
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	08/25/23 09:41	08/25/23 09:41
	<b>Prep Method: SM 4500-Norg B</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-15</b>							
Total Suspended Solids	<5	mg/L	LL		5	AH	08/24/23 12:37	08/24/23 12:37
	<b>Prep Method: No Prep - WetChem</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-16 (discrete)</b>							
Nitrate/Nitrite	0.751	mg/L			0.104	AW	08/24/23 13:58	08/24/23 13:58
	<b>Prep Method: No Prep - WetChem</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>							
Phosphorus	0.39	mg/L			0.20	JMS	08/29/23 14:49	08/29/23 14:49
	<b>Prep Method: SM 4500 P B</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-16</b>							
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	SS		2.00	ATJ	08/18/23 10:22	08/23/23 08:58
	<b>Prep Method: No Prep - WetChem</b>							
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>							
Fecal Coliforms	<1	MPN/100 mL			1	JP	08/17/23 14:39	08/18/23 11:30
	<b>Prep Method: No Prep - Micro</b>							

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

01 of 4  
 02  
 03  
 04  
 05  
 06  
 07  
 08  
 09  
 10  
 11  
 12  
 13  
 14  
 15  
 16  
 17  
 18  
 19  
 20  
 21  
 22  
 23  
 24  
 25  
 26  
 27  
 28  
 29  
 30  
 31  
 32  
 33  
 34  
 35  
 36  
 37  
 38  
 39  
 40  
 41  
 42  
 43  
 44  
 45  
 46  
 47  
 48  
 49  
 50  
 51  
 52  
 53  
 54  
 55  
 56  
 57  
 58  
 59  
 60  
 61  
 62  
 63  
 64  
 65  
 66  
 67  
 68  
 69  
 70  
 71  
 72  
 73  
 74  
 75  
 76  
 77  
 78  
 79  
 80  
 81  
 82  
 83  
 84  
 85  
 86  
 87  
 88  
 89  
 90  
 91  
 92  
 93  
 94  
 95  
 96  
 97  
 98  
 99  
 100

HEADQUARTERS  
 13 Philadelphia St.  
 Lancaster, PA 17601  
 (724) 463-TEST  
 FAX: (724) 465-4209

SOUTHERN DIVISION  
 1276 Bentleyville Road  
 Van Voorhis, PA 15966  
 (724) 258-TEST  
 FAX: (724) 258-8376

NORTHWEST DIVISION  
 950 Main Street  
 Sharpshoof, PA 16150  
 (724) 463-TEST  
 FAX: (724) 465-4209

FOR INTERNAL LA

23H2496

Sample Identification	ESL#	Composite		Sample Type		Matrix	# of Containers	Container Type	Analysis Requested
		Date on/off	Time on/off	Date	Grab Time				
Effluent Outfall 001	23H2496			8/17/23	11:00 AM	WW	1	Poly 500mL H2SO4	Ammonia, Total Nitrogen, Total Phosphorus
						WW	1	None	CBOD, TSS
						WW	1	Poly 1000mL	
						WW	1	Sterile Plastic 125mL Na2S2O3	Fecal Coliform

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
 THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)  
 THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY  
 ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Requested By: (Signature) [Signature]  
 Date/ Time 8/17/23 11:00 AM

Requested By: (Signature) [Signature]  
 Date/ Time 8/17/23 1:01

Requested By: (Signature) [Signature]  
 Date/ Time 8/17/23 1:46

Received By: (Signature) [Signature]  
 Date/ Time 8/17/23 1:01

Received By: (Signature) [Signature]  
 Date/ Time 8/17/23 1:46

Received By: (Signature) [Signature]  
 Date/ Time 8/17/23 1:46

Project Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature \_\_\_\_\_

Company/Name: **MONITEAU SCHOOL DISTRICT**  
 Contact Person: **JEFFREY CAMPBELL**  
 Address: **1810 WEST SUNBURY ROAD**  
**WEST SUNBURY, PA 16061**  
 Phone / Cell: **724-406-4426**  
 Email: **jcambell@moniteau.org**



# SAMPLE RECEIPT AND REVIEW FORM

Client: McIntev Work C

Barcode: 23H2496

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: \_\_\_\_\_ Date/Time Received: / /

Method of Delivery: Client Drop-Off ESL Courier Other: \_\_\_\_\_ Received on Ice? YES NO

Sample Receipt Temperature: \_\_\_\_\_ °C IR Gun ID: \_\_\_\_\_

Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN N/A

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: 00382 Samples Received on Ice?  YES NO

Date/Time Received: 8/17/23 1445 Date Sampled: 8/17/23

Method of Delivery: FedEx UPS Client Drop off ESL courier Other: \_\_\_\_\_


Sample Receipt Temperature: 5.0 °C IR Gun ID: 3

Sample State of Collection: PA NY OH WV Other: \_\_\_\_\_ PWSID Compliance Drinking Water Samples: YES  NO

## PART C: Receipt Details Completed (if different from above):

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?				Comments:
COC form is properly signed in relinquished/received sections?				Comments:
Sample containers intact and sealed?				Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?				Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?				Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?				Sample IDs and Containers Affected:
Samples received within holding time?				Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?				Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?				For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?				Analyses Affected:
VOA vial headspace < 6 mm?				Sample IDs and Containers Affected:
Other Comments:				
				Deficiency Log Created: YES NO

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.



**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

30 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 23H2496**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23H2496-01	Waste Water	08/17/2023 11:00	8/17/23 14:45	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- LL Laboratory control sample below acceptance criteria, result may be biased low.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/30/2023 11:41

Lab Sample ID#: 23H2496-01  
 Sample Type: Waste Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Effluent Outfall 001


Sample Date: 08/17/2023 11:00  
 Receipt Date: 08/17/2023 14:45

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: *** DEFAULT SPECIFIC METHOD</b>							
Total Nitrogen	0.751	mg/L			0.729	AW	08/25/23 09:41	08/25/23 09:41
	<b>Prep Method: [CALC]</b>							
<b>General Chemistry</b>	<b>Analytical Method: ASTM6919-17</b>							
Ammonia as N	<0.165	mg/L		0.165	0.400	DAA	08/23/23 09:41	08/23/23 09:41
	<b>Prep Method: No Prep - WetChem</b>							
<b>General Chemistry</b>	<b>Analytical Method: EPA 351.2 2.0</b>							
Total Kjeldahl Nitrogen	<0.625	mg/L			0.625	AW	08/25/23 09:41	08/25/23 09:41
	<b>Prep Method: SM 4500-Norg B</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-15</b>							
Total Suspended Solids	<5	mg/L	LL		5	AH	08/24/23 12:37	08/24/23 12:37
	<b>Prep Method: No Prep - WetChem</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-16 (discrete)</b>							
Nitrate/Nitrite	0.751	mg/L			0.104	AW	08/24/23 13:58	08/24/23 13:58
	<b>Prep Method: No Prep - WetChem</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>							
Phosphorus	0.39	mg/L			0.20	JMS	08/29/23 14:49	08/29/23 14:49
	<b>Prep Method: SM 4500 P B</b>							
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-16</b>							
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	SS		2.00	ATJ	08/18/23 10:22	08/23/23 08:58
	<b>Prep Method: No Prep - WetChem</b>							
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>							
Fecal Coliforms	<1	MPN/100 mL			1	JP	08/17/23 14:39	08/18/23 11:30
	<b>Prep Method: No Prep - Micro</b>							



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

Page 3 of 4  
 3 Philadelphia St.  
 Philadelphia, PA 19101  
 (724) 463-TEST  
 (724) 465-4209



**SOUTHERN DIVISION**  
 1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 (724) 258-1-TEST  
 FAX: (724) 258-8376




**NORTHERN DIVISION**



23H2496

**NORTHWEST DIVISION**  
 950 Main Street  
 Sharpsville, PA 16150  
 (724) 463-TEST  
 FAX: (724) 465-4209



## SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESI #	Composite		Sample Type		Matrix	# of Containers	Container Type	Analysis Requested
		Date on/of	Time on/of	Date	Grab Time				
Effluent Outfall 001	23H2496					WW	1	Poly 1000mL Preservative	CBOD, TSS Ammonia, Total Nitrogen, Total Phosphorus Fecal Coliform
				8/17/23	11:00 AM	WW	1	Poly 500mL H2SO4	
						WW	1	Sterile Plastic 125mL Na2S2O3	
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>									
<p>Project Notes:  <b>Wastewater</b></p>									
<p>Company/Name:  <b>MONITEAU SCHOOL DISTRICT</b></p>									
<p>Contact Person:  <b>JEFFREY CAMPBELL</b></p>									
<p>Address:  <b>1810 WEST SUNBURY ROAD</b></p>									
<p>Phone / Cell:  <b>WEST SUNBURY, PA 16061</b></p>									
<p>Email:  <b>724-406-4426</b></p>									
<p><a href="mailto:jcampbell@moniteau.org">jcampbell@moniteau.org</a></p>									

Relinquished By: (Signature) *[Signature]* Date/ Time *8/16/23 1:01*  
 Relinquished By: (Signature) *[Signature]* Date/ Time *8/17/23 1:15*  
 Relinquished By: (Signature) *[Signature]* Date/ Time *8/17/23 11:00 AM*  
 Received By: (Signature) *[Signature]* Date/ Time *8/17/23 11:01*  
 Received By: (Signature) *[Signature]* Date/ Time *8/17/23 11:01*  
 Received By: (Signature) *[Signature]* Date/ Time *8/17/23 11:01*  
 Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature \_\_\_\_\_



### SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work C	 23H2496
-------------------------	--------	--

#### PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID:
Containers Removed by Satellite Lab for Analysis of: FE CAL TC/EC TC MPN EC MPN TC/EC MPN N/A	

#### PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JM 00382</u>	Samples Received on Ice? <input checked="" type="checkbox"/> YES NO
Date/Time Received: <u>8/17/23 1445</u>	Date Sampled: <u>8/17/23</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>5.0</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input checked="" type="checkbox"/> NO

#### PART C: Receipt Details Completed (if different from above): \_\_\_\_\_

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="checkbox"/> YES			Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/> YES			Comments:
Sample containers intact and sealed?	<input checked="" type="checkbox"/> YES			Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/> YES			Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/> YES			Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/> YES			Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="checkbox"/> YES			Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/> YES			Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/> YES			For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="checkbox"/> YES			Analyses Affected:
VOA vial headspace < 6 mm?	<input checked="" type="checkbox"/> YES			Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.

Moniteau School District  
Maintenance Department  
Moniteau High School  
Water Treatment Facility  
Monthly Report for August 2023

MONTH		MONITEAU HIGH SCHOOL WATER TREATMENT PLANT										
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME	
1	Tues	78.3	8,111	8,203,356	0.53	0.55	7.3	0.03	0	1.26	JEFF C	8:00 AM
2	Wed	70.5	11.26	8,213,779	0.54	0.56	7.3	0.02	0	1.19	JEFF C	2:00 PM
3	Thurs	71.1	10.84	8,213,779	0.54	0.56	7.3	0.02	0	1.19	JEFF C	7:00 AM
4	Fri											
5	SAT											
6	SUN											
7	Mon	77.4	8.21	8,213,779	0.53	0.55	7.3	0.02	0	1.18	JEFF C	8:00 AM
8	Tues	72.3	11.26	8,224,830	0.60	0.63	7.2	0.01	0	1.21	JEFF C	3:00 PM
9	Wed	72.9	10.46	8,224,830	0.58	0.61	7.2	0.01	0	1.21	JEFF C	10:00 AM
10	Thurs	73.4	9.03	8,224,830	0.59	0.62	7.2	0.01	0	1.21	JEFF C	9:00 AM
11	Fri											
12	SAT											
13	SUN											
14	Mon	73.1	9.91	8,235,035	0.79	1.01	7.2	0.02	0	1.39	JEFF C	8:00 AM
15	Tues	74.0	8.70	8,235,035	0.78	1.00	7.2	0.02	0	1.39	JEFF C	9:00 AM
16	Wed	70.5	11.04	8,247,360	0.80	1.01	7.2	0.01	0	1.21	JEFF C	2:00 PM
17	Thurs	71.1	8.03	8,247,360	0.81	0.99	7.2	0.01	0	1.20	JEFF C	8:30 AM
18	Fri											
19	SAT											
20	SUN											
21	Mon	67.4	11.40	8,282,484	0.97	0.99	7.2	0.00	0	1.17	JEFF C	9:00 AM
22	Tues	68.1	10.70	8,282,484	0.97	0.99	7.2	0.00	0	1.17	JEFF C	10:00 AM
23	Wed	69.0	9.21	8,282,484	0.96	0.99	7.2	0.00	0	1.17	JEFF C	9:00 AM
24	Thurs	71.0	8.36	8,282,484	0.96	0.98	7.2	0.00	0	1.17	JEFF C	9:00 AM
25	Fri	67.0	11.59	8,307,419	0.69	0.71	7.2	0.02	0	1.09	JEFF C	6:00 AM
26	SAT											
27	SUN											
28	Mon	70.9	9.90	8,307,419	0.68	0.71	7.2	0.02	0	1.09	JEFF C	8:00 AM
29	Tues	70.6	8.10	8,307,419	0.68	0.71	7.2	0.02	0	1.08	JEFF C	10:00 AM
30	Wed	68.3	10.54	8,321,427	0.75	0.79	7.2	0.01	0	0.99	JEFF C	2:00 PM
31	Thurs											

WATER Samples Sewage Samples 8, 203, 356 meter Reading 7/31/23



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 August 2023

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 23H0676  
 Project: Drinking Water Moniteau Jr/Sr - Monthly 802  
 Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23H0676-01	Drinking Water	08/03/2023 12:40	8/3/23 14:40	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/11/2023 14:56

Lab Sample ID#: 23H0676-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 802 Room 204 Sink

Sample Date: 08/03/2023 12:40  
 Receipt Date: 08/03/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>							
Analytical Method: SM4500-Cl G-11							
Chlorine, Free	0.780	mg/L		0.200	PS	08/03/23 12:40	08/03/23 12:40
Prep Method: No Prep - Field							
<b>Microbiology</b>							
Analytical Method: SM 9223 B-16							
Total Coliform	Absent	per 100 mL		1	JP	08/03/23 15:17	08/04/23 15:25
E. Coli	Absent	per 100 mL		1	JP	08/03/23 15:17	08/04/23 15:25
Prep Method: No Prep - Micro							

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957



## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	23H0676	8/3/03	12:40	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.78

704: Jan, Mar, May, Jul, Sept, Nov  
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

*Drinking Water Monteau Jr/Sr - Monthly*

<p>Sampled By: (Signature) <i>[Signature]</i> Date/Time <i>8/3/03 12:40</i></p> <p>Relinquished By: (Signature) <i>[Signature]</i> Date/Time <i>8/3/03 12:40</i></p> <p>Relinquished By: (Signature) _____ Date/Time _____</p> <p>Relinquished By: (Signature) _____ Date/Time _____</p> <p>Correct Preservations <i>Y/N/NA</i> Correct Containers <i>Y/N/NA</i></p>	<p>Received By: (Signature) <i>[Signature]</i> Date/Time <i>8-3-23 14:40</i></p> <p>Received By: (Signature) _____ Date/Time _____</p> <p>Received By: (Signature) _____ Date/Time _____</p> <p>Receipt Temperature <i>40#3</i></p>
<p>Company/Name: <b>MONTTEAU SCHOOL DISTRICT</b></p> <p>Address: <b>1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</b></p> <p>Contact Person: _____ Phone Number: _____ Cell Phone: <b>724-406-4426</b></p> <p>Email Address: <b>jcambell@monteau.org</b></p> <p>Billing Address: _____ PWSID: <b>5100324</b></p>	

*ice*



E-Government Application for Drinking Water Program  
 SAFE DRINKING WATER ACT  
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.78	080323	802		080323	D	1240	32382	23H0676-01	BROWNKA_278
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1240	32382	23H0676-01	BROWNKA_279





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

14 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 23H1698**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23H1698-01	Drinking Water	08/10/2023 12:35	8/10/23 15:50	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/14/2023 17:03

**Lab Sample ID#:** 23H1698-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 08/10/2023 12:35  
**Receipt Date:** 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>							
<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.550	mg/L		0.200	PS	08/10/23 12:35	08/10/23 12:35

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.55	081023	704		081023	D	1235	32382	23H1698-01	BROWNKA_876
5100324	1013	FREE CHLORINE	301	0.78	080323	802		080323	D	1240	32382	23H0676-01	BROWNKA_278
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1240	32382	23H0676-01	BROWNKA_279

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_591
5100324	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_593
5100324	2955	XYLENES - TOTAL (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_595
5100324	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_597
5100324	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_599
5100324	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_601
5100324	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_603
5100324	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_605
5100324	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_607
5100324	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_609
5100324	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_611
5100324	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_613



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 615
5100324	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 617
5100324	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 619
5100324	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 621
5100324	2989	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 623
5100324	2990	BENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 625
5100324	2991	TOLUENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 627
5100324	2992	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 629
5100324	2996	STYRENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 631

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE \_\_\_\_ OF \_\_\_\_

HEADQUARTER  
803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-8376

ORTHWEST DIVISION  
50 Main Street  
Harpersville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

23H1698

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 764	9811698			DW	Field	Field	Free Chlorine 0.55 mg/L

### ROTATION

- WK-1 - 704 Kitchen Sink
- WK-2 - 802 Room 204 Sink
- WK-3 - 803 Admin Sink
- WK-4 - 804 400 Hall RR Sink
- WK-5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:::

Drinking Water Monticau Jr/Sr - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time *8/10/13 15:50*

Relinquished By: (Signature) *[Signature]* Date/ Time *8/10/13 15:50*

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations  Y/N/NA Correct Containers  Y/N/NA Receipt Temperature *89.90°C*

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: \_\_\_\_\_

Cell Phone: **724-406-4426**

Email Address: **jcampbell@monticau.org**

Billing Address: \_\_\_\_\_

PWSID: **5100324**

*8/10/13*



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

18 August 2023

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 23H1611**  
**Project: Drinking Water Moniteau Jr/Sr - Lead and Copper**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Custodial Breakroom Sink	23H1611-01	Drinking Water	08/10/2023 05:00	8/10/23 15:50	
Faculty Restroom Sink	23H1611-02	Drinking Water	08/10/2023 05:10	8/10/23 15:50	
100 Hall South Mens RR Sink	23H1611-03	Drinking Water	08/10/2023 05:20	8/10/23 15:50	
Admin Office Breakroom Sink	23H1611-04	Drinking Water	08/10/2023 05:30	8/10/23 15:50	
300 Hall South Mens RR Sink	23H1611-05	Drinking Water	08/10/2023 05:40	8/10/23 15:50	
600 Hall Mens RR Sink	23H1611-06	Drinking Water	08/10/2023 05:50	8/10/23 15:50	
Cafeteria Kitchen Sink	23H1611-07	Drinking Water	08/10/2023 06:00	8/10/23 15:50	
400 Hall Mens RR Sink	23H1611-08	Drinking Water	08/10/2023 06:10	8/10/23 15:50	
100 Hall North Mens RR Sink	23H1611-09	Drinking Water	08/10/2023 06:20	8/10/23 15:50	
300 Hall North Mens RR Sink	23H1611-10	Drinking Water	08/10/2023 06:30	8/10/23 15:50	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1611-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Custodial Breakroom Sink

Sample Date: 08/10/2023 05:00  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		Analytical Method: EPA200.5 4.2				Prep Method: EPA 200.5 4.2	
Copper	0.050	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:17
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:17

Lab Sample ID#: 23H1611-02  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Faculty Restroom Sink

Sample Date: 08/10/2023 05:10  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		Analytical Method: EPA200.5 4.2				Prep Method: EPA 200.5 4.2	
Copper	0.051	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:20
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:20

Lab Sample ID#: 23H1611-03  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 100 Hall South Mens RR Sink

Sample Date: 08/10/2023 05:20  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		Analytical Method: EPA200.5 4.2				Prep Method: EPA 200.5 4.2	
Copper	0.049	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:35
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:35



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpshville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1611-04  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Admin Office Breakroom Sink

Sample Date: 08/10/2023 05:30  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		<b>Analytical Method: EPA200.5 4.2</b>					
Copper	0.063	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:38
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:38

**Prep Method: EPA 200.5 4.2**

Lab Sample ID#: 23H1611-05  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 300 Hall South Mens RR Sink

Sample Date: 08/10/2023 05:40  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		<b>Analytical Method: EPA200.5 4.2</b>					
Copper	0.085	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:40
Lead	0.0055	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:40

**Prep Method: EPA 200.5 4.2**

Lab Sample ID#: 23H1611-06  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 600 Hall Mens RR Sink

Sample Date: 08/10/2023 05:50  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		<b>Analytical Method: EPA200.5 4.2</b>					
Copper	0.049	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:42
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:42

**Prep Method: EPA 200.5 4.2**





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1611-07  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Cafeteria Kitchen Sink

Sample Date: 08/10/2023 06:00  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		<b>Analytical Method: EPA200.5 4.2</b>					
Copper	0.091	mg/L			<b>Prep Method: EPA 200.5 4.2</b>		
Lead	0.0099	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:57
				0.0025	ANO	08/14/23 11:39	08/15/23 10:57

Lab Sample ID#: 23H1611-08  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 400 Hall Mens RR Sink

Sample Date: 08/10/2023 06:10  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		<b>Analytical Method: EPA200.5 4.2</b>					
Copper	0.051	mg/L			<b>Prep Method: EPA 200.5 4.2</b>		
Lead	<0.0025	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:47
				0.0025	ANO	08/14/23 11:39	08/15/23 10:47

Lab Sample ID#: 23H1611-09  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 100 Hall North Mens RR Sink

Sample Date: 08/10/2023 06:20  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		<b>Analytical Method: EPA200.5 4.2</b>					
Copper	0.054	mg/L			<b>Prep Method: EPA 200.5 4.2</b>		
Lead	<0.0025	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:52
				0.0025	ANO	08/14/23 11:39	08/15/23 10:52



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1611-10  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: 300 Hall North Mens RR Sink

Sample Date: 08/10/2023 06:30  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>	<b>Analytical Method: EPA200.5 4.2</b>				<b>Prep Method: EPA 200.5 4.2</b>		
Copper	0.055	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:54
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:54

Monteau High School 1810 W. Sunbury Rd. West Sunbury Pa 16861

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

**SAMPLE REQUEST & CHAIN OF CUSTODY**

**ADQUARTERS**  
 803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209

**SOUTHERN DIVISION**  
 1276 Bentleyville Road  
 Van Voorhis, PA 15386  
 (724) 258-TEST  
 FAX: (724) 258-8376

**NORTHWEST DIVISION**  
 435 Bior  
 Monour  
 (970) 32  
 FAX: (9

FOR INTERNAL LABORATORY USE



Sample Identification

23H1611

ESL#

Sample Type

Matrix

# of Bottles

Container Type

Analysis Requested

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested			
		Date	Time							
(1) Custodian	Breakroom	SINK	01	8/10/03	05:00	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(2) Faculty	Restroom	SINK	02	11	05:16	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(3) 100 Hall	South Mens RR	SINK	03	11	05:30	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(4) Admin office	Breakroom	SINK	01	11	05:30	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(5) 300 Hall	South Mens RR	SINK	05	11	05:40	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(6) 600 Hall	Mens RR	SINK	02	11	05:50	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(7) Cafeteria	Kitchen	SINK	02	11	06:00	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(8) 400 Hall	Mens RR	SINK	02	11	06:10	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(9) 100 Hall	North Mens RR	SINK	01	11	06:30	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2
(10) 300 Hall	North Mens RR	SINK	10	11	06:30	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER	2

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).  
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:  
**Voluntary Non-Reportable Sampling**  
**Drinking Water Monteau Jr/Sr - Lead and Copper**

Sampled By: (Signature) *[Signature]* Date/Time 8/10/03 05:00 - 06:30

Relinquished By: (Signature) *[Signature]* Date/Time 8/10/03 12:35

Relinquished By: (Signature) *[Signature]* Date/Time 8/10/03 15:45

Relinquished By: (Signature) *[Signature]* Date/Time 8/10/03 15:45

Received By: (Signature) *[Signature]* Date/Time 8/10/03 15:45

Received By: (Signature) *[Signature]* Date/Time 8/10/03 15:45


Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature

Company/Name: MONTEAU SCHOOL DISTRICT  
 Address: 1810 WEST SUNBURY ROAD  
 WEST SUNBURY, PA 16061  
 JEFFREY CAMPBELL  
 Contact Person: JEFFREY CAMPBELL  
 Cell Phone: 724-406-4426  
 Email Address: jcampbell@monteau.org  
 Billing Address: [Blank]  
 PWSID: [Blank]  
 Nonreportable



# SAMPLE RECEIPT AND REVIEW FORM

1611

Client: <u>Moniteau</u>	Work  23H1611
-------------------------	---

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FECAL TC/EC TC MPN EC MPN TC/EC MPN <u>N/A</u>	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>SLC/ESSV</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>8/10/03 13.5</u>	Date Sampled: <u>8/10/03</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>3.0</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <u>NO</u>

## PART C: Receipt Details

Completed (if different from above): \_\_\_\_\_ Signature \_\_\_\_\_ / Date / Time

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="radio"/>	<input type="radio"/>	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="radio"/>	<input type="radio"/>	Comments:
Sample containers intact and sealed?	<input checked="" type="radio"/>	<input type="radio"/>	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="radio"/>	<input type="radio"/>	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="radio"/>	<input type="radio"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="radio"/>	<input type="radio"/>	Analyses Affected:
VOA vial headspace < 6 mm?	<input type="radio"/>	<input checked="" type="radio"/>	Sample IDs and Containers Affected:
Other Comments:			
			Deficiency Log Created: YES <input checked="" type="radio"/> NO

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.



# INVOICE

# 2318034

**Invoice To**

Jeffrey Campbell  
Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Remit To**

Accounts Receivable  
Environmental Service Laboratories, Inc.  
1802 Philadelphia Street  
Indiana, PA 15701

**Sample Received**

08/10/2023

**PO Number**

**Invoiced On**

08/18/2023

**Project Manager**

Kirsten Conoran

**Terms**

Due Upon Receipt

**Project Description(s)**

Drinking Water

**Project(s)**

Drinking Water Dassa McKinney - Lead and Copper

Work Order(s)		Work Order(s)	Total Cost
23H1616		\$450.00	\$450.00
Additional Items		Item Cost	Total Cost
Quantity	Description		
1	7% Inflationary Adjustment		\$31.71
1	Aqueous Sample Disposal Fee, per Work Order	\$3.00	\$3.00
<b>Invoice Total:</b>			<b>\$484.71</b>

During the past year ESL, like so many companies, has experienced rising costs across our supply chain, including raw material and services. Although ESL has been absorbing cost increases through 2021, effective January 1, 2022 we will need to pass along a price appreciation on some products and services that may apply to you. ESL continues to focus on providing superior quality and outstanding customer care. Our entire team at ESL sincerely appreciates your continued support.

Standard Rush Charges: 1-2days 100%, 3-4days 75%, 5-6days 50%, 7-8days 25%  
Interest on past due balances at 18% APR.  
Please direct inquiries to Accounts Receivable at ar@envlabs.com or (724) 463-8378.



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

18 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 23H1616  
Project: Drinking Water Dassa McKinney - Lead and Copper  
Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Office Sink	23H1616-01	Drinking Water	08/10/2023 05:10	8/10/23 15:50	
Classroom 107 Sink	23H1616-02	Drinking Water	08/10/2023 05:13	8/10/23 15:50	
Classroom 201 Sink	23H1616-03	Drinking Water	08/10/2023 05:16	8/10/23 15:50	
Classroom 215 Sink	23H1616-04	Drinking Water	08/10/2023 05:19	8/10/23 15:50	
Classroom 313 Sink	23H1616-05	Drinking Water	08/10/2023 05:22	8/10/23 15:50	
Water Treatment Room	23H1616-06	Drinking Water	08/10/2023 05:25	8/10/23 15:50	
Classroom 408 Sink	23H1616-07	Drinking Water	08/10/2023 05:27	8/10/23 15:50	
Classroom 506 Sink	23H1616-08	Drinking Water	08/10/2023 05:30	8/10/23 15:50	
Classroom 606 Sink	23H1616-09	Drinking Water	08/10/2023 05:33	8/10/23 15:50	
Cafeteria Kitchen Sink	23H1616-10	Drinking Water	08/10/2023 05:37	8/10/23 15:50	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Data Qualifiers/Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1616-01  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Office Sink

Sample Date: 08/10/2023 05:10  
Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		Analytical Method: EPA200.5 4.2			Prep Method: EPA 200.5 4.2		
Copper	0.12	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:59
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:59

Lab Sample ID#: 23H1616-02  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Classroom 107 Sink

Sample Date: 08/10/2023 05:13  
Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		Analytical Method: EPA200.5 4.2			Prep Method: EPA 200.5 4.2		
Copper	0.15	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 10:22
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 10:22

Lab Sample ID#: 23H1616-03  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Classroom 201 Sink

Sample Date: 08/10/2023 05:16  
Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>		Analytical Method: EPA200.5 4.2			Prep Method: EPA 200.5 4.2		
Copper	0.10	mg/L		0.002	ANO	08/14/23 11:39	08/15/23 11:01
Lead	<0.0025	mg/L		0.0025	ANO	08/14/23 11:39	08/15/23 11:01



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1616-04  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Classroom 215 Sink

Sample Date: 08/10/2023 05:19  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>	<b>Analytical Method: EPA200.5 4.2</b>				<b>Prep Method: EPA 200.5 4.2</b>		
Copper	0.13	mg/L		0.002	ANO	08/15/23 04:42	08/15/23 11:33
Lead	<0.0025	mg/L		0.0025	ANO	08/15/23 04:42	08/15/23 11:33

Lab Sample ID#: 23H1616-05  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Classroom 313 Sink

Sample Date: 08/10/2023 05:22  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>	<b>Analytical Method: EPA200.5 4.2</b>				<b>Prep Method: EPA 200.5 4.2</b>		
Copper	0.098	mg/L		0.002	ANO	08/15/23 04:42	08/15/23 11:17
Lead	<0.0025	mg/L		0.0025	ANO	08/15/23 04:42	08/15/23 11:17

Lab Sample ID#: 23H1616-06  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Water Treatment Room

Sample Date: 08/10/2023 05:25  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>	<b>Analytical Method: EPA200.5 4.2</b>				<b>Prep Method: EPA 200.5 4.2</b>		
Copper	0.071	mg/L		0.002	ANO	08/15/23 04:42	08/15/23 11:19
Lead	<0.0025	mg/L		0.0025	ANO	08/15/23 04:42	08/15/23 11:19





**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1616-07  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Classroom 408 Sink

Sample Date: 08/10/2023 05:27  
Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>							
Analytical Method: EPA200.5 4.2							
Copper	0.091	mg/L			ANO	08/15/23 04:42	08/15/23 11:21
Lead	<0.0025	mg/L		0.002	ANO	08/15/23 04:42	08/15/23 11:21
				0.0025			
Prep Method: EPA 200.5 4.2							

Lab Sample ID#: 23H1616-08  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Classroom 506 Sink

Sample Date: 08/10/2023 05:30  
Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>							
Analytical Method: EPA200.5 4.2							
Copper	0.077	mg/L			ANO	08/15/23 04:42	08/15/23 11:24
Lead	<0.0025	mg/L		0.002	ANO	08/15/23 04:42	08/15/23 11:24
				0.0025			
Prep Method: EPA 200.5 4.2							

Lab Sample ID#: 23H1616-09  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Client  
Client Sample ID: Classroom 606 Sink

Sample Date: 08/10/2023 05:33  
Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>							
Analytical Method: EPA200.5 4.2							
Copper	0.079	mg/L			ANO	08/15/23 04:42	08/15/23 11:26
Lead	<0.0025	mg/L		0.002	ANO	08/15/23 04:42	08/15/23 11:26
				0.0025			
Prep Method: EPA 200.5 4.2							



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/18/2023 12:42

Lab Sample ID#: 23H1616-10  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Client  
 Client Sample ID: Cafeteria Kitchen Sink

Sample Date: 08/10/2023 05:37  
 Receipt Date: 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Total Metals</b>	<b>Analytical Method: EPA200.5 4.2</b>				<b>Prep Method: EPA 200.5 4.2</b>		
Copper	0.10	mg/L		0.002	ANO	08/15/23 04:42	08/15/23 11:28
Lead	<0.0025	mg/L		0.0025	ANO	08/15/23 04:42	08/15/23 11:28

DASSA McKinney Elem. School 391 Hooker Rd, West Sunbury PA  
 ENVIRONMENTAL SERVICE LABORATORIES, INC.  
 SAMPLE REQUEST & CHAIN OF CUSTODY 3E 1 OF 1 16061

HEADQUARTER  
 803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4208

SOUTHERN DIVISION  
 1276 Bentleyville Road  
 Van Voorhis, PA 15386  
 (724) 258-TEST  
 FAX: (724) 258-8376

NORTHERN  
 435 Broad  
 Montoursvi  
 (570) 321-1  
 FAX: (570) 321-1111

FOR INTERNAL LABORATORY USE ONLY



Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
(1) OFFICE SINK	23H1616			DW	1	PLASTIC LITER PRESERVATIVE	LEAD AND COPPER 42
(2) CLASSROOM 107 SINK	01	8/16/23	5:10am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(3) CLASSROOM 201 SINK	02	11	5:13am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(4) CLASSROOM 215 SINK	03	11	5:16am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(5) CLASSROOM 313 SINK	04	11	5:19am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(6) WATER TREATMENT ROOM	05	11	5:22am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(7) CLASSROOM 408 SINK	06	11	5:25am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(8) CLASSROOM 506 SINK	07	11	5:27am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(9) CLASSROOM 606 SINK	08	11	5:30am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(10) KITCHEN SINK	09	11	5:33am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42
(10) KITCHEN SINK	11	11	5:37am	DW	1	PLASTIC LITER HNO3	LEAD AND COPPER 42

THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1.0% PER ANNUM) ON THE MAXIMUM ALLOWED BY LAW. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:  
 Drinking Water Dassa McKinney - Lead and Copper (10)

Signature: *[Signature]*  
 Date: 8/16/23 10:26  
 Inquired By: (Signature) *[Signature]*  
 Date: 8/16/23 15:58


Signature: *[Signature]*  
 Date: 8/16/23 15:58  
 Received By: (Signature) *[Signature]*  
 Date: 8/16/23 15:58

Company Name: MONTICAU SCHOOL DISTRICT  
 Address: 391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 JEFFREY CAMPBELL  
 Contact Person: JEFFREY CAMPBELL  
 Phone Number: 724-406-4426  
 Cell Phone: 724-406-4426  
 Email Address: jcampbell@monticau.org  
 Billing Address: jcampbell@monticau.org  
 PWSID: 5100316



# SAMPLE RECEIPT AND REVIEW FORM

1016

Client: <u>Monitow</u>	Work Order:  23H1616
------------------------	---

## PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID:	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: <input type="checkbox"/> FECAL <input type="checkbox"/> TC/EC <input type="checkbox"/> TC MPN <input type="checkbox"/> EC MPN <input type="checkbox"/> TC/EC MPN <input checked="" type="checkbox"/> N/A	

## PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>ES10133U</u>	Samples Received on Ice? <input checked="" type="checkbox"/> YES NO
Date/Time Received: <u>8/10/13 15:50</u>	Date Sampled: <u>8/10/13</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	
Sample Receipt Temperature: <u>22</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <input checked="" type="checkbox"/> PA NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input checked="" type="checkbox"/> NO

## PART C: Receipt Details

Completed (if different from above): \_\_\_\_\_ Signature \_\_\_\_\_ Date / / Time \_\_\_\_\_

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
Sample containers intact and sealed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Analyses Affected:
VOA vial headspace < 6 mm?	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Sample IDs and Containers Affected:
Other Comments:	YES NO <input checked="" type="checkbox"/> N/A		
			Deficiency Log Created: YES <input checked="" type="checkbox"/> NO

For the following test methods, pH is measured and documented by the analysts at the bench level: Oil & Grease/TPH, BOD/CBOD, Phenolics, NO3+NO2, Alkalinity, Total Phosphorus, and all Organics methods.



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

24 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 23H2529**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23H2529-01	Drinking Water	08/17/2023 10:50	8/17/23 14:24	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/24/2023 14:16

**Lab Sample ID#:** 23H2529-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803 Admin Sink

**Sample Date:** 08/17/2023 10:50  
**Receipt Date:** 08/17/2023 14:24

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	1.10	mg/L		0.200	PS	08/17/23 10:50	08/17/23 10:50

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E   1   OF   1  

**HEADQUARTER**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

**NORTHERN**  
435 Broad  
Montoursville  
(370) 321-5  
FAX: (570) 321-1331



N

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL #	Sample Type		Matrix	# of Bottles	Field	Container Type Preservative	Analysis Requested
		Grab	Time					
Distribution: <u>803</u>	<u>23H2529</u>							
		<u>8123</u>	<u>1058</u>	DW			Field	Free Chlorine <u>1.10</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).  
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Monteau Jr/Sr - Weekly**

<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>8123 08 1050</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>8123 05 1055</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Correct Preservations Y / N / NA _____ Correct Containers Y / N / NA _____</p>	<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>8-17-23 1424</u></p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Receipt Temperature _____</p>
<p>Company/Name: <b>MONTEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: _____</p> <p>Email Address: <b>jcambell@monteau.org</b></p> <p>Billing Address: _____</p> <p>PWSID: <b>5100324</b></p>	

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.55	081023	704		081023	D	1235	32382	23H1698-01	BROWNKA_876
5100324	1013	FREE CHLORINE	301	0.78	080923	802		080323	D	1240	32382	23H0676-01	BROWNKA_278
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1240	32382	23H0676-01	BROWNKA_279
5100324	1013	FREE CHLORINE	301	1.1	081723	803		081723	D	1050	32382	23H2529-01	BROWNKA_1588

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_591
5100324	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_593
5100324	2955	XYLENES - TOTAL (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_595
5100324	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_597
5100324	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_599
5100324	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_601
5100324	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_603
5100324	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_605
5100324	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_607
5100324	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_609
5100324	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_611



**5100324: MONITEAU JR/SR HIGH SCHOOL**  
**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 613
5100324	2983	1,2-DICHLOROPROPANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 615
5100324	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080323	101		080323	E	1245	32382	23H0635-01	BROWNKA 617
5100324	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 619
5100324	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080323	101		080323	E	1245	32382	23H0635-01	BROWNKA 621
5100324	2989	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 623
5100324	2990	BENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 625
5100324	2991	TOLUENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 627
5100324	2992	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 629
5100324	2996	STYRENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 631



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

29 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 23H3272**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23H3272-01	Drinking Water	08/24/2023 10:50	8/25/23 9:25	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/29/2023 08:29

**Lab Sample ID#:** 23H3272-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 08/24/2023 10:50  
**Receipt Date:** 08/25/2023 09:25

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.750	mg/L		0.200	PS	08/24/23 10:50	08/24/23 10:50

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.55	081023	704		081023	D	1235	32382	23H1698-01	BROWNKA_876
5100324	1013	FREE CHLORINE	301	0.78	080323	802		080323	D	1240	32382	23H0676-01	BROWNKA_278
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1240	32382	23H0676-01	BROWNKA_279
5100324	1013	FREE CHLORINE	301	1.1	081723	603		081723	D	1050	32382	23H2529-01	BROWNKA_1588
5100324	1013	FREE CHLORINE	301	0.75	082423	804		082423	D	1050	32382	23H3272-01	BROWNKA_2588

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_591
5100324	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_593
5100324	2955	XYLENES - TOTAL (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_595
5100324	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_597
5100324	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_599
5100324	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_601
5100324	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_603
5100324	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_605
5100324	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_607
5100324	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_609



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 611
5100324	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 613
5100324	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 615
5100324	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 617
5100324	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 619
5100324	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 621
5100324	2989	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 623
5100324	2990	BENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 625
5100324	2991	TOLUENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 627
5100324	2982	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 629
5100324	2996	STYRENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 631

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 483-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Vortis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

FOR INTERNAL LABORATORY USE ONLY

WEST DIVISION  
10 Main Street  
Bristolville, PA 16010  
(724) 483-TEST  
FAX: (724) 465-4209



Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>SOL</u>	<u>754572</u>			DW	Field	Field	Free Chlorine <u>0.75</u> mg/L

- ROTATION
- WK 1 - 704 Kitchen Sink
  - WK 2 - 802 Room 204 Sink
  - WK 3 - 803 Admin Sink
  - WK 4 - 804 400 Hall RR Sink
  - WK 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

*Drinking Water Monteau Jr/Sr - Weekly*

Sampled By: (signature) [Signature] Date/ Time 8/21/08 08:10:50

Relinquished By: (signature) [Signature] Date/ Time 8/21/08 08:13:57

Relinquished By: (signature) [Signature] Date/ Time 8/21/08 08:13:57

Relinquished By: (signature) [Signature] Date/ Time 8/21/08 08:13:57

Relinquished By: (signature) [Signature] Date/ Time 8/21/08 08:13:57

Correct Preservations Y/N (NA) Correct Containers Y/N (NA) Receipt Temperature     

Company/Name: **MONTICAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD**  
**WEST SUNBURY, PA 16061**  
**JEFFREY CAMPBELL**  
 Contact Person:  
 Phone Number:  
 Cell Phone: **724-406-4426**  
 Email Address: **jcampbell@monticau.org**  
 Billing Address:  
 PWSID: **5100324**



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

06 September 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 23H3832**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23H3832-01	Drinking Water	08/31/2023 10:20	8/31/23 13:10	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Data Qualifiers/Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 09/06/2023 15:08

**Lab Sample ID#:** 23H3832-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul SOMogyi  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 08/31/2023 10:20  
**Receipt Date:** 08/31/2023 13:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>						
Chlorine, Free	0.560	mg/L		0.200	PS	08/31/23 10:20	08/31/23 10:20
					<b>Prep Method: No Prep - Field</b>		





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.55	081023	704		081023	D	1235	32382	23H1698-01	BROWNKA_876
5100324	1013	FREE CHLORINE	301	0.78	080323	802		080323	D	1240	32382	23H0676-01	BROWNKA_278
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1240	32382	23H0676-01	BROWNKA_279
5100324	1013	FREE CHLORINE	301	1.1	081723	803		081723	D	1050	32382	23H2529-01	BROWNKA_1588
5100324	1013	FREE CHLORINE	301	0.75	082423	804		082423	D	1050	32382	23H3272-01	BROWNKA_2588
5100324	1013	FREE CHLORINE	301	0.56	083123	804		083123	D	1020	32382	23H3832-01	BROWNKA_3556

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080323	101		080323	E	1245	32382	23H0635-01	BROWNKA_591
5100324	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_593
5100324	2955	XYLENES - TOTAL (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_595
5100324	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_597
5100324	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_599
5100324	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_601
5100324	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080323	101		080323	E	1245	32382	23H0635-01	BROWNKA_603
5100324	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_605
5100324	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA_607



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL  
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Deflection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 609
5100324	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 611
5100324	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080323	101		080923	E	1245	32382	23H0635-01	BROWNKA 613
5100324	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 615
5100324	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 617
5100324	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 619
5100324	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 621
5100324	2980	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 623
5100324	2980	BENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 625
5100324	2991	TOLUENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 627
5100324	2992	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 629
5100324	2996	STYRENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1245	32382	23H0635-01	BROWNKA 631

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

**HEADQUARTER**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Bentleysville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

**NORTHERN I**  
435 Broad St  
Monroeville, PA  
(570) 321-8000  
FAX: (570) 321-8000

FOR INTERNAL LABORATORY USE ONLY

23H3832

Sample Identification	ESL #	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	<u>2943832</u>	<u>01</u>		DW	Field	Field	Free Chlorine <u>0.86</u> mg/L


- ROTATION**
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (15% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

*Drinking Water Montieau Jr/Sr - Weekly*

<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (15% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>	<p><b>Drinking Water Montieau Jr/Sr - Weekly</b></p> <p>Notes/Special Instructions::</p>
<p><b>Sampled By: (Signature)</b>  <u>8/13/03</u> <u>13:10</u></p> <p><b>Date/ Time</b> <u>8/13/03</u> <u>13:10</u></p> <p><b>Received By: (Signature)</b> <u>JS</u> <u>08/13/03</u> <u>13:10</u></p> <p><b>Date/ Time</b> <u>8/13/03</u> <u>13:10</u></p>	<p><b>Company/Name:</b> <b>MONTIEAU SCHOOL DISTRICT</b></p> <p><b>Address:</b> 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p><b>Contact Person:</b> JEFFREY CAMPBELL</p> <p><b>Phone Number:</b> 724-406-4426</p> <p><b>Cell Phone:</b> 724-406-4426</p> <p><b>Email Address:</b> jcampbell@montieau.org</p> <p><b>Billing Address:</b></p> <p><b>PWSID:</b> 5100324</p>
<p><b>Relinquished By: (Signature)</b> _____ <b>Date/ Time</b> _____</p> <p><b>Relinquished By: (Signature)</b> _____ <b>Date/ Time</b> _____</p> <p><b>Correct Preservations</b> Y / N / NA <b>Correct Containers</b> Y / N / NA <b>Receipt Temperature</b> _____</p>	

Moniteau School District  
Maintenance Department  
Dassa McKinney Elem. School  
Water Treatment Facility  
Monthly Report for August 2023

Dassa McKinney Elementary School Water Treatment Facility											
Month	Aug	2023	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Tues	8.7	0.03	0.73	0.82	3.38	14261100	Jeff R	3:30P	800	
2	wed	8.7	0.00	0.88	0.98	2.88	14262500	Jeff R	3:30P	1400	
3	Thurs										
4	Fri										
5	Sat										
6	Sun										
7	Mon	8.7	0.02	0.40	0.48	2.97	14263200	Jeff R	3:00P	700	
8	Tues	8.7	0.03	0.58	0.68	3.14	14265800	Jeff R	3:30P	2600	
9	wed	8.7	0.00	0.39	0.40	2.23	14267500	Jeff R	3:30P	1700	
10	Thurs	8.7	0.01	0.41	0.46	2.43	14268500	Jeff R	3:30P	1000	
11	Fri										
12	Sat										
13	Sun										
14	Mon	8.7	0.02	0.40	0.48	2.55	14268600	Jeff R	3:30P	100	
15	Tues	8.7	0.02	0.49	0.57	2.84	14268700	Jeff R	3:30P	100	
16	wed	8.7	0.01	0.60	0.64	2.31	14268800	Jeff R	3:30P	100	
17	Thurs	8.7	0.02	0.50	0.58	2.44	14268900	Jeff R	3:30P	100	
18	Fri										
19	Sat										
20	Sun										
21	Mon	8.7	0.01	0.51	0.58	2.56	14269400	Jeff R	2:30P	500	
22	Tues	8.7	0.00	0.85	0.94	2.84	14269900	Jeff R	2:30P	500	
23	wed	8.7	0.06	0.77	0.86	3.06	14270700	Jeff R	3:30P	800	
24	Thurs	8.7	0.03	0.69	0.76	3.12	14274200	Jeff R	3:30P	3500	
25	Fri										
26	Sat										
27	Sun										
28	Mon										
29	Tues	8.7	0.02	0.46	0.50	2.38	14286200	Jeff C	2:00P		
30	wed	8.7	0.01	0.71	0.80	2.45	14291600	Jeff R	2:30P	5400	
31	Thurs	8.7	0.04	0.74	0.83	2.61	14295700	Jeff R	3:30P	4100	

Meter Reading 7/31/23 - 14260300



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 August 2023

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 23H0677**  
**Project: Drinking Water Dassa McKinney - Monthly 802**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23H0677-01	Drinking Water	08/03/2023 12:20	8/3/23 14:40	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/11/2023 14:57

**Lab Sample ID#:** 23H0677-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 08/03/2023 12:20  
**Receipt Date:** 08/03/2023 14:40

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.400	mg/L		0.200	PS	08/03/23 12:20	08/03/23 12:20
<b>Microbiology</b>		<b>Analytical Method: SM 9223 B-16</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	JP	08/03/23 15:17	08/04/23 15:25
E. Coli	Absent	per 100 mL		1	JP	08/03/23 15:17	08/04/23 15:25

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

**HEADQUARTER**  
 1803 Philadelphia St.  
 Indiana, PA 15701  
 (724) 463-TEST  
 FAX: (724) 465-4209

**SOUTHERN DIVISION**  
 1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 (724) 258-TEST  
 FAX: (724) 258-4376

**NORTHERN DIVISION**  
 435 Broad Street  
 Montoursville, PA 17754  
 (570) 321-9003  
 FAX: (570) 321-1957



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23H0677	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
802-KITCHEN SINK 802 ROOM 617 SINK	8393	1230	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine	0.40 mg/L

**Rotation:**  
 801: Jan, Mar, May, Jul, Sep,  
 Nov  
 802: Feb, Apr, Jun, Aug, Oct,  
 Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

*Drinking Water Dassa McKinney - Monthly*

Sampled By: (Signature) *[Signature]* Date/ Time *8393 1230*

Relinquished By: (Signature) *[Signature]* Date/ Time *1430*

Relinquished By: (Signature) *[Signature]* Date/ Time *1440*

Relinquished By: (Signature) *[Signature]* Date/ Time *1440*

Correct Preservations *(Y/N/NA)* *(Y/N/NA)* Correct Containers *(Y/N/NA)* Receipt Temperature *40 #3*

Company/Name: **MONTTEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **icampbell@montteau.org**

Email Address: **5100316**

Billing Address: **5100316**

PWSID: **5100316**

102



**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.4	080323	802		080323	D	1220	32382	23H0677-01	BROWNKA_274
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1220	32382	23H0677-01	BROWNKA_275



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

14 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 23H1699**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23H1699-01	Drinking Water	08/10/2023 12:00	8/10/23 15:50	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/14/2023 17:04

**Lab Sample ID#:** 23H1699-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 08/10/2023 12:00  
**Receipt Date:** 08/10/2023 15:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.420	mg/L		0.200	PS	08/10/23 12:00	08/10/23 12:00

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE   1   OF   1  

HEADQUARTER  
803 Philadelphia St  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Berleville Road  
Van Vleet, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



NORTHWEST DIVISION  
950 Main Street  
Sharsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Grab	Time				
Distribution: <u>SW</u>	<u>23H1699</u>	<u>SW</u>	<u>Dec</u>	DW	Field	Field	Free Chlorine <u>0.42</u> mg/L

- ROTATION**
- W/K 1 - 801 Kitchen Sink
  - W/K 2 - 802 Room 617 Sink
  - W/K 3 - 803 Room 606 Sink
  - W/K 4 - 804 Room 408 Sink
  - W/K 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

*Drinking Water Dassa McKinney - Weekly*

1. Sampled By: (signature) [Signature] Date/Time 8/10/03 12:00

2. Relinquished By: (signature) [Signature] Date/Time 8/10/03 13:50

3. Relinquished By: (signature) [Signature] Date/Time 8/10/03 13:50

4. Relinquished By: (signature) [Signature] Date/Time 8/10/03 13:50

5. Relinquished By: (signature) [Signature] Date/Time 8/10/03 13:50

6. Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature           

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD**

Contact Person: **WEST SUNBURY, PA 16061**

Phone Number: **JEFFREY CAMPBELL**

Cell Phone: **724-406-4426**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.42	081023	801		081023	D	1200	32382	23H1699-01	BROWNKA_875
5100316	1013	FREE CHLORINE	301	0.4	080323	802		080323	D	1220	32382	23H0677-01	BROWNKA_274
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1220	32382	23H0677-01	BROWNKA_275

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_590
5100316	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_592
5100316	2955	XYLENES - TOTAL (VOC)	221	0.00065	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_594
5100316	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_596
5100316	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_598
5100316	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_600
5100316	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_602
5100316	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_604
5100316	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_606
5100316	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_606
5100316	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_610
5100316	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_612



E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

<b>5100316: DASSA MCKINNEY ELEM SCHOOL</b>															
<b>SDWA4</b>															
PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 614
5100316	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 616
5100316	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 618
5100316	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 620
5100316	2989	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 622
5100316	2990	BENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 624
5100316	2991	TOLUENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 626
5100316	2992	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 628
5100316	2996	STYRENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 630



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

24 August 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 23H2530  
Project: Drinking Water Dassa McKinney - Weekly  
Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23H2530-01	Drinking Water	08/17/2023 10:37	8/17/23 14:24	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 08/24/2023 14:16

Lab Sample ID#: 23H2530-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 803 Room 606 Sink

Sample Date: 08/17/2023 10:37  
 Receipt Date: 08/17/2023 14:24

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.410	mg/L		0.200	PS	08/17/23 10:37	08/17/23 10:37



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Benleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



FOR INTERNAL LABORATORY USE ONLY

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE RECEIPT & CHAIN OF CUSTODY

RE \_\_\_\_\_ OF \_\_\_\_\_

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>803</u>	<u>23H2530</u>			DW	Field	Field	Free Chlorine <u>0.41</u> mg/L

- ROTATION**
- Wk 1 - 801 Kitchen Sink
  - Wk 2 - 802 Room 617 Sink
  - Wk 3 - 803 Room 606 Sink
  - Wk 4 - 804 Room 408 Sink
  - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1.34% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

*Drinking Water Dassa McKinney - Weekly*

Sampled By: (Signature) [Signature] Date/ Time 8/17/03 08:10:37

Relinquished By: (Signature) [Signature] Date/ Time 8/17/03 08:10:37

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Company/Name: **MONTTEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: \_\_\_\_\_

Email Address: **jcambbell@montteau.org**

Billing Address: \_\_\_\_\_

PWSID: **5100316**

Correct Preservations NA/NA Correct Containers NA/NA

Received By: (Signature) [Signature] Date/ Time 8/17/03

[Signature]

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.42	081023	801		081023	D	1200	32382	23H1699-01	BROWNKA_875
5100316	1013	FREE CHLORINE	301	0.4	080323	802		080323	D	1220	32382	23H0677-01	BROWNKA_274
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1220	32382	23H0677-01	BROWNKA_275
5100316	1013	FREE CHLORINE	301	0.41	081723	803		081723	D	1037	32382	23H2530-01	BROWNKA_1587

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_590
5100316	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_592
5100316	2955	XYLENES - TOTAL (VOC)	221	0.00065	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_594
5100316	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_596
5100316	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_598
5100316	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_600
5100316	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_602
5100316	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_604
5100316	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_606
5100316	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_608
5100316	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_610

**5100316: DASSA MCKINNEY ELEM SCHOOL  
SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 612
5100316	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 614
5100316	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 616
5100316	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 618
5100316	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 620
5100316	2989	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 622
5100316	2990	BENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 624
5100316	2991	TOLUENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 626
5100316	2992	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 628
5100316	2996	STYRENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 630



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

29 August 2023

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 23H3273**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23H3273-01	Drinking Water	08/24/2023 10:30	8/25/23 9:26	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 08/29/2023 08:28

**Lab Sample ID#:** 23H3273-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 Room 408 Sink

**Sample Date:** 08/24/2023 10:30  
**Receipt Date:** 08/25/2023 09:26

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>							
	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.800	mg/L		0.200	PS	08/24/23 10:30	08/24/23 10:30

**5100316: DASSA MCKINNEY ELEM SCHOOL  
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID (HAA)	206	0.0	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2222
5100316	2451	DICHLOROACETIC ACID (HAA)	206	0.00384	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2228
5100316	2452	TRICHLOROACETIC ACID (HAA)	206	0.00214	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2233
5100316	2453	MONOBROMOACETIC ACID (HAA)	206	0.0	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2237
5100316	2454	DIBROMOACETIC ACID (HAA)	206	0.0	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2242
5100316	2456	HALOACETIC ACIDS (HAA5)	206	0.00598	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2248
5100316	2941	CHLOROFORM (THM)	221	0.00808	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2253
5100316	2942	BROMOFORM (THM)	221	0.00111	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2258
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00379	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2263
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.0031	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2268
5100316	2950	TRICHLOROMETHANES (TTHM)	221	0.0161	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2273
5100316	2450	MONOCHLOROACETIC ACID (HAA)	206	0.0	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2223
5100316	2451	DICHLOROACETIC ACID (HAA)	206	0.00323	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2227
5100316	2452	TRICHLOROACETIC ACID (HAA)	206	0.00204	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2232
5100316	2453	MONOBROMOACETIC ACID (HAA)	206	0.0	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2238
5100316	2454	DIBROMOACETIC ACID (HAA)	206	0.0	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2238
5100316	2456	HALOACETIC ACIDS (HAA5)	206	0.00527	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2243
5100316	2941	CHLOROFORM (THM)	221	0.00719	081723	704		081023	D	1205	32382	23H1588-02	BROWN_2247
5100316	2942	BROMOFORM (THM)	221	0.0	081723	704		081023	D	1205	32382	23H1588-02	BROWN_2252
5100316	2942	BROMOFORM (THM)	221	0.0	081723	704		081023	D	1205	32382	23H1588-02	BROWN_2257



E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00329	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2262
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.0026	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2267
5100316	2950	TRIHALOMETHANES (TTHM)	221	0.0131	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2272
5100316	1013	FREE CHLORINE	301	0.42	081023	801		081023	D	1200	32382	23H1699-01	BROWNKA_875
5100316	1013	FREE CHLORINE	301	0.4	080323	802		080323	D	1220	32382	23H0677-01	BROWNKA_274
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1220	32382	23H0677-01	BROWNKA_275
5100316	1013	FREE CHLORINE	301	0.41	081723	803		081723	D	1037	32382	23H2530-01	BROWNKA_1587
5100316	1013	FREE CHLORINE	301	0.8	082423	804		082423	D	1030	32382	23H3273-01	BROWNKA_2587

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_590
5100316	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_592
5100316	2955	XYLENES - TOTAL (VOC)	221	0.00065	0.00050		080323	101		080323	E	1225	32382	23H0633-01	BROWNKA_594
5100316	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_596
5100316	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_598
5100316	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_600
5100316	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_602
5100316	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_604



E-Government Application for Drinking Water Program  
SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**  
**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 606
5100316	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 608
5100316	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080323 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 610
5100316	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 612
5100316	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 614
5100316	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080323 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 616
5100316	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 618
5100316	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 620
5100316	2980	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 622
5100316	2990	BENZENE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 624
5100316	2991	TOLUENE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 626
5100316	2992	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 628
5100316	2996	STYRENE (VOC)	221	0.0	0.00050		080923 101	101		080323	E	1225	32382	23H0633-01	BROWNKA 630



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 465-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Vleet, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

FOR INTERNAL LABORATORY USE ONLY



EST DIVISION  
York PA 16  
EST  
465-4209

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Field	Container Type Preservative	Analysis Requested
		Grab	Time					
Distribution: <u>SCJ</u>	<u>23H3273</u>	<u>SCJ</u>	<u>1530</u>	DW		Field	Field	Free Chlorine <u>0.86</u> mg/L

- ROTATION**
- WK 1 - 801 Kitchen Sink
  - WK 2 - 802 Room 617 Sink
  - WK 3 - 803 Room 606 Sink
  - WK 4 - 804 Room 408 Sink**
  - WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Sampled By: (Signature) [Signature] Date/ Time 8/24/08 10:00

Relinquished By: (Signature) [Signature] Date/ Time 8/24/08 11:52

Company/Name: **MONTEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **724-406-4426**

Email Address: **jcampbell@monteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y/N (N) Correct Containers Y/N (N) Receipt Temperature \_\_\_\_\_



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

06 September 2023

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 23H3829**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23H3829-01	Drinking Water	08/31/2023 10:00	8/31/23 13:10	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Data Qualifiers/Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 09/06/2023 15:09

**Lab Sample ID#:** 23H3829-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 08/31/2023 10:00  
**Receipt Date:** 08/31/2023 13:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.840	mg/L		0.200	PS	08/31/23 10:00	08/31/23 10:00



E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2450	MONOCHLOROACETIC ACID (HAA)	206	0.0	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2222
5100316	2451	DICHLOROACETIC ACID (HAA)	206	0.00384	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2228
5100316	2452	TRICHLOROACETIC ACID (HAA)	206	0.00214	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2233
5100316	2453	MONOBROMOACETIC ACID (HAA)	206	0.0	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2237
5100316	2454	DIBROMOACETIC ACID (HAA)	206	0.0	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2242
5100316	2456	HALOACETIC ACIDS (HAA5)	206	0.00598	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2248
5100316	2941	CHLOROFORM (THM)	221	0.00808	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2253
5100316	2942	BROMOFORM (THM)	221	0.00111	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2258
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00379	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2263
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.0031	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2268
5100316	2950	TRICHLOROMETHANES (TTHM)	221	0.0161	081723	703		081023	D	1215	32382	23H1588-01	BROWNKA_2273
5100316	2450	MONOCHLOROACETIC ACID (HAA)	206	0.0	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2223
5100316	2451	DICHLOROACETIC ACID (HAA)	206	0.00323	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2227
5100316	2452	TRICHLOROACETIC ACID (HAA)	206	0.00204	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2232
5100316	2453	MONOBROMOACETIC ACID (HAA)	206	0.0	081023	704		081023	D	1205	32382	23H1588-02	BROWNKA_2238
5100316	2454	DIBROMOACETIC ACID (HAA)	206	0.0	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2243
5100316	2456	HALOACETIC ACIDS (HAA5)	206	0.00527	081923	704		081023	D	1205	32382	23H1588-02	BROWNKA_2247
5100316	2941	CHLOROFORM (THM)	221	0.00719	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2252
5100316	2942	BROMOFORM (THM)	221	0.0	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2257



E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

<b>5100316: DASSA MCKINNEY ELEM SCHOOL</b>													
<b>SDWA1</b>													
PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2943	BROMODICHLOROMETHANE (THM)	221	0.00329	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2262
5100316	2944	CHLORODIBROMOMETHANE (THM)	221	0.0026	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2267
5100316	2950	TRICHALOMETHANES (TTHM)	221	0.0131	081723	704		081023	D	1205	32382	23H1588-02	BROWNKA_2272
5100316	1013	FREE CHLORINE	301	0.42	081023	801		081023	D	1200	32382	23H1699-01	BROWNKA_875
5100316	1013	FREE CHLORINE	301	0.4	080323	802		080323	D	1220	32382	23H0677-01	BROWNKA_274
5100316	1013	FREE CHLORINE	301	0.64	083123	802		083123	D	1000	32382	23H3829-01	BROWNKA_3355
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	080423	802		080323	D	1220	32382	23H0677-01	BROWNKA_275
5100316	1013	FREE CHLORINE	301	0.41	081723	803		081723	D	1037	32382	23H2530-01	BROWNKA_1587
5100316	1013	FREE CHLORINE	301	0.8	082423	804		082423	D	1030	32382	23H3273-01	BROWNKA_2587

<b>5100316: DASSA MCKINNEY ELEM SCHOOL</b>															
<b>SDWA4</b>															
PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2378	1,2,4-TRICHLOROBENZENE (VOC)	221	0.0	0.00050		080323	101		080323	E	1225	32382	23H0633-01	BROWNKA_590
5100316	2380	CIS-1,2-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_592
5100316	2955	XYLENES - TOTAL (VOC)	221	0.00065	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_594
5100316	2964	DICHLOROMETHANE (VOC)	221	0.0	0.00050		080323	101		080323	E	1225	32382	23H0633-01	BROWNKA_596
5100316	2968	O-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_598
5100316	2969	P-DICHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_600
5100316	2976	VINYL CHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA_602



E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA4**

PWSID	Contam ID	Contam	Analysis Method	Result	Lower Limit of Detection	Counting Error	Analysis Date	Loc/EP ID	Loc/EP ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	2977	1,1-DICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080923	E	1225	32382	23H0633-01	BROWNKA 604
5100316	2979	TRANS-1,2-DICHLOROETHENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 606
5100316	2980	1,2-DICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 608
5100316	2981	1,1,1-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 610
5100316	2982	CARBON TETRACHLORIDE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 612
5100316	2983	1,2-DICHLOROPROPANE(VOC)	221	0.0	0.00050		080923	101		080923	E	1225	32382	23H0633-01	BROWNKA 614
5100316	2984	TRICHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 616
5100316	2985	1,1,2-TRICHLOROETHANE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 618
5100316	2987	TETRACHLOROETHYLENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 620
5100316	2969	CHLOROBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 622
5100316	2990	BENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 624
5100316	2991	TOLUENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 626
5100316	2992	ETHYLBENZENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 628
5100316	2990	STYRENE (VOC)	221	0.0	0.00050		080923	101		080323	E	1225	32382	23H0633-01	BROWNKA 630

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

**HEADQUARTER**  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

**SOUTHERN DIVISION**  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

**NORTHEAST**  
435 Brook  
Montours  
(570) 321  
FAX: (570) 341-1151

FOR INTERNAL LABORATORY USE ONLY



Sample Identification	ESL #	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>23H3829</u>			DW	Field	Field	Free Chlorine <u>0.84</u> mg/L

ROTATION
WK 1 - 801 Kitchen Sink
WK 2 - 802 Room 617 Sink
WK 3 - 803 Room 606 Sink
WK 4 - 804 Room 408 Sink
WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>8-21-23 08:00</u></p> <p>Retrified By: (Signature) <u>[Signature]</u> Date/ Time <u>8-21-23 08:15</u></p> <p>Retrified By: (Signature) <u>[Signature]</u> Date/ Time <u>8-21-23 08:15</u></p> <p>Retrified By: (Signature) <u>[Signature]</u> Date/ Time <u>8-21-23 08:15</u></p> <p>Retrified By: (Signature) <u>[Signature]</u> Date/ Time <u>8-21-23 08:15</u></p> <p>Correct Preservations Y/N/NA <u>Y/N/NA</u> Correct Containers Y/N/NA <u>Y/N/NA</u> Receipt Temperature <u>—</u></p>	<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</b></p> <p>Contact Person: <b>JEFFREY CAMPBELL</b></p> <p>Phone Number: <b>724-406-4426</b></p> <p>Cell Phone: <b>724-406-4426</b></p> <p>Email Address: <b>jcampbell@moniteau.org</b></p> <p>Billing Address: <b>5100316</b></p> <p>PWSID: <b>5100316</b></p>
--	--