

**Moniteau School District
Maintenance Department
Monthly Operations Report for
June 2020**

**Dassa McKinney Elementary
School**

Water Treatment Plant

Dassa McKinney Elementary School Water Treatment Facility

June 2020

Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Mon	7.9	0.06	0.38	0.41	2.41	11957900	Jeff R	2:00P	400
2	Tues	7.8	0.07	0.47	0.52	2.75	11958000	Jeff R	2:30P	100
3	Wed.	7.9	0.07	0.44	0.48	2.62	11958100	Jeff R	2:30P	100
4	Thurs.	8.1	0.07	0.42	0.45	2.78	11958400	Jeff R	2:30P	300
5	Fri	7.9	0.05	0.40	0.44	2.67	11958700	Jeff R	2:30P	
6	Sat									
7	Sun									
8	Mon	7.9	0.04	0.48	0.54	2.08	11958600	Jeff R.	2:30P	200
9	Tues	7.9	0.03	0.61	0.66	2.14	11958600	Jeff R.	2:30P	0
10	Wed.	7.8	0.06	0.57	0.62	1.73	11958700	Jeff R	2:30P	100
11	Thurs	7.9	0.06	0.61	0.65	1.82	11959100	Jeff R	2:30P	400
12	Fri	7.9	0.07	0.88	0.93	2.17	11959100	Jeff R.	2:50P	0
13	Sat									
14	Sun									
15	Mon	7.9	0.03	0.57	0.63	1.93	11959100	Jeff C	4:30PM	0
16	Tues	7.9	0.03	0.58	0.65	1.97	11959300	Jeff C	5:00PM	200
17	Wed	7.9	0.05	0.58	0.64	2.03	11959400	Jeff C	5:00PM	100
18	Thurs	7.9	0.05	0.60	0.69	1.99	11959400	Jeff C	5:00PM	0
19	Fri	7.9	0.06	0.53	0.58	1.97	11960000	Jeff C	7:15AM	600
20	Sat									
21	Sun									
22	Mon	7.9	0.02	0.39	0.48	2.02	11960100	Jeff C	1:00PM	180
23	Tues	7.9	0.02	0.30	0.41	2.08	11960200	Jeff C	4:30PM	100
24	Wed	7.9	0.02	1.06	1.12	2.06	11960300	Jeff C	4:30PM	100
25	Thurs	7.9	0.01	1.00	1.07	2.04	11960400	Jeff C	5:00AM	100
26	Fri	7.9	0.02				11960100	Jeff C	3:00AM	760
27	Sat									
28	Sun									
29	Mon	7.9	0.02	1.30	1.40	1.98	11961100	Jeff C	1:00PM	0
30	Tues.	7.9	0.03	1.34	1.42	1.92	11961200	Jeff C	8:00AM	100
31										

Meter Reading on 5/29/20 - 11957500



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

26 June 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0062165
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0062165-01	Drinking Water	06/25/2020 11:25	6/25/20 14:07	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/26/2020 10:21

Lab Sample ID#: 0062165-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 06/25/2020 11:25
Receipt Date: 06/25/2020 14:07

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.680	mg/L		0.200	PFS	06/25/20 11:25	06/25/20 11:25

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVI
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-19



0062165

FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: _____	0062165	6/25/02	11:05	DW	Field	Field	Free Chlorine .68 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 ROOM 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: 5100316</p> <p>PWSID: 5100316</p>			
<p>Sampled By: (Signature) <i>[Signature]</i></p> <p>Date/ Time: 6/25/02 11:05</p>		<p>Received By: (Signature) <i>[Signature]</i></p> <p>Date/ Time: 6/25/02 14:05</p>		<p>Relinquished By: (Signature) _____</p> <p>Date/ Time: _____</p>		<p>Correct Containers Y/N (NA) _____</p> <p>Receipt Temperature _____</p>	

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.59	060420	802		060420	D	1335	32382	0060508-01	BROWNKA_69
5100316	1013	FREE CHLORINE	301	0.73	061120	802		061120	D	1205	32382	0061074-01	BROWNKA_401
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1335	32382	0060508-01	BROWNKA_70
5100316	1013	FREE CHLORINE	301	0.69	061820	803		061820	D	1200	32382	0061691-01	BROWNKA_721
5100316	1013	FREE CHLORINE	301	0.68	062520	804		062520	D	1125	32382	0062165-01	BROWNKA_995



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 June 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0061691
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	0061691-01	Drinking Water	06/18/2020 12:00	6/19/20 9:24	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/19/2020 10:29

Lab Sample ID#: 0061691-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 06/18/2020 12:00
Receipt Date: 06/19/2020 09:24

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.690	mg/L		0.200	PFS	06/18/20 12:00	06/18/20 12:00



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.59	060420	802		060420	D	1335	32382	0060508-01	BROWNKA_69
5100316	1013	FREE CHLORINE	301	0.73	061120	802		061120	D	1205	32382	0061074-01	BROWNKA_401
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1335	32382	0060508-01	BROWNKA_70
5100316	1013	FREE CHLORINE	301	0.69	061820	803		061820	D	1200	32382	0061691-01	BROWNKA_721

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209



SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: 803	0061691	6-18-20	1200	DW	Field	Field	Free Chlorine 0.69 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>				<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcambell@moniteau.k12.pa.us</p> <p>Billing Address: 5100316</p>			
<p>Sampled By: (Signature) [Signature]</p> <p>Date/ Time: 6-18-20 1200</p>		<p>Received By: (Signature) [Signature]</p> <p>Date/ Time: 6-18-20 1430</p>		<p>Relinquished By: (Signature) [Signature]</p> <p>Date/ Time: 6-18-20 1430</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>	
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Correct Preservations Y / N / NA</p> <p>Correct Containers Y / N / NA</p> <p>Receipt Temperature</p>	



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0061074
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0061074-01	Drinking Water	06/11/2020 12:05	6/11/20 15:24	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/12/2020 10:13

Lab Sample ID#: 0061074-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 06/11/2020 12:05
Receipt Date: 06/11/2020 15:24

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.730	mg/L		0.200	PFS	06/11/20 12:05	06/11/20 12:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
0061074

NORTHWEST DIVISION
n Street
ille, PA 16
3-TEST
24) 465-4209



FOR INTERNAL LAE

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Sample Identification	ESL# 0061074	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: 802	0061074	DW	Field	Field	Free Chlorine .73 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>					
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>					
<p>Notes/Special Instructions:</p> <p>Drinking Water Dassa McKinney - Weekly</p>					
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.k12.pa.us</p> <p>Billing Address: 51D0316</p> <p>PWSID: 51D0316</p>					
Sampled By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Relinquished By: (Signature)	Date/ Time
	6-11-20 1435		6-11-20 1522		
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Relinquished By: (Signature)	Date/ Time
Correct Preservations Y/N (NA)	Correct Containers Y/N (NA)	Receipt Temperature			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.59	060420	802		060420	D	1335	32382	0060508-01	BROWNKA_69
5100316	1013	FREE CHLORINE	301	0.73	061120	802		061120	D	1205	32382	0061074-01	BROWNKA_401
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1335	32382	0060508-01	BROWNKA_70



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

11 June 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0060508
Project: Drinking Water Dassa McKinney - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0060508-01	Drinking Water	06/04/2020 13:35	6/4/20 16:46	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/11/2020 10:33

Lab Sample ID#: 0060508-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Justin Matava
Client Sample ID: 802 Room 617 Sink

Sample Date: 06/04/2020 13:35
Receipt Date: 06/04/2020 16:46

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.590	mg/L		0.200	JDM	06/04/20 13:35	06/04/20 13:35
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	06/04/20 18:05	06/05/20 18:48
E. Coli	Absent	per 100 mL		1	DAA	06/04/20 18:05	06/05/20 18:48

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 1 OF 1

Page 3 of 4



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
801 KITCHEN SINK 802 ROOM 617 SINK	0060508 01	6/4/06	1335	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 0.59 mg/L

Rotation:

801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 6/4/06 1335
 Relinquished By: (Signature) *[Signature]* Date/ Time 6/4/06 1645

Relinquished By: (Signature) _____ Date/ Time _____
 Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____

Notes/Special Instructions:

Drinking Water Dassa McKinney - Monthly

Company Name: MONITEAU SCHOOL DISTRICT
 Address: 391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: jcampbell@moniteau.k12.pa.us
 Billing Address: 5100316
 PWSID: 5100316



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.59	060420	802		060420	D	1335	32382	0060508-01	BROWNKA_69
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1335	32382	0060508-01	BROWNKA_70

**Moniteau School District
Maintenance Department
Monthly Operations Report for
June 2020**

**Moniteau High School
Water Treatment Plant**

MONTH	DAY	TEMP	LEVEL	MONTEAU HIGH SCHOOL WATER TREATMENT PLANT										OPERATOR	TIME	
				METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS						
June	2020															
1	Mon	67.3	7.15	3,404, 364	0.65	0.72	7.4	0.01	0	0.97	Jeff C	1:30 PM				
2	Tues	67.5	6.77	3,404, 364	0.64	0.72	7.5	0.02	0	0.99	Jeff C	11:30 AM				
3	Wed	69.4	7.48	3,413, 010	0.58	0.62	7.4	0.00	0	1.02	Jeff C	4:00 PM				
4	Thurs	69.6	6.44	3,413, 010	0.59	0.62	7.4	0.00	0	1.02	Jeff C	4:00 PM				
5	Fri	67.0	8.07	3,418, 850	0.95	0.97	7.4	0.00	0	0.99	Jeff C	2:00 PM				
6	SAT															
7	SUN															
8	Mon	67.0	6.91	3,432, 549	0.99	1.11	7.3	0.00	0	1.00	Jeff C	2:00 PM				
9	Tues	66.4	8.58	3,456, 212	0.96	1.06	7.3	0.00	0	1.02	Jeff C	3:15 PM				
10	Wed	65.4	7.82	3,484, 865	0.95	1.00	7.3	0.00	0	1.00	Jeff C	4:00 PM				
11	Thurs	66.1	8.40	3,491, 147	0.75	0.84	7.3	0.01	0	0.96	Jeff C	9:00 AM				
12	Fri	67.9	7.02	3,491, 147	0.74	0.85	7.3	0.00	0	0.95	Jeff C	9:00 AM				
13	SAT															
14	SUN															
15	Mon	67.8	6.10	3,491, 147	0.74	0.84	7.3	0.00	0	1.00	Jeff C	2:00 PM				
16	Tues	66.2	8.31	3,507, 189	0.76	0.84	7.3	0.02	0	1.16	Jeff C	8:00 AM				
17	Wed	69.4	6.64	3,507, 189	0.76	0.84	7.3	0.01	0	1.15	Jeff C	3:00 PM				
18	Thurs	66.5	8.21	3,519, 467	0.63	0.74	7.3	0.00	0	0.99	Jeff C	3:00 PM				
19	Fri	67.4	7.01	3,519, 467	0.60	0.70	7.3	0.00	0	1.01	Jeff C	9:00 AM				
20	SAT															
21	SUN															
22	Mon	68.3	7.58	3,532, 610	0.45	0.56	7.3	0.02	0	1.89	Jeff C	10:30 AM				
23	Tues	70.5	6.08	3,532, 610	0.47	0.58	7.3	0.01	0	1.91	Jeff C	11:30 AM				
24	Wed	67.7	8.20	3,544, 712	0.53	0.62	7.3	0.00	0	1.53	Jeff C	3:30 PM				
25	Thurs	69.1	7.14	3,544, 712	0.48	0.56	7.3	0.00	0	1.51	Jeff C	3:00 PM				
26	Fri	70.5	6.32	3,544, 712	0.48	0.55	7.3	0.00	0	1.50	Jeff C	2:00 PM				
27	SAT															
28	SUN															
29	Mon	72.5	6.87	3,551, 624	0.67	0.79	7.3	0.00	0	1.94	Jeff C	1:15 PM				
30	Tues	67.6	8.94	3,565, 180	0.74	0.84	7.3	0.00	0	2.02	Jeff C	4:00 PM				
31																

Meter Reading on 5/29/20 3,393, 148



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

26 June 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0062166
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0062166-01	Drinking Water	06/25/2020 11:50	6/25/20 14:08	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/26/2020 10:21

Lab Sample ID#: 0062166-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 06/25/2020 11:50
Receipt Date: 06/25/2020 14:08

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.420	mg/L		0.200	PFS	06/25/20 11:50	06/25/20 11:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

DATE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: _____	0062166	6/5/20	1150	DW	Field	Field	Free Chlorine <u>0.22</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 6-25-20 1150

Relinquished By: (Signature) [Signature] Date/ Time 6-25-20 1344

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) [Signature] Date/ Time 6/25/20 14:05

Received By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature _____

Notes/Special Instructions:

Drinking Water / Moniteau Jr/Sr - Weekly

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **724-406-4426**

Cell Phone: **jcampbell@moniteau.k12.pa.us**

Email Address: **jcampbell@moniteau.k12.pa.us**

Billing Address: **5100324**

PWSID: **5100324**

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	060420	802		060420	D	1408	32382	0060496-01	BROWNKA_75
5100324	1013	FREE CHLORINE	301	0.64	061120	802		061120	D	1218	32382	0061075-01	BROWNKA_402
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1408	32382	0060496-01	BROWNKA_76
5100324	1013	FREE CHLORINE	301	0.63	061820	803		061820	D	1220	32382	0061690-01	BROWNKA_722
5100324	1013	FREE CHLORINE	301	0.42	062520	804		062520	D	1150	32382	0062166-01	BROWNKA_996



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

19 June 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0061690
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	0061690-01	Drinking Water	06/18/2020 12:20	6/19/20 9:21	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/19/2020 10:29

Lab Sample ID#: 0061690-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 06/18/2020 12:20
Receipt Date: 06/19/2020 09:21

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.630	mg/L		0.200	PFS	06/18/20 12:20	06/18/20 12:20

5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	060420	802		060420	D	1408	32382	0060496-01	BROWNKA_75
5100324	1013	FREE CHLORINE	301	0.64	061120	802		061120	D	1218	32382	0061075-01	BROWNKA_402
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1408	32382	0060496-01	BROWNKA_76
5100324	1013	FREE CHLORINE	301	0.63	061820	803		061820	D	1220	32382	0061690-01	BROWNKA_722

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

HEADQUARTER
 1803 Philadelphia St.
 Indiana, PA 15701
 (724) 463-TEST
 FAX: (724) 465-4209

SOUTHERN DIVISION
 1276 Benlleyville Road
 Van Voorhis, PA 15366
 (724) 258-TEST
 FAX: (724) 258-8376

NORTHERN DIVISION
 435 Broad Street
 Montoursville, PA 17754
 (570) 321-9003
 FAX: (570) 321-1957

NORTHWEST DIVISION
 950 Main Street
 Sharpsville, PA 16
 (724) 463-TEST
 FAX: (724) 465-4209



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>SOS</u>	<u>0061690</u>	<u>6/18/20</u>	<u>1220</u>	DW	Field	Field	Free Chlorine <u>.63</u> mg/L
<div style="border: 1px solid black; padding: 5px;"> <p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - <u>802 ROOM 204 Sink</u></p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p> </div>							

Notes/Special Instructions:
Drinking Water Moniteau Jr/Sr - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) [Signature] Date/ Time 6/18/20 1520

Received By: (Signature) [Signature] Date/ Time 6/18/20 1455

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA _____ Correct Containers Y / N / NA _____ Receipt Temperature _____

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061**
 Contact Person: **JEFFREY CAMPBELL**
 Phone Number: **724-406-4426**
 Cell Phone: **jcampbell@moniteau.k12.pa.us**
 Billing Address: **724-406-4426**
 PWSID: **5100324**



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

12 June 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0061075
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0061075-01	Drinking Water	06/11/2020 12:18	6/11/20 15:24	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Rebecca Erwin
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/12/2020 10:13

Lab Sample ID#: 0061075-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 06/11/2020 12:18
Receipt Date: 06/11/2020 15:24

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-C1 G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.640	mg/L		0.200	PFS	06/11/20 12:18	06/11/20 12:18

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORT
435 Br
Montic
(570) 3
FAX: (



FOR INTERNAL LABORATORY USE ONLY

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>802</u>	<u>0061075</u>	<u>6-11-20</u>	<u>12:18</u>	DW	Field	Field	Free Chlorine <u>6.64</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time <u>6-11-20 12:18</u>		Notes/Special Instructions: <u>Drinking Water Moniteau Jr/Sr - Weekly</u>			
Relinquished By: (Signature)		Date/ Time <u>6-11-20 14:35</u>		Company Name: <u>MONITEAU SCHOOL DISTRICT</u>			
Relinquished By: (Signature)		Date/ Time		Address: <u>391 HOOKER ROAD</u>			
Relinquished By: (Signature)		Date/ Time		Contact Person: <u>JEFFREY CAMPBELL</u>			
Correct Preservations <u>Y / N / NA</u>		Correct Containers <u>Y / N / NA</u>		Phone Number: <u>724-406-4426</u>			
Receipt Temperature <u>—</u>		Received By: (Signature)		Cell Phone: <u>jcampbell@moniteau.k12.pa.us</u>			
Received By: (Signature)		Date/ Time		Billing Address: <u>WEST SUNBURY, PA 16061</u>			
Received By: (Signature)		Date/ Time		PWSID: <u>5100324</u>			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT

VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	060420	802		060420	D	1408	32382	0060496-01	BROWNKA_75
5100324	1013	FREE CHLORINE	301	0.64	061120	802		061120	D	1218	32382	0061075-01	BROWNKA_402
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1408	32382	0060496-01	BROWNKA_76



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

11 June 2020

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 0060496
Project: Drinking Water Moniteau Jr/Sr - Monthly 802
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0060496-01	Drinking Water	06/04/2020 14:08	6/4/20 16:46	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/11/2020 10:33

Lab Sample ID#: 0060496-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Justin Matava
Client Sample ID: 802 Room 204 Sink

Sample Date: 06/04/2020 14:08
Receipt Date: 06/04/2020 16:46

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.640	mg/L		0.200	JDM	06/04/20 14:08	06/04/20 14:08
Microbiology		Analytical Method: SM9223 B-04			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	DAA	06/04/20 18:05	06/05/20 18:48
E. Coli	Absent	per 100 mL		1	DAA	06/04/20 18:05	06/05/20 18:48

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Benitleyville Road
Van Vorthis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

Page 3 of 4



0060496

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Matrix	# of Bottles	Container Type	Analysis Requested
	0060496				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM 204 SINK	Date	DW	1	NA THIO	
	6/4/20				

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Supplied By: (Signature) *[Signature]* Date/Time 6/4/20 1408
Relinquished By: (Signature) *[Signature]* Date/Time 6/4/20 1645

Received By: (Signature) *[Signature]* Date/Time 6/14/20 1644
Relinquished By: (Signature) Date/Time
Relinquished By: (Signature) Date/Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Monthly

Company Name: MONITEAU SCHOOL DISTRICT
Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: jcampbell@moniteau.k12.pa.us
Billing Address: 5100324
PWSID: 5100324

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.64	060420	802		060420	D	1408	32382	0060496-01	BROWNKA_75
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	060520	802		060420	D	1408	32382	0060496-01	BROWNKA_76

**Moniteau School District
Maintenance Department
Monthly Operations Report for
June 2020**

**Moniteau High School
Wastewater Treatment Plant**



COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 FACILITY: MONTEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220
 STAGE: Final Effluent

PA0091341
PERMIT NUMBER

001
OUTFALL NUMBER

Reporting Frequency: Monthly
 DMR Effective From: 06/01/2020
 DMR Effective To: 06/30/2020
 Permit Expires: 05/31/2022
 Permit Application Due: 12/02/2021
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2020	06	01	2020	06	30

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		8.36	***	***	1/week	Grab
	PERMIT REQUIREMENT	***		4.0 Min	***	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		6.99	***	8.88	1/week	Grab
	PERMIT REQUIREMENT	***		6.0 Min	***	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		<5.0	***	***	2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo	***	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		17.05	***	***	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		1.8	***	***	2/month	Grab
	PERMIT REQUIREMENT	***		***	***	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		6.29	***	***	1/week	Grab
	PERMIT REQUIREMENT	***		***	***	***	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.007	MGD	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	***	1/week	Measured

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***	***		<1.0	<1.0		No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	***	***		200	1000	IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***	***		<3.0	***		mg/L	2/month	Grab
	PERMIT REQUIREMENT	***	***		25	Avg Mb	***		2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------

Your eDMR Report Has Been Received For Permit No. PA0091341

From: depgreenporthelpdesk@state.pa.us
To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com
Date: Wednesday, July 8, 2020, 08:20 AM EDT

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL
Permit Number: PA0091341
Report Frequency: Monthly
Report Type: DMR
Reporting Period: 06/01/2020-06/30/2020
Report Due Date: 07/28/2020

Submitted By: Jeffrey Campbell
Submission Id: 214458
Submission Status: Received
Submission Type: Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.

Moniteau High School Sewage Treatment Plant Permit # PA0091341			Daily Operations Worksheet						
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Meter Reading	Time	Operator
6/1/20	Mon	8.28	9.40	OFF	OFF	June 2020	No Flow	1:30 PM	JEFFC
6/2/20	Tues	8.32	9.43	"	"	7.6	"	08:00 AM	JEFFC
6/3/20	Wed	8.74	9.00	"	"	7.3	"	4:30 PM	JEFFC
6/4/20	Thurs	8.79	8.68	"	"	6.0	"	11:00 AM	JEFFC
6/5/20	Fri	8.45	8.36	"	"	5.5	"	9:30 AM	JEFFC
6/8/20	MON	8.75	9.38	"	"	5.8	"	10:30 AM	JEFFC
6/9/20	Tues	8.79	9.22	"	"	5.0	"	11:00 AM	JEFFC
6/10/20	Wed	8.88	9.18	"	"	6.3	"	2:30 PM	JEFFC
6/11/20	Thurs	7.76	8.88	"	"	6.6	"	7:00 AM	JEFFC
6/12/20	Fri	7.41	9.02	"	"	6.8	"	3:00 PM	JEFFC
6/15/20	MON	7.13	9.99	"	"	6.3	"	1:00 AM	JEFFC
6/14/20	Tues	7.12	10.02	"	"	5.9	"	9:00 AM	JEFFC
6/17/20	Wed	7.10	9.98	"	"	6.0	"	9:00 AM	JEFFC
6/18/20	Thurs	7.07	9.95	"	"	6.7	"	8:00 AM	JEFFC
6/19/20	Fri	7.00	9.93	"	"	6.0	"	1:00 PM	JEFFC
6/22/20	Mon	7.00	9.85	"	"	6.5	"	11:30 AM	JEFFC
6/23/20	Tues	7.02	9.81	"	"	6.0	"	11:30 AM	JEFFC
6/24/20	Wed	7.00	9.72	"	"	6.5	"	2:00 PM	JEFFC
6/25/20	Thurs	6.99	9.68	"	"	6.5	"	10:00 PM	JEFFC
6/26/20	Fri	7.01	9.65	"	"	6.4	"	8:00 AM	JEFFC
6/29/20	Mon	7.00	9.63	"	"	6.4	"	1:30 PM	JEFFC
6/30/20	Tues	7.02	9.60	"	"	6.0	"	3:30 AM	JEFFC
						6.5	"	4:00 PM	JEFFC
						Flow. Total	21,000		
						÷ 30	700 GPD		
						UV -	138.3 ÷ 22 = 6.29	Daily Avg.	

Moniteau Sewage Treatment Plant

Monthly Worksheet for June 2020

Flow $21,000 \div 30 = 700$ Gallons Per Day

UV $138.3 \div 22 = 6.29$ Daily Avg.

pH High - 8.88

Low - 6.99

D.O. High - 10.02

Low - 8.36

Total Nitrogen - $22 + 12.1 = 34.1 \div 2 = 17.05$ Avg.

TSS - $< 5 + < 5 = < 5$ Avg.

Nitrate/Nitrite - $21.0 + 11.8 = 32.8 \div 2 = 16.4$ Avg.

Phosphorus - $1.5 + 2.1 = 3.6 \div 2 = 1.8$ Avg.

CBOD - $< 3 + < 3 = < 3$ Avg.

Fecal Coliforms - $< 1 + < 1 = < 1$ Avg.



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

30 June 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0061664
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0061664-01	Waste Water	06/18/2020 11:30	6/18/20 15:05	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934


Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 06/30/2020 16:47

Lab Sample ID#: 0061664-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 06/18/2020 11:30
Receipt Date: 06/18/2020 15:05

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	12.1	mg/L		0.520	DAA	06/25/20 17:00	06/26/20 18:37
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	06/24/20 09:03	06/24/20 10:15
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	11.8	mg/L		0.520	DAA	06/25/20 17:00	06/26/20 18:37
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	2.1	mg/L		0.50	JPD	06/30/20 11:52	06/30/20 16:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	BB	3.00	AW	06/19/20 10:13	06/24/20 08:35
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	06/18/20 15:37	06/19/20 12:34



SAMPLE RECEIPT AND REVIEW FORM

0061664

PART A: General Information

Client: <u>Monitrac</u>		Work Order: _____	
Received by: <u>DA</u>	Date/Time Received: <u>6/18/20</u> <u>1505</u>	Date Sampled: <u>6/18/20</u>	
Method of Delivery: FedEx UPS Client Drop off <u>EST courier</u> Other: _____			
Sample Receipt Temp: <u>3.1</u>	Samples Received on Ice: <input checked="" type="radio"/> YES NO		
IR Gun # Used: 1 2 <u>(3)</u> 4			
Samples Removed by Satellite Lab Division: Southern(BV) NorthWest(NW) Northern(WP)	Containers removed by Satellite Lab for analysis of:	TCMPN Fecal Coliform TC/EC	ECMPN
Sample State of Collection: <input checked="" type="radio"/> PA NY OH WV Other: _____	PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <input checked="" type="radio"/> NO		

PART B: Receipt Details

Completed (if different from above): _____ / _____ / _____
Signature
Date
Time

Sample Receipt Criteria				Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1 Chain of custody documents included with samples?	Yes	No	N/A	Comments:	YES NO
2 COC form is properly signed in relinquished/received sections?	Yes	No	N/A	Comments:	YES NO
3 Sample containers intact and sealed?	Yes	No	N/A	Circle Applicable: Damaged container Leaking container Custody Seal Broken Other: _____	YES NO
4 Number of containers received match number indicated on COC?	Yes	No	N/A	Sample ID's affected:	YES NO
5 Sample ID's on COC match ID's on bottles?	Yes	No	N/A	Sample ID's and containers affected:	YES NO
6 Date and time on COC match date and time on bottles?	Yes	No	N/A	Sample ID's affected:	YES NO
7 Samples received within holding time?	Yes	No	N/A	ID's and tests affected:	YES NO
8 Samples received at appropriate pH for analysis requested?	Yes	No	N/A	Sample ID's, containers affected and observed pH:	YES NO
9 Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun.	YES NO
11 Adequate sample volume received?	Yes	No	N/A	Analyses Affected:	YES NO
10 VOA vials free of headspace (defined as < 6mm bubble)?	Yes	No	<u>N/A</u>	Sample ID's and containers affected:	YES NO
Other Comments:					Deficiency Log Created: Yes <input checked="" type="radio"/> No



Results Report

Order ID: 0064505

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 0064505-01

Site: 0061664-01

Sample ID:

Collector: Client

Collect Date: 06/18/2020 11:30 am

Sample Type: C

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By	
Inorganics										
Total Kjeldahl Nitrogen (TKN)	0.32	B	mg/L	EPA 351.2	0.50	1	06/24/20	SMD	06/29/20 10:23	DWL

Data Qualifiers:

B The target analyte was detected in the Method, Dilution Water, Instrument or Extraction Blank or Sterility Check at or above the method Reporting Limit or applicable method, client, or regulatory requirement.

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 06/29/2020 4:33 pm
STL_Results Revision #1.9

0064505
Effective: 04/16/2020



SUBCONTRACT ORI
Environmental Service Labor
0061664



0064505
Charles Wanyo

Please report all results to reports@envlabs.com.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
 1803 Philadelphia Street
 Indiana, PA 15701
 Phone: 724-463-8378
 Fax: 724-465-4209
 Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
 1037F MacArthur Road
 Reading, PA 19605
 Phone : (610) 375-8378
 Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0061664-01			
Matrix: Water	Sampled: 06/18/2020 11:30	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	06/30/2020 23:00	07/16/2020 11:30	
Containers Supplied:			
Poly 250mL, H2SO4 (D)	<i>pkc 2006-19-20</i>		

Suburban Testing Labs

Lab Date/Time: *6-19-20 1538* Lab Temp: *25.5*
 Number of containers/coolers match number on COC? Y N
 Sample labels and COC are free of discrepancies? Y N
 All containers in tact? Y N
 Received in lab within acceptable temperature limits? Y N
 40mL VOA vials free of headspace? Y N
 Relinquished by: *[Signature]*
 Received in Lab by: *[Signature]*

Released By	Date	Received By	Date
<i>[Signature]</i>	<i>6/18/20</i>	<i>[Signature]</i>	<i>6-19-20 0940</i>
Released By	Date	Received By	Date
<i>[Signature]</i>	<i>6/19/20</i>	<i>[Signature]</i>	<i>6-19-20 0940</i>





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

18 June 2020

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 0060515
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0060515-01	Waste Water	06/04/2020 11:00	6/4/20 16:46	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Suburban Water Testing Laboratory-Reading, PA DEP Lab ID 06-00208; please see attached subcontract laboratory Report of Analysis for results.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Rebecca Erwin
 Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 06/18/2020 07:40

Lab Sample ID#: 0060515-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001


Sample Date: 06/04/2020 11:00
Receipt Date: 06/04/2020 16:46

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
General Chemistry	Analytical Method: CALC				Prep Method: [CALC]		
Total Nitrogen	22.0	mg/L		0.520	DAA	06/12/20 12:21	06/12/20 18:23
General Chemistry	Analytical Method: SM2540 D-11				Prep Method: No Prep - WetChem		
Total Suspended Solids	<5	mg/L		5	LMB	06/10/20 12:18	06/10/20 14:15
General Chemistry	Analytical Method: SM4500-NO3 E-11 (discrete)				Prep Method: No Prep - WetChem		
Nitrate/Nitrite	21.0	mg/L		0.520	DAA	06/12/20 12:21	06/12/20 18:23
General Chemistry	Analytical Method: SM4500-P E-11				Prep Method: No Prep - WetChem		
Phosphorus	1.5	mg/L		0.20	JPD	06/15/20 11:10	06/15/20 13:00
General Chemistry	Analytical Method: SM5210 B-11				Prep Method: No Prep - WetChem		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L		3.00	JAW	06/05/20 15:09	06/10/20 11:30
Microbiology	Analytical Method: Colilert-18				Prep Method: No Prep - Micro		
Fecal Coliforms	<1	MPN/100 mL		1	DAA	06/04/20 17:28	06/05/20 12:12

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957



NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209



0060515

SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		# of Containers	Matrix	Container Type <small>Preservative</small>	Analysis Requested
		Composite	Grab				
		Date on/off	Time on/off	Date	Time		
Effluent Outfall 001	0060515			6/4/20	11:00 AM	Poly 1000mL	CBOD, TSS 7
	01					Poly 1000mL	Total Nitrogen, Total Phosphorus 12
						H2SO4	Fecal Coliform
						Sterile Plastic 125mL	
						Na2S2O3	

Project Notes: Wastewater

Company/Name: **MONITEAU SCHOOL DISTRICT**

Contact Person: **JEFFREY CAMPBELL**

Address: **1810 WEST SUNBURY ROAD**
WEST SUNBURY, PA 16061
724-406-4426

Phone / Cell: _____

Email: jcambell@moniteau.k12.pa.us

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature) *[Signature]* Date/ Time 6/4/20 1415


Relinquished By: (Signature) *[Signature]* Date/ Time 6/4/20 1615

Received By: (Signature) *[Signature]* Date/ Time 6/4/20 1648

Relinquished By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____



SAMPLE RECEIPT AND REVIEW FORM

PART A: General Information

Client: <u>Non-lead</u>		Work Order: <u>0060515</u>	
Received by: <u>[Signature]</u>		Date/Time Received: <u>6/14/16</u>	
Method of Delivery: <u>Fedex</u>		Other: <u>ESL courier</u>	
Sample Receipt Temp: <u>2.1</u>		Samples Received on Ice: <u>YES</u>	
IR Gun # Used: <u>1 2 3 4</u>		Samples Received by Satellite Lab Division: <u>Southern(BV) NorthWest(NW) Northern(WP)</u>	
Sample State of Collection: <u>PA</u>		Containers removed by Satellite Lab for analysis of: <u>TCMPN Fecal Coliform TC/EC</u>	
Other: <u>NY OH WV</u>		PWSID COMPLIANCE DRINKING WATER SAMPLES: <u>YES</u>	

PART B: Receipt Details

Completed (if different from above): _____

Signature _____
Date / / _____
Time _____

Sample Receipt Criteria		Comments/Qualifiers (Required for Non-Conforming Items)		Deficiency Log Required	
1	Chain of custody documents included with samples?	Yes	N/A	YES	NO
2	COC form is properly signed in relinquished/received sections?	Yes	N/A	YES	NO
3	Sample containers intact and sealed?	Yes	N/A	YES	NO
4	Number of containers received match number indicated on COC?	Yes	N/A	YES	NO
5	Sample ID's on COC match ID's on bottles?	Yes	N/A	YES	NO
6	Date and time on COC match date and time on bottles?	Yes	N/A	YES	NO
7	Samples received within holding time?	Yes	N/A	YES	NO
8	Samples received at appropriate pH for analysis requested?	Yes	N/A	YES	NO
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes	N/A	YES	NO
11	Adequate sample volume received?	Yes	N/A	YES	NO
10	VOA vials free of headspace (defined as < 6mm bubble)?	Yes	N/A	YES	NO
Other Comments:					



Results Report

Order ID: 0062428

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701

Project: TKN Testing

Attn: Accounts Payable

Regulatory ID:

Sample Number: 0062428-01

Site: 0060515-01

Sample ID:

Collector: Client

Collect Date: 06/04/2020 11:00 am

Sample Type: Grab

Department / Test / Parameter	Result	Units	Method	R.L.	DF	Prep Date	By	Analysis Date	By
Inorganics									
Total Kjeldahl Nitrogen (TKN)	1.03	mg/L	EPA 351.2	0.50	1	06/17/20	ZJH	06/17/20 11:55	DWL

Sample Receipt Conditions:

All samples met the sample receipt requirements for the relevant analyses.

The test *pH, Lab* is performed in the Laboratory as soon as possible. These results are not appropriate for compliance with NPDES, SDWA, or other regulatory programs that require analysis within 15 minutes of sample collection and should be considered for informational purposes only.

**pH, Final* for ASTM leachate is performed by method SM 4500-H-B.

All results meet the requirements of STL's TNI (NELAC) Accredited Quality System unless otherwise noted. If your results contain any data qualifiers or comments, you should evaluate useability relative to your needs.

If collectors initials include "STL", samples have been collected in accordance with STL SOP SL0015.

All results reported on an As Received (Wet Weight) basis unless otherwise noted.

This laboratory report may not be reproduced, except in full, without the written approval of STL.

Results are considered Preliminary unless report is signed by authorized representative of STL.

Reviewed and Released By:

Lisa F. Care
Project Manager I

Report Generated On: 06/17/2020 4:40 pm
STL_Results Revision #1.9

0062428
Effective: 04/16/2020





0062428
Lisa F. Care

CONTRACT ORDER

Environmental Service Laboratories, Inc.

0060515

@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.
1803 Philadelphia Street
Indiana, PA 15701
Phone: 724-463-8378
Fax: 724-465-4209
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Suburban Water Testing Labs - Reading
1037F MacArthur Road
Reading, PA 19605
Phone: (610) 375-8378
Fax: 1610-375-4090

State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0060515-01 Matrix: Water	Sampled: 06/04/2020 11:00	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen	06/16/2020 23:00	07/02/2020 11:00	
Containers Supplied: Poly 250mL, H2SO4 (D)			

(1) 250 mL p & H₂SO₄
PhLA YAH

Suburban Testing Labs

Lab Date/Time: 6-5-20 1345 Lab Temp: 20.9°C
 Number of containers/coolers match number on COC? N
 Sample labels and COC are free of discrepancies? N
 All containers in tact? N
 Received in lab within acceptable temperature limits? N
 40mL VOA vials free of headspace? N
 Relinquished by: *[Signature]*
 Received in Lab by: *[Signature]* 20ice

Released By: *[Signature]* Date: 6/4/20
 Received By: *[Signature]* Date: 6-5-20
 Released By: *[Signature]* Date: 6-5-20
 Received By: *[Signature]* Date: 6-5-20

