

**Moniteau School  
District**

**Maintenance  
Department**

**Monthly WasteWater  
Testing Results for  
Dassa McKinney  
Elementary School  
March 2020**

Feb. Reading - 11883000

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sun						11887300			
2	Mon	7.9	0.00	0.31	0.43	0.95	11887300	JEFF R	2:30P	4300
3	Tues	7.8	0.02	0.41	0.45	1.16	11891400	JEFF R	2:30P	0
4	Wed	7.9	0.04	0.63	0.69	1.68	11895900	JEFF R	3:00P	4166
5	Thurs	7.9	0.05	0.56	0.65	1.61	11900600	JEFF R	3:00P	4506
6	Fri	7.8	0.02	0.65	0.70	1.78	11906000	JEFF R	3:00P	4700
7	Sat								2:30P	5406
8	Sun									
9	Mon	7.9	0.03	0.46	0.51	2.40	11910400	JEFF R	2:30P	4400
10	Tues	7.9	0.03	0.57	0.64	2.24	11914900	JEFF R	2:30P	4500
11	Wed	8.0	0.05	0.58	0.64	2.53	11919600	JEFF R	2:30P	4700
12	Thurs	7.9	0.03	0.56	0.61	1.61	11924100	JEFF R	2:30P	4500
13	Fri						11930100			6000
14	Sat									
15	Sun									
16	Mon	7.9	0.01	0.49	0.55	1.52	11933500	JEFF R	1:30P	3400
17	Tues	7.9	0.02	0.49	0.54	1.68	11933800	JEFF R	3:00P	300
18	Wed	7.9	0.03	0.46	0.51	1.71	11934000	JEFF R	3:00P	200
19	Thurs	7.8	0.01	0.61	0.67	1.80	11934400	JEFF R	2:30P	400
20	Fri	7.9	0.05	0.60	0.64	1.80	11934500	JEFF R	11:30A	100
21	Sat									
22	Sun									
23	Mon						11934500			
24	Tues	7.9	0.01	0.42	0.47	1.74	11934600	JEFF C	09:00A	0
25	Wed	7.9	0.02	0.50	0.55	1.72	11934800	JEFF C	02:30P	
26	Thurs	7.9	0.02	1.40	1.42	1.72	11934800	JEFF C	11:00A	
27	Fri						11935200			
28	Sat						11935200			
29	Sun									
30	Mon	8.0	<del>0.04</del>	1.69	1.70	1.54	11935500	JEFF R	1:30P	1000
31	Tues	7.9	0.02	1.52	1.57	1.49	11935700	JEFF C	1:45P	260



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

12 March 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0030508**  
**Project: Drinking Water Dassa McKinney - Monthly 801**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	0030508-01	Drinking Water	03/05/2020 13:00	3/5/20 17:30	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

**REVISED REPORT:** Modified to report correct field chlorine reading. 3/12/20 RAE

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Rebecca Erwin  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 03/12/2020 14:36

**Lab Sample ID#:** 0030508-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 03/05/2020 13:00  
**Receipt Date:** 03/05/2020 17:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-CI G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.750	mg/L		0.200	PFS	03/05/20 13:00	03/05/20 13:00
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	ANP	03/05/20 15:36	03/06/20 17:29
E. Coli	Absent	per 100 mL		1	ANP	03/05/20 15:36	03/06/20 17:29

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8378



FOR INTERNAL LABORATORY USE ONLY

WEST DIVISION  
Main Street  
Pittsburgh, PA 15201  
663-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification		ESL#	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
801 KITCHEN SINK 802 ROOM 617 SINK		0030508	Grab Date: 3/5/20 Time: 1300	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine 15 mg/L 4.1 i.e. (4) 1510 APR 3/15/20
<p>Rotation: 801: Jan, Mar, May, Jul, Sep, Nov 802: Feb, Apr, Jun, Aug, Oct, Dec</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time	Received By: (Signature)		Date/ Time	Company/Name:	
		3-5-20 1300			3/5/20 1730	MONITEAU SCHOOL DISTRICT	
Relinquished By: (Signature)		Date/ Time	Received By: (Signature)		Date/ Time	Address:	
		3-5-20 1503			3/5/20 1730	391 HOOKER ROAD	
Relinquished By: (Signature)		Date/ Time	Received By: (Signature)		Date/ Time	Contact Person:	
						JEFFREY CAMPBELL	
Relinquished By: (Signature)		Date/ Time	Received By: (Signature)		Date/ Time	Phone Number:	
						WEST SUNBURY, PA 16061	
Correct Preservations Y/N/NA		Correct Containers Y/N/NA	Receipt Temperature		Billing Address:		
Y/N/NA	Y/N/NA				icampbell@moniteau.k12.pa.us		
				PWSID:			
				5100316			
Notes/Special Instructions:							
Drinking Water Dassa McKinney - Monthly							



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.75	030520	801		030520	D	1300	32382	0030508-01	BROWNKA_162
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	801		030520	D	1300	32382	0030508-01	BROWNKA_344



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

13 March 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0031140**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	0031140-01	Drinking Water	03/12/2020 12:05	3/13/20 8:59	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 03/13/2020 09:54

**Lab Sample ID#:** 0031140-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 03/12/2020 12:05  
**Receipt Date:** 03/13/2020 08:59

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.480	mg/L		0.200	PFS	03/12/20 12:05	03/12/20 12:05



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



0031140

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>408</u>	0031140	3-20-05	1205	DW	Field	Field	Free Chlorine <u>2.85</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>Notes/Special Instructions:</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>							
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/Time: <u>3-20-05</u>		Company Name: <b>MONITEAU SCHOOL DISTRICT</b>			
Relinquished By: (Signature)		Date/Time: <u>3-20-05</u>		Address: <b>391 HOOKER ROAD</b> <b>WEST SUNBURY, PA 16061</b> <b>JEFFREY CAMPBELL</b>			
Relinquished By: (Signature)		Date/Time:		Contact Person:			
Relinquished By: (Signature)		Date/Time:		Phone Number: <b>724-406-4426</b>			
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Billing Address: <b>JEFFREY CAMPBELL</b>			
Receipt Temperature		Receipt Temperature		PWSID: <b>5100316</b>			





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.75	030520	801		030520	D	1300	32382	0030508-01	BROWNKA_162
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	801		030520	D	1300	32382	0030508-01	BROWNKA_344
5100316	1013	FREE CHLORINE	301	0.48	031220	802		031220	D	1205	32382	0031140-01	BROWNKA_453



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

20 March 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 0031737  
Project: Drinking Water **Dassa McKinney** - Weekly  
Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803	0031737-01	Drinking Water	03/19/2020 11:20	3/19/20 13:45	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 03/20/2020 18:42

**Lab Sample ID#:** 0031737-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803

**Sample Date:** 03/19/2020 11:20  
**Receipt Date:** 03/19/2020 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.300	mg/L		0.200	PFS	03/19/20 11:20	03/19/20 11:20

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Vorchis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>803</u>	<u>0031737</u>	DW	Field	Field	Free Chlorine : <u>30</u> mg/L
Sample Type Date: <u>3/19/06</u> Time: <u>11:00</u>					
ROTATION Wk 1 - 801 Kitchen Sink Wk 2 - 802 Room 617 Sink Wk 3 - 803 Room 606 Sink Wk 4 - 804 Room 408 Sink Wk 5 - 802 Room 617 Sink					
Notes/Special Instructions: Drinking Water Dassa McKinney - Weekly					
Company/Name: Address: Contact Person: Phone Number: Cell Phone: Email Address: Billing Address: PWSID:		MONTEAU SCHOOL DISTRICT 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL 724-406-4426 jcampbell@monteau.k12.pa.us 5100316			
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.) 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.		Received By: (Signature) <u>Alisa Faulk</u> Date/ Time <u>3-20-20 1006</u> Received By: (Signature) _____ Date/ Time _____ Received By: (Signature) _____ Date/ Time _____			
Sampled By: (Signature) _____ Date/ Time <u>3/19/06 11:00</u> Relinquished By: (Signature) _____ Date/ Time <u>3/19/06 13:40</u> Relinquished By: (Signature) _____ Date/ Time _____ Relinquished By: (Signature) _____ Date/ Time _____	Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature _____				



**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.75	030520	801		030520	D	1300	32382	0030508-01	BROWNKA_162
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	801		030520	D	1300	32382	0030508-01	BROWNKA_344
5100316	1013	FREE CHLORINE	301	0.48	031220	802		031220	D	1205	32382	0031140-01	BROWNKA_453
5100316	1013	FREE CHLORINE	301	0.3	031920	803		031920	D	1120	32382	0031737-01	BROWNKA_791





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

20 March 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0031735**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803	0031735-01	Drinking Water	03/19/2020 11:45	3/19/20 13:45	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

07 April 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0032049**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	0032049-01	Drinking Water	03/26/2020 10:42	3/26/20 13:15	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 04/07/2020 08:20

**Lab Sample ID#:** 0032049-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 Room 408 Sink

**Sample Date:** 03/26/2020 10:42  
**Receipt Date:** 03/26/2020 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	1.40	mg/L		0.200	PFS	03/26/20 10:42	03/26/20 10:42

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 483-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>809</u>	<u>0032049</u>	<u>3/26/20</u>	<u>1047</u>	DW	Field	Field	Free Chlorine <u>1.28</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
Sampled By: (Signature)		Date/ Time <u>3/26/20 1047</u>		Notes/Special Instructions:  Drinking Water Dassa McKinney - Weekly			
Relinquished By: (Signature)		Date/ Time <u>3/26/20 1300</u>		Company Name: <b>MONITEAU SCHOOL DISTRICT</b>			
Relinquished By: (Signature)		Date/ Time		Address: <b>391 HOOKER ROAD</b>			
Relinquished By: (Signature)		Date/ Time		Contact Person: <b>JEFFREY CAMPBELL</b>			
Correct Preservations Y / N / NA		Correct Containers Y / N / NA		Phone Number: <b>724-406-4426</b>			
Receipt Temperature		Date/ Time		Cell Phone: <b>jcampbell@moniteau.k12.pa.us</b>			
Correct Preservations Y / N / NA		Date/ Time		Billing Address: <b>WEST SUNBURY, PA 16061</b>			
Correct Preservations Y / N / NA		Date/ Time		PWSID: <b>5100316</b>			



**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.75	030520	801		030520	D	1300	32382	0030508-01	BROWNKA_162
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	801		030520	D	1300	32382	0030508-01	BROWNKA_344
5100316	1013	FREE CHLORINE	301	0.48	031220	802		031220	D	1205	32382	0031140-01	BROWNKA_453
5100316	1013	FREE CHLORINE	301	0.3	031920	803		031920	D	1120	32382	0031737-01	BROWNKA_791
5100316	1013	FREE CHLORINE	301	1.4	032620	804		032620	D	1042	32382	0032049-01	BROWNKA_1203



**Moniteau School**

**District**

**Maintenance**

**Department**

**Monthly WasteWater**

**Testing Results for**

**Moniteau High School**

**March 2020**

Moniteau High School Sewage Treatment Plant  
Permit # PA0091341

Daily Operations Worksheet

Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Meter Reading	Time	Operator
3/2	Mon	7.98	9.66	7.83	9.82	4.5		11:30A	JEFFC
3/3	Tues	7.99	9.62	7.85	9.91	4.3		9:15A	JEFFC
3/4	WED	8.00	9.85	7.84	9.72	4.5		9:00A	JEFFC
3/5	Thurs	8.01	10.04	7.83	9.44	4.3		10:00A	JEFFC
3/6	Fri	7.99	10.92	8.04	9.24	5.2		10:45A	JEFFR
3/9	Mon	7.99	10.92	8.04	9.24	5.2		10:45A	JEFFR
3/10	Tues	7.80	10.16	7.60	7.89	5.0		10:45A	JEFFR
3/11	Wed	7.91	9.09	8.01	9.01	2.6		12:00P	JEFFR
3/12	Thurs	7.87	7.98	7.97	8.02	4.8		11:30A	JEFFR
3/13	Fri	7.85	8.05	7.95	8.00	4.5		1:00P	JEFFC
3/16	Mon	8.01	9.12	7.97	9.10	4.5	No Flow	10:15A	JEFFC
3/17	Tues	8.08	10.23	8.02	9.21	4.5	"	1:00P	JEFFC
3/18	Wed	8.19	10.56	8.06	9.53	4.5	"	11:00A	JEFFC
3/19	Thurs	8.21	10.62	8.10	9.61	4.5	"	10:00A	JEFFC
3/20	Fri	8.25	10.68	8.12	9.68	4.6	"	2:30P	JEFFC
3/23	Mon	8.75	10.20	8.94	10.95	4.5	"	2:30P	JEFFC
3/24	Tues	8.70	10.18	8.71	10.22	4.5	"	09:00A	JEFFC
3/25	Wed	8.68	10.12	8.69	10.17	4.5	"	08:00A	JEFFC
3/26	Thurs	8.95	10.61	8.95	9.86	5.4	"	11:30A	JEFFC
3/27	Fri	8.92	10.58	8.90	9.57	5.5	"	1:00 AM	JEFFC
3/30	Mon	8.72	10.31	8.68	9.02	5.1	"	09:00A	JEFFC
3/31	Tues	8.17	9.88	8.71	10.21	5.6	"	1:00 AM	JEFFC
						102.6	22=4.66		

TEST DAY

No Flow

"

"

"

"

"

"

"

"

"

"

"

"

Moniteau High School  
WASTEWATER TREATMENT PLANT  
MONTHLY WORK SHEET FOR MARCH 2020

Flow  $83,598 \div 31 = 2696.71$  Daily Avg.

U.V.  $102.6 \div 22 = 4.66$  Avg.

PH Low 7.60

High 8.95

D.O. Low 7.89

High 10.95

Total Nitrogen =  $21.1 + 27.4 = 48.5 \div 2 = 24.25$  mg/l

Total Suspended Solids =  $< 5 + < 5 = < 5$  mg/l

Nitrate/Nitrite =  $21.1 + 27.4 = 48.5 \div 2 = 24.25$  mg/l.

Phosphorus =  $0.34 + 3.1 = 3.44 \div 2 = 1.72$  mg/l.

COD =  $< 3.00 + 4.18 = 7.18 \div 2 = 3.59$  mg/l.

Fecal Coliforms =  $< 1 + < 1 = < 1$





COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST  
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 FACILITY: MONTEAU JR SR HIGH SCHOOL  
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220  
 STAGE: Final Effluent

PA0091341  
PERMIT NUMBER

001  
OUTFALL NUMBER

Reporting Frequency: Monthly  
 DMR Effective From: 03/01/2020  
 DMR Effective To: 03/31/2020  
 Permit Expires: 05/31/2022  
 Permit Application Due: 12/02/2021  
 No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2020	03	01	2020	03	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION		UNITS	SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS			
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***		7.89	***	mg/L	1/weekday	Recorded
	PERMIT REQUIREMENT	***		4.0 Min	***	mg/L	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***		7.60	***	8.95	1/weekday	Recorded
	PERMIT REQUIREMENT	***		6.0 Min	***	9.0 Max	1/week	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		<5.0	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		30 Avg Mo	***	mg/L	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***		24.25	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	mg/L	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***		1.72	***	mg/L	2/month	Grab
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	mg/L	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		4.66	***	µW/cm²	1/weekday	Recorded
	PERMIT REQUIREMENT	***		Monitor & Report Avg Mo	***	µW/cm²	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.002696	***	***	***	MGD	1/weekday	Recorded
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	***	***	MGD	1/week	Measured

COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<1.0	<1.0		2/month	Grab
	PERMIT REQUIREMENT	***		***	2000 Geo Mean	10000 IMAX	No./100 ml	2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	3.59	***		2/month	Grab
	PERMIT REQUIREMENT	***		***	25 Avg Mo	***	mg/L	2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



## Your eDMR Report Has Been Received For Permit No. PA0091341

---

From: depgreenporthelpdesk@state.pa.us

To: monwarrior2003@yahoo.com; monwarrior2003@yahoo.com; mcafoose92@hotmail.com

Date: Monday, April 13, 2020, 01:30 PM EDT

---

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL

**Permit Number:** PA0091341

**Report Frequency:** Monthly

**Report Type:** DMR

**Reporting Period:** 03/01/2020-03/31/2020

**Report Due Date:** 04/28/2020

**Submitted By:** Jeffrey Campbell

**Submission Id:** 201847

**Submission Status:** Received

**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

27 March 2020

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 0030471**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Grab	0030471-01	Waste Water	03/05/2020 11:00	3/5/20 15:10	

**Report Narrative**

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Summit Environmental Technologies, Inc., PA-DEP ID 68-01335; please see attached subcontract laboratory Report of Analysis for results.

**Definitions**

RL Reporting Limit

**Certifications**

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

**Approved By**

Rebecca Erwin  
 Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 03/27/2020 09:12

**Lab Sample ID#:** 0030471-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Jeffrey Campbell  
**Client Sample ID:** Effluent Grab

**Sample Date:** 03/05/2020 11:00  
**Receipt Date:** 03/05/2020 15:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	27.4	mg/L		1.04	TLL	03/13/20 15:44	03/13/20 15:47
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	03/09/20 10:49	03/09/20 12:15
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	27.4	mg/L		1.04	TLL	03/13/20 15:44	03/13/20 15:47
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	3.1	mg/L		0.40	JPD	03/07/20 13:13	03/10/20 14:30
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	4.18	mg/L		3.00	AW	03/06/20 17:25	03/11/20 11:00
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	ANP	03/05/20 15:33	03/06/20 11:53









Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

March 26, 2020

Rebecca Erwin  
Environmental Service Laboratories Inc  
1803 Philadelphia Street  
Indiana, PA 15701  
TEL:  
FAX:  
RE: 0030471

Order No.: 20030890

Dear Rebecca Erwin:

Summit Environmental Technologies, Inc. received 1 sample(s) on 3/13/2020 for the analyses presented in the following report.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative.

Quality control data is within laboratory defined or method specified acceptance limits except where noted.

If you have any questions regarding these tests results, please feel free to call the laboratory.

Sincerely,

Holly Florea  
Project Manager  
3310 Win St.  
Cuyahoga Falls, Ohio 44223

Arkansas 88-0735, California 07256CA, Colorado, Connecticut PH-0108, Delaware, Florida NELAC E87688, Georgia E87688, Idaho OH00923, Illinois 200061, Indiana C-OH-13, Kansas E-10347, Kentucky (Underground Storage Tank) 3, Kentucky 90146, Louisiana 04061, Maryland 339, Minnesota 409711, New Hampshire 2996, New Jersey OH006, New York 11777, North Carolina 39705 and 631, North Dakota R-201, Ohio DW, Ohio VAP CL0052, Oklahoma 9940, Oregon OH200001, Pennsylvania 010, Rhode Island LA000317, South Carolina 92016001, Texas T104704466-11-5, Utah OH009232011-1, Virginia VELAP 9456, Washington C891



**SUMMIT**  
ENVIRONMENTAL TECHNOLOGIES, INC.  
Analytical Laboratories

Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

## Case Narrative

WO#: 20030890  
Date: 3/26/2020

---

**CLIENT:** Environmental Service Laboratories Inc  
**Project:** 0030471

---

This report in its entirety consists of the following documents: Cover Letter, Case Narrative, Analytical Results, QC Summary Report, Applicable Accreditation Information, Chain-of-Custody, Cooler Receipt Form, and other applicable forms as necessary. All documents contain the Summit Environmental Technologies, Inc., Work Order Number assigned to this report.

Summit Environmental Technologies, Inc., holds the accreditations/certifications listed at the bottom of the cover letter that may or may not pertain to this report. Please refer to the "Accreditation Program Analytes Report" for accredited analytes list.

The information contained in this analytical report is the sole property of Summit Environmental Technologies, Inc. and that of the customer. It cannot be reproduced in any form without the consent of Summit Environmental Technologies, Inc. or the customer for which this report was issued. The results contained in this report are only representative of the samples received. Conditions can vary at different times and at different sampling conditions. Summit Environmental Technologies, Inc. is not responsible for use or interpretation of the data included herein.

All results for Solid Samples are reported on an "as received" or "wet weight" basis unless indicated as "dry weight" using the "-dry" designation on the reporting units.

This report is believed to meet all of the requirements of the accrediting agency, where applicable. Any comments or problems with the analytical events associated with this report are noted below.

---

Original



**SUMMIT**  
 ENVIRONMENTAL TECHNOLOGIES, INC  
 Analytical Laboratories

Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.setek.com>

## Workorder Sample Summary

WO#: 20030890  
 26-Mar-20

**CLIENT:** Environmental Service Laboratories Inc  
**Project:** 0030471

Lab SampleID	Client Sample ID	Tag No	Date Collected	Date Received	Matrix
20030890-001	0030471-01		3/5/2020 11:00:00 AM	3/13/2020 3:08:00 PM	Non-Potable Water



**SUMMIT**  
 ENVIRONMENTAL TECHNOLOGIES, INC.  
 Analytical Laboratories

Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.settek.com>

# Analytical Report

(consolidated)

WO#: 20030890

Date Reported: 3/26/2020

**CLIENT:** Environmental Service Laboratories Inc

**Collection Date:** 3/5/2020 11:00:00 AM

**Project:** 0030471

**Lab ID:** 20030890-001

**Matrix:** NON-POTABLE WATER

**Client Sample ID** 0030471-01

Analyses	Result	PQL	Qual	Units	DF	Date Analyzed
<b>TOTAL KJELDAHL NITROGEN (4500-NH3-D) 2011</b>					<b>A4500-NH3-D</b>	<b>A4500-NOR</b> Analyst: DNS
Nitrogen, Total Kjeldahl	ND	0.500		mg/L	1	3/26/2020 3:10:00 PM

**Qualifiers:**  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected  
 RL Reporting Detection Limit

M Manual Integration used to determine area response  
 PL Permit Limit  
 W Sample container temperature is out of limit as specified at testcode

Original





Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.settek.com>

# QC SUMMARY REPORT

WO#: 20030890  
 26-Mar-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0030471

**BatchID:** 42706

Sample ID: MB-42706	SampType: MBLK	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 3/25/2020	RunNo: 111031						
Client ID: PBW	Batch ID: 42706	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 3/26/2020	SeqNo: 2700883						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	ND	0.500									

Sample ID: LCS-42706	SampType: LCS	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 3/25/2020	RunNo: 111031						
Client ID: LCSW	Batch ID: 42706	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 3/26/2020	SeqNo: 2700884						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	14.3	0.500	12.50	0	114	85	115				

Sample ID: RLC-42706	SampType: RLC	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 3/25/2020	RunNo: 111031						
Client ID: BatchQC	Batch ID: 42706	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 3/26/2020	SeqNo: 2700885						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	0.566	0.500	0.5000	0	113	50	150				

Sample ID: 20030826-001CMS	SampType: MS	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 3/25/2020	RunNo: 111031						
Client ID: BatchQC	Batch ID: 42706	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 3/26/2020	SeqNo: 2700907						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	13.7	0.500	12.50	0.9830	102	80	120				

**Qualifiers:** B Analyte detected in the associated Method Blank  
 J Analyte detected below quantitation limits  
 ND Not Detected  
 R RPD outside accepted recovery limits  
 E Value above quantitation range  
 M Manual Integration used to determine area response  
 P Second column confirmation exceeds  
 RL Reporting Detection Limit  
 H Holding times for preparation or anal  
 MC Value is below Minimum Compound  
 PL Permit Limit  
 S Spike Recovery outside accepted reco



**SUMMIT**  
ENVIRONMENTAL TECHNOLOGIES, INC  
Analytical Laboratories

Summit Environmental Technologies, Inc.  
3310 Win St  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

# QC SUMMARY REPORT

WO#: 20030890  
26-Mar-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0030471

**BatchID:** 42706

Sample ID: 20030826-001CMS	SampType: MS	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 3/25/2020	RunNo: 111031						
Client ID: BatchQC	Batch ID: 42706	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 3/26/2020	SeqNo: 2700907						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Sample ID: 20030826-001CMSD	SampType: MSD	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 3/25/2020	RunNo: 111031						
Client ID: BatchQC	Batch ID: 42706	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 3/26/2020	SeqNo: 2700908						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Nitrogen, Total Kjeldahl 15.1 0.500 12.50 0.9830 113 80 120 13.70 9.72 20

Sample ID: 20030895-001ADUP	SampType: DUP	TestCode: TKN_NPW(45)	Units: mg/L	Prep Date: 3/25/2020	RunNo: 111031						
Client ID: BatchQC	Batch ID: 42706	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 3/26/2020	SeqNo: 2700920						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Nitrogen, Total Kjeldahl 2.75 0.500 3.130 12.9 20

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range	H	Holding times for preparation or analy
J	Analyte detected below quantitation limits	M	Manual Integration used to determine area response	MC	Value is below Minimum Compound	
ND	Not Detected	P	Second column confirmation exceeds	PL	Permit Limit	Original
R	RPD outside accepted recovery limits	RL	Reporting Detection Limit	S	Spike Recovery outside accepted reco	



These commonly used Qualifiers and Acronyms may or may not be present in this report.

#### Qualifiers

U	The compound was analyzed for but was not detected above the MDL.
J	The reported value is greater than the Method Detection Limit but less than the Reporting Limit.
H	The hold time for sample preparation and/or analysis was exceeded. Not Clean Water Act compliant.
D	The result is reported from a dilution.
E	The result exceeded the linear range of the calibration or is estimated due to interference.
MC	The result is below the Minimum Compound Limit.
*	The result exceeds the Regulatory Limit or Maximum Contamination Limit.
m	Manual integration was used to determine the area response.
d	Manual integration in which peak was deleted
N	The result is presumptive based on a Mass Spectral library search assuming a 1:1 response.
P	The second column confirmation exceeded 25% difference.
C	The result has been confirmed by GC/MS.
X	The result was not confirmed when GC/MS Analysis was performed.
B	The analyte was detected in the Method Blank at a concentration greater than the RL.
MB+	The analyte was detected in the Method Blank at a concentration greater than the MDL.
G	The ICB or CCB contained reportable amounts of analyte.
QC-/+	The CCV recovery failed low (-) or high (+).
R/QDR	The RPD was outside of accepted recovery limits.
QL-/+	The LCS or LCSD recovery failed low (-) or high (+).
QLR	The LCS/LCSD RPD was outside of accepted recovery limits.
QM-/+	The MS or MSD recovery failed low (-) or high (+).
QMR	The MS/MSD RPD was outside of accepted recovery limits.
QV-/+	The ICV recovery failed low (-) or high (+).
S	The spike result was outside of accepted recovery limits.
W	Samples were received outside temperature limits (0° – 6° C). Not Clean Water Act compliant.
Z	Deviation; A deviation from the method was performed; Please refer to the Case Narrative for additional information

#### Acronyms

ND	Not Detected	RL	Reporting Limit
QC	Quality Control	MDL	Method Detection Limit
MB	Method Blank	LOD	Level of Detection
LCS	Laboratory Control Sample	LOQ	Level of Quantitation
LCSD	Laboratory Control Sample Duplicate	PQL	Practical Quantitation Limit
QCS	Quality Control Sample	CRQL	Contract Required Quantitation Limit
DUP	Duplicate	PL	Permit Limit
MS	Matrix Spike	RegLvl	Regulatory Limit
MSD	Matrix Spike Duplicate	MCL	Maximum Contamination Limit
RPD	Relative Percent Different	MinCL	Minimum Compound Limit
ICV	Initial Calibration Verification	RA	Reanalysis
ICB	Initial Calibration Blank	RE	Reextraction
CCV	Continuing Calibration Verification	TIC	Tentatively Identified Compound
CCB	Continuing Calibration Blank	RT	Retention Time
RLC	Reporting Limit Check	CF	Calibration Factor

This list of Qualifiers and Acronyms reflects the most commonly utilized Qualifiers and Acronyms for reporting. Please refer to the Analytical Notes in the Case Narrative for any Qualifiers or Acronyms that do not appear in this list or for additional information regarding the use of these Qualifiers on reported data.



**SUMMIT**  
 ENVIRONMENTAL TECHNOLOGIES, INC.  
*Analytical Laboratories*

Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.settek.com>

# DATES REPORT

WO#: 20030890  
 26-Mar-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0030471

Sample ID	Client Sample ID	Collection Date	Matrix	Test Name	Leachate Date	Prep Date	Analysis Date
20030890-001A	0030471-01	3/5/2020 11:00:00 AM	Non-Potable Water	Total Kjeldahl Nitrogen (4500-NH3-D		3/25/2020 9:05:00 AM	3/26/2020 3:10:00 PM

Original





**SUMMIT**  
 ENVIRONMENTAL TECHNOLOGIES, INC  
 Analytical Laboratories

Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.settek.com>

**Accreditation Program  
 Analytes Report**

WO#: 20030890  
 26-Mar-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0030471

**State:** PA  
**Program Name:** Pennsylvanis DEP

Test Name	Matrix	Analyte	Status
Total Kjeldahl Nitrogen (4500-NH3-D) 2011	Non-Potable Water	Nitrogen, Ammonia	A

**Key**

PA-NELAP    A    Accredited

Original #1

SUBCONTRACT ORDER  
Environmental Service Laboratories, Inc.  
0030471

20030890

Please report all results to reports@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:	RECEIVING LABORATORY:
Environmental Service Laboratories, Inc. 1803 Philadelphia Street Indiana, PA 15701 Phone: 724-463-8378 Fax: 724-465-4209 Project Manager: Rebecca Erwin	Summit Environmental Technologies, Inc. 3310 Win Street Cuyahoga Falls, OH 44223 Phone: (330) 253-8211 Fax: (330) 253-4489
	State of Origin: PA

Analysis	Due	Expires	Comments
Sample ID: 0030471-01 Matrix: Water	Sampled: 03/05/2020 11:00	Sample Type: Grab	Sampled By: Jeffrey Campbell
Total Kjeldahl Nitrogen	03/17/2020 23:00	04/02/2020 11:00	
Containers Supplied: Poly 250mL, H2SO4 (1)			

Handwritten notes: 3/13/20 1508  
SET sample 3.1403  
3.4

Released By: <i>Rebecca G</i>	Date: <i>3/12/20</i>	Received By: <i>[Signature]</i>	Date: <i>3.13.20</i>
Released By: <i>[Signature]</i>	Date: <i>3.13.20</i>	Received By: <i>Jackie Rosillo</i>	Date: <i>3/13/20 11:00</i>





Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

## Sample Log-In Check List

Client Name: **ENV-PA-15701** Work Order Number: **20030890** RcptNo: **1**

Logged by:	<b>Jacqueline Rasile</b>	<b>3/13/2020 3:08:00 PM</b>	<i>Jacqueline Rasile</i>
Completed By:	<b>Jacqueline Rasile</b>	<b>3/15/2020 5:29:42 PM</b>	<i>Jacqueline Rasile</i>
Reviewed By:	<b>Sara E. Kidd</b>	<b>3/16/2020 10:00:54 AM</b>	<i>Sara Kidd</i>

### Chain of Custody

1. Is Chain of Custody complete? Yes  No  Not Present   
 2. How was the sample delivered? Summit

### Log In

3. Coolers are present? Yes  No  NA   
 4. Shipping container/cooler in good condition? Yes  No   
 Custody seals intact on shipping container/cooler? Yes  No  Not Present   
 No. Seal Date: Signed By:  
 5. Was an attempt made to cool the samples? Yes  No  NA   
 6. Were all samples received at a temperature of >0° C to 6.0°C Yes  No  NA   
 7. Sample(s) in proper container(s)? Yes  No   
 8. Sufficient sample volume for indicated test(s)? Yes  No   
 9. Are samples (except VOA and ONG) properly preserved? Yes  No   
 10. Was preservative added to bottles? Yes  No  NA   
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes  No  No VOA Vials   
 12. Were any sample containers received broken? Yes  No   
 13. Does paperwork match bottle labels? Yes  No   
 (Note discrepancies on chain of custody)  
 14. Are matrices correctly identified on Chain of Custody? Yes  No   
 15. Is it clear what analyses were requested? Yes  No   
 16. Were all holding times able to be met? Yes  No   
 (If no, notify customer for authorization.)

### Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes  No  NA

Person Notified:	_____	Date:	_____
By Whom:	_____	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	_____		
Client Instructions:	_____		

18. Additional remarks:

### Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	3.4	Good	Not Present			



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

03 April 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0031653**  
**Project: Wastewater**  
**Project Description: Wastewater**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	0031653-01	Waste Water	03/19/2020 10:30	3/19/20 13:45	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

TKN subcontracted to Summit Environmental Technologies, Inc., PA-DEP ID 68-01335; please see attached subcontract laboratory Report of Analysis for results.

#### Definitions

- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Rebecca Erwin*

Rebecca Erwin  
Project Manager







1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 04/03/2020 13:50

**Lab Sample ID#:** 0031653-01  
**Sample Type:** Waste Water  
**Sample Source:** Grab  
**Sampler:** Client  
**Client Sample ID:** Effluent Outfall 001


**Sample Date:** 03/19/2020 10:30  
**Receipt Date:** 03/19/2020 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>General Chemistry</b>	<b>Analytical Method: CALC</b>				<b>Prep Method: [CALC]</b>		
Total Nitrogen	21.1	mg/L		1.04	DAA	03/26/20 14:00	03/30/20 14:47
<b>General Chemistry</b>	<b>Analytical Method: SM2540 D-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Total Suspended Solids	<5	mg/L		5	LMB	03/24/20 11:05	03/24/20 12:45
<b>General Chemistry</b>	<b>Analytical Method: SM4500-NO3 E-11 (discrete)</b>				<b>Prep Method: No Prep - WetChem</b>		
Nitrate/Nitrite	21.1	mg/L		1.04	DAA	03/26/20 14:00	03/30/20 14:47
<b>General Chemistry</b>	<b>Analytical Method: SM4500-P E-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Phosphorus	0.34	mg/L		0.10	JPD	03/25/20 10:15	03/25/20 14:00
<b>General Chemistry</b>	<b>Analytical Method: SM5210 B-11</b>				<b>Prep Method: No Prep - WetChem</b>		
Carbonaceous Biochemical Oxygen Demand	<3.00	mg/L	BB	3.00	AW	03/20/20 13:30	03/25/20 09:30
<b>Microbiology</b>	<b>Analytical Method: Colilert-18</b>				<b>Prep Method: No Prep - Micro</b>		
Fecal Coliforms	<1	MPN/100 mL		1	ANP	03/19/20 15:32	03/20/20 13:00

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Benetysville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376



NORTHERN DIVISION  
435 Broad Street  
Montboursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957



NORTHWEST  
950 Main Street  
Sharpsville, PA  
(724) 463-TEST  
FAX: (724) 465



0031653

## SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

Page 3 of 15

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type Preservative	Analysis Requested
		Composite	Grab				
		Date on/of	Time on/of	Date	Time		
Effluent Outfall 001	0031653			3/19/20	10:30 AM	Poly 1000mL	CBOD, TSS
						None	
						Poly 1000mL	Total Nitrogen, Total Phosphorus
	01					Sterile Plastic 125mL	2.4 ice (3) Fecal Coliform ✓ 1345 AAF 3/19/20
						Na2S2O3	

**Project Notes:** Wastewater

**Company/Name:** MONITEAU SCHOOL DISTRICT

**Contact Person:** JEFFREY CAMPBELL

**Address:** 1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061

**Phone / Cell:** 724-406-4426

**Email:** jcampbell@moniteau.k12.pa.us

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Received By: (Signature)  Date/ Time 3/19/20 10:30 AM	Received By: (Signature)  Date/ Time 3/19/20 11:45
Relinquished By: (Signature)  Date/ Time 3/19/20 13:00	Relinquished By: (Signature)  Date/ Time 3/19/20 14:00
Relinquished By: (Signature)  Date/ Time	Relinquished By: (Signature)  Date/ Time

Correct Preservations Y / N / NA
Correct Containers Y / N / NA
Receipt Temperature





# SAMPLE RECEIPT AND REVIEW FORM

## PART A: General Information



0031653

Client: <u>Moniteau S.D.</u>		Work Order: _____	
Received by: <u>AMP</u>		Date/Time Received: <u>3/19/20 1345</u>	Date Sampled: <u>3/19/20</u>
Method of Delivery: FedEx    UPS    Client Drop off <u>ESL courier</u> Other: _____			
Sample Receipt Temp: <u>2.4</u>		Samples Received on Ice: <u>YES</u> NO	
IR Gun # Used: 1    2 <u>3</u> 4		Containers removed by Satellite Lab for analysis of: <u>TCMPN</u> Fecal Coliform    TC/EC	
Samples Removed by Satellite Lab Division: Southern(BV)    NorthWest(NW)    Northern(WP)		ECMPN	
Sample State of Collection: <u>PA</u> NY    OH    WV    Other: _____		PWSID COMPLIANCE DRINKING WATER SAMPLES: YES <u>NO</u>	

## PART B: Receipt Details

Completed (if different from above): \_\_\_\_\_ / \_\_\_\_ / \_\_\_\_  
Signature Date Time

Sample Receipt Criteria				Comments/Qualifiers (Required for Non-Conforming Items)	Deficiency Log Required
1	Chain of custody documents included with samples?	Yes	No	N/A	Comments: YES    NO
2	COC form is properly signed in relinquished/received sections?	Yes	No	N/A	Comments: YES    NO
3	Sample containers intact and sealed?	Yes	No	N/A	Circle Applicable: Damaged container    Leaking container    Custody Seal Broken Other: _____ YES    NO
4	Number of containers received match number indicated on COC?	Yes	No	N/A	Sample ID's affected: YES    NO
5	Sample ID's on COC match ID's on bottles?	Yes	No	N/A	Sample ID's and containers affected: YES    NO
6	Date and time on COC match date and time on bottles?	Yes	No	N/A	Sample ID's affected: YES    NO
7	Samples received within holding time?	Yes	No	N/A	ID's and tests affected: YES    NO
8	Samples received at appropriate pH for analysis requested?	Yes	No	N/A	Sample ID's, containers affected and observed pH: YES    NO
9	Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	Yes	No	N/A	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable condition as the cooling process has begun. YES    NO
11	Adequate sample volume received?	Yes	No	N/A	Analyses Affected: YES    NO
10	VOA vials free of headspace (defined as < 6mm bubble)?	Yes	No	<u>N/A</u>	Sample ID's and containers affected: YES    NO
Other Comments:					Deficiency Log Created: Yes <u>No</u>



Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

April 03, 2020

Rebecca Erwin  
Environmental Service Laboratories Inc  
1803 Philadelphia Street  
Indiana, PA 15701  
TEL:  
FAX:  
RE: 0031653

Order No.: 20031364

Dear Rebecca Erwin:

Summit Environmental Technologies, Inc. received 1 sample(s) on 3/20/2020 for the analyses presented in the following report.

There were no problems with the analytical events associated with this report unless noted in the Case Narrative.

Quality control data is within laboratory defined or method specified acceptance limits except where noted.

If you have any questions regarding these tests results, please feel free to call the laboratory.

Sincerely,

*Sara Kidd*

Sara E. Kidd  
Project Manager  
3310 Win St.  
Cuyahoga Falls, Ohio 44223

Arkansas 88-0735, California 07256CA, Colorado, Connecticut PH-0108, Delaware, Florida NELAC E87688, Georgia E87688, Idaho OH00923, Illinois 200061, Indiana C-OH-13, Kansas E-10347, Kentucky (Underground Storage Tank) 3, Kentucky 90146, Louisiana 04061, Maryland 339, Minnesota 409711, New Hampshire 2996, New Jersey OH006, New York 11777, North Carolina 39705 and 631, North Dakota R-201, Ohio DW, Ohio VAP CL0052, Oklahoma 9940, Oregon OH200001, Pennsylvania 010, Rhode Island LA000317, South Carolina 92016001, Texas T104704466-11-5, Utah OH009232011-1, Virginia VELAP 9456, Washington C891

Page 1 of 10





**SUMMIT**  
ENVIRONMENTAL TECHNOLOGIES, INC.  
Analytical Laboratories

Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

## Case Narrative

WO#: 20031364  
Date: 4/3/2020

---

**CLIENT:** Environmental Service Laboratories Inc  
**Project:** 0031653

---

This report in its entirety consists of the following documents: Cover Letter, Case Narrative, Analytical Results, QC Summary Report, Applicable Accreditation Information, Chain-of-Custody, Cooler Receipt Form, and other applicable forms as necessary. All documents contain the Summit Environmental Technologies, Inc., Work Order Number assigned to this report.

Summit Environmental Technologies, Inc., holds the accreditations/certifications listed at the bottom of the cover letter that may or may not pertain to this report. Please refer to the "Accreditation Program Analytes Report" for accredited analytes list.

The information contained in this analytical report is the sole property of Summit Environmental Technologies, Inc. and that of the customer. It cannot be reproduced in any form without the consent of Summit Environmental Technologies, Inc. or the customer for which this report was issued. The results contained in this report are only representative of the samples received. Conditions can vary at different times and at different sampling conditions. Summit Environmental Technologies, Inc. is not responsible for use or interpretation of the data included herein.

All results for Solid Samples are reported on an "as received" or "wet weight" basis unless indicated as "dry weight" using the "-dry" designation on the reporting units.

This report is believed to meet all of the requirements of the accrediting agency, where applicable. Any comments or problems with the analytical events associated with this report are noted below.

---

Original  
Page 2 of 10



**SUMMIT**  
 ENVIRONMENTAL TECHNOLOGIES, INC  
 Analytical Laboratories

Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.settek.com>

## Workorder Sample Summary

WO#: 20031364  
 03-Apr-20

**CLIENT:** Environmental Service Laboratories Inc  
**Project:** 0031653

Lab SampleID	Client Sample ID	Tag No	Date Collected	Date Received	Matrix
20031364-001	0031653-01		3/19/2020 10:30:00 AM	3/20/2020 10:05:00 AM	Non-Potable Water



Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.settek.com>

# Analytical Report

(consolidated)

WO#: 20031364

Date Reported: 4/3/2020

**CLIENT:** Environmental Service Laboratories Inc

**Collection Date:** 3/19/2020 10:30:00 AM

**Project:** 0031653

**Lab ID:** 20031364-001

**Matrix:** NON-POTABLE WATER

**Client Sample ID:** 0031653-01

Analyses	Result	PQL	Qual	Units	DF	Date Analyzed
<b>TOTAL KJELDAHL NITROGEN (4500-NH3-D) 2011</b>						
		<b>A4500-NH3-D</b>	<b>A4500-NOR</b>			Analyst: CXS
Nitrogen, Total Kjeldahl	ND	0.500		mg/L	1	4/2/2020 4:54:00 PM

**Qualifiers:**  
 H Holding times for preparation or analysis exceeded  
 ND Not Detected  
 RL Reporting Detection Limit

M Manual Integration used to determine area response  
 PL Permit Limit  
 W Sample container temperature is out of limit as specified at testcode

Original  
 Page 4 of 10



**SUMMIT**  
ENVIRONMENTAL TECHNOLOGIES, INC  
Analytical Laboratories

Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

# QC SUMMARY REPORT

WO#: 20031364  
03-Apr-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0031653

**BatchID:** 42786

Sample ID: MB-42786	SampType: MBLK	TestCode: TKN_NPW(45	Units: mg/L	Prep Date: 4/1/2020	RunNo: 111331						
Client ID: PBW	Batch ID: 42786	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 4/2/2020	SeqNo: 2711473						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	ND	0.500									

Sample ID: RLC-42786	SampType: RLC	TestCode: TKN_NPW(45	Units: mg/L	Prep Date: 4/1/2020	RunNo: 111331						
Client ID: BatchQC	Batch ID: 42786	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 4/2/2020	SeqNo: 2711474						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	0.614	0.500	0.5000	0	123	50	150				

Sample ID: LCS-42786	SampType: LCS	TestCode: TKN_NPW(45	Units: mg/L	Prep Date: 4/1/2020	RunNo: 111331						
Client ID: LCSW	Batch ID: 42786	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 4/2/2020	SeqNo: 2711475						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	13.3	0.500	12.50	0	106	85	115				

Sample ID: 20031356-001ADUP	SampType: DUP	TestCode: TKN_NPW(45	Units: mg/L	Prep Date: 4/1/2020	RunNo: 111331						
Client ID: BatchQC	Batch ID: 42786	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 4/2/2020	SeqNo: 2711483						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	ND	0.500						0	0	20	

<b>Qualifiers:</b>	B	Analyte detected in the associated Method Blank	E	Value above quantitation range	H	Holding times for preparation or analy
	J	Analyte detected below quantitation limits	M	Manual Integration used to determine area response	MC	Value is below Minimum Compound
	ND	Not Detected	P	Second column confirmation exceeds	PL	Permit Limit
	R	RPD outside accepted recovery limits	RL	Reporting Detection Limit	S	Spike Recovery outside accepted reco





**SUMMIT**  
ENVIRONMENTAL TECHNOLOGIES, INC  
*Analytical Laboratories*

Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

# QC SUMMARY REPORT

WO#: 20031364  
03-Apr-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0031653

**BatchID:** 42786

Sample ID: 20031356-001ADUP	SampType: DUP	TestCode: TKN_NPW(45	Units: mg/L	Prep Date: 4/1/2020	RunNo: 111331						
Client ID: BatchQC	Batch ID: 42786	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 4/2/2020	SeqNo: 2711483						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Sample ID: 20031360-001AMS	SampType: MS	TestCode: TKN_NPW(45	Units: mg/L	Prep Date: 4/1/2020	RunNo: 111331						
Client ID: BatchQC	Batch ID: 42786	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 4/2/2020	SeqNo: 2711483						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	14.1	0.500	12.50	1.730	99.0	80	120				

Sample ID: 20031360-001AMSD	SampType: MSD	TestCode: TKN_NPW(45	Units: mg/L	Prep Date: 4/1/2020	RunNo: 111331						
Client ID: BatchQC	Batch ID: 42786	TestNo: A4500-NH3-D	A4500-NorgC	Analysis Date: 4/2/2020	SeqNo: 2711494						
Analyte	Result	PQL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual
Nitrogen, Total Kjeldahl	14.5	0.500	12.50	1.730	102	80	120	14.10	2.80	20	

**Qualifiers:** B Analyte detected in the associated Method Blank  
 J Analyte detected below quantitation limits  
 ND Not Detected  
 R RPD outside accepted recovery limits  
 E Value above quantitation range  
 M Manual Integration used to determine area response  
 P Second column confirmation exceeds  
 RL Reporting Detection Limit  
 H Holding times for preparation or analy  
 MC Value is below Minimum Compound  
 PL Permit Limit  
 S Spike Recovery outside accepted reco

Original  
Page 6 of 10

These commonly used Qualifiers and Acronyms may or may not be present in this report.

**Qualifiers**

<b>U</b>	The compound was analyzed for but was not detected above the MDL.
<b>J</b>	The reported value is greater than the Method Detection Limit but less than the Reporting Limit.
<b>H</b>	The hold time for sample preparation and/or analysis was exceeded. Not Clean Water Act compliant.
<b>D</b>	The result is reported from a dilution.
<b>E</b>	The result exceeded the linear range of the calibration or is estimated due to interference.
<b>MC</b>	The result is below the Minimum Compound Limit.
<b>*</b>	The result exceeds the Regulatory Limit or Maximum Contamination Limit.
<b>m</b>	Manual integration was used to determine the area response.
<b>d</b>	Manual integration in which peak was deleted
<b>N</b>	The result is presumptive based on a Mass Spectral library search assuming a 1:1 response.
<b>P</b>	The second column confirmation exceeded 25% difference.
<b>C</b>	The result has been confirmed by GC/MS.
<b>X</b>	The result was not confirmed when GC/MS Analysis was performed.
<b>B</b>	The analyte was detected in the Method Blank at a concentration greater than the RL.
<b>MB+</b>	The analyte was detected in the Method Blank at a concentration greater than the MDL.
<b>G</b>	The ICB or CCB contained reportable amounts of analyte.
<b>QC-/+</b>	The CCV recovery failed low (-) or high (+).
<b>R/QDR</b>	The RPD was outside of accepted recovery limits.
<b>QL-/+</b>	The LCS or LCSD recovery failed low (-) or high (+).
<b>QLR</b>	The LCS/LCSD RPD was outside of accepted recovery limits.
<b>QM-/+</b>	The MS or MSD recovery failed low (-) or high (+).
<b>QMR</b>	The MS/MSD RPD was outside of accepted recovery limits.
<b>QV-/+</b>	The ICV recovery failed low (-) or high (+).
<b>S</b>	The spike result was outside of accepted recovery limits.
<b>W</b>	Samples were received outside temperature limits (0° – 6° C). Not Clean Water Act compliant.
<b>Z</b>	Deviation; A deviation from the method was performed; Please refer to the Case Narrative for additional information

**Acronyms**

<b>ND</b>	Not Detected	<b>RL</b>	Reporting Limit
<b>QC</b>	Quality Control	<b>MDL</b>	Method Detection Limit
<b>MB</b>	Method Blank	<b>LOD</b>	Level of Detection
<b>LCS</b>	Laboratory Control Sample	<b>LOQ</b>	Level of Quantitation
<b>LCSD</b>	Laboratory Control Sample Duplicate	<b>PQL</b>	Practical Quantitation Limit
<b>QCS</b>	Quality Control Sample	<b>CRQL</b>	Contract Required Quantitation Limit
<b>DUP</b>	Duplicate	<b>PL</b>	Permit Limit
<b>MS</b>	Matrix Spike	<b>RegLvl</b>	Regulatory Limit
<b>MSD</b>	Matrix Spike Duplicate	<b>MCL</b>	Maximum Contamination Limit
<b>RPD</b>	Relative Percent Different	<b>MinCL</b>	Minimum Compound Limit
<b>ICV</b>	Initial Calibration Verification	<b>RA</b>	Reanalysis
<b>ICB</b>	Initial Calibration Blank	<b>RE</b>	Reextraction
<b>CCV</b>	Continuing Calibration Verification	<b>TIC</b>	Tentatively Identified Compound
<b>CCB</b>	Continuing Calibration Blank	<b>RT</b>	Retention Time
<b>RLC</b>	Reporting Limit Check	<b>CF</b>	Calibration Factor

**This list of Qualifiers and Acronyms reflects the most commonly utilized Qualifiers and Acronyms for reporting. Please refer to the Analytical Notes in the Case Narrative for any Qualifiers or Acronyms that do not appear in this list or for additional information regarding the use of these Qualifiers on reported data.**



**SUMMIT**  
ENVIRONMENTAL TECHNOLOGIES, INC.  
*Analytical Laboratories*

Summit Environmental Technologies, Inc.  
3310 Win St.  
Cuyahoga Falls, Ohio 44223  
TEL: (330) 253-8211 FAX: (330) 253-4489  
Website: <http://www.settek.com>

# DATES REPORT

WO#: 20031364  
03-Apr-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0031653

Sample ID	Client Sample ID	Collection Date	Matrix	Test Name	Leachate Date	Prep Date	Analysis Date
20031364-001A	0031653-01	3/19/2020 10:30:00 AM	Non-Potable Water	Total Kjeldahl Nitrogen (4500-NH3-D		4/1/2020 8:10:00 AM	4/2/2020 4:54:00 PM



**SUMMIT**  
 ENVIRONMENTAL TECHNOLOGIES, INC  
 Analytical Laboratories

Summit Environmental Technologies, Inc.  
 3310 Win St.  
 Cuyahoga Falls, Ohio 44223  
 TEL: (330) 253-8211 FAX: (330) 253-4489  
 Website: <http://www.settek.com>

**Accreditation Program  
 Analytes Report**

WO#: 20031364  
 03-Apr-20

**Client:** Environmental Service Laboratories Inc  
**Project:** 0031653

**State:** PA  
**Program Name:** Pennsylvanis DEP

Test Name	Matrix	Analyte	Status
Total Kjeldahl Nitrogen (4500-NH3-D) 2011	Non-Potable Water	Nitrogen, Ammonia	A

**Key**

PA-NELAP    A    Accredited

Page 1 of 1  
 Original #1



SUBCONTRACT ORDER  
Environmental Service Laboratories, Inc.  
0031653

20031364

Please report all results to reports@envlabs.com. Contact ESL with any questions.

SENDING LABORATORY:

Environmental Service Laboratories, Inc.  
1803 Philadelphia Street  
Indiana, PA 15701  
Phone: 724-463-8378  
Fax: 724-465-4209  
Project Manager: Rebecca Erwin

RECEIVING LABORATORY:

Summit Environmental Technologies, Inc.  
3310 Win Street  
Cuyahoga Falls, OH 44223  
Phone: (330) 253-8211  
Fax: (330) 253-4489

State of Origin PA

Analysis	Due	Expires	Comments
Sample ID: 0031653-01 Matrix: Water	Sampled: 03/19/2020 10:30	Sample Type: Grab	Sampled By: Client
Total Kjeldahl Nitrogen Containers Supplied: Poly 250mL, H2SO4 (D)	03/31/2020 23:00	04/16/2020 10:30	

pk

DBPix Evaluation

Released By: DE Date: 3/19/20

Received By: Jackie Pasile Date: 3/20/2005

Released By: \_\_\_\_\_ Date: \_\_\_\_\_

Received By: \_\_\_\_\_ Date: 07/20/11/2011/UCS



## Sample Log-In Check List

Client Name: **ENV-PA-15701** Work Order Number: **20031364** RcptNo: **1**

Logged by:	<b>Jacqueline Rasile</b>	<b>3/20/2020 10:05:00 AM</b>	<i>Jacqueline Rasile</i>
Completed By:	<b>Jacqueline Rasile</b>	<b>3/21/2020 1:06:51 PM</b>	<i>Jacqueline Rasile</i>
Reviewed By:	<b>Sara E. Kidd</b>	<b>3/23/2020 11:05:13 AM</b>	<i>Sara Kidd</i>

### Chain of Custody

1. Is Chain of Custody complete? Yes  No  Not Present   
 2. How was the sample delivered? UPS

### Log In

3. Coolers are present? Yes  No  NA   
 4. Shipping container/cooler in good condition? Yes  No   
 Custody seals intact on shipping container/cooler? Yes  No  Not Present   
 No. Seal Date: Signed By:  
 5. Was an attempt made to cool the samples? Yes  No  NA   
 6. Were all samples received at a temperature of >0° C to 6.0°C? Yes  No  NA   
 7. Sample(s) in proper container(s)? Yes  No   
 8. Sufficient sample volume for indicated test(s)? Yes  No   
 9. Are samples (except VOA and ONG) properly preserved? Yes  No   
 10. Was preservative added to bottles? Yes  No  NA   
 11. Is the headspace in the VOA vials less than 1/4 inch or 6 mm? Yes  No  No VOA Vials   
 12. Were any sample containers received broken? Yes  No   
 13. Does paperwork match bottle labels? Yes  No   
 (Note discrepancies on chain of custody)  
 14. Are matrices correctly identified on Chain of Custody? Yes  No   
 15. Is it clear what analyses were requested? Yes  No   
 16. Were all holding times able to be met? Yes  No   
 (If no, notify customer for authorization.)

### Special Handling (if applicable)

17. Was client notified of all discrepancies with this order? Yes  No  NA

Person Notified:	_____	Date:	_____
By Whom:	_____	Via:	<input type="checkbox"/> eMail <input type="checkbox"/> Phone <input type="checkbox"/> Fax <input type="checkbox"/> In Person
Regarding:	_____		
Client Instructions:	_____		

18. Additional remarks:

### Cooler Information

Cooler No	Temp °C	Condition	Seal Intact	Seal No	Seal Date	Signed By
1	1.1	Good	Not Present			

**Moniteau School  
District**

**Maintenance  
Department**

**Monthly Water Testing  
Results for Moniteau  
High School  
March 2020**

MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
MARCH	2020	MONTICAU HIGH SCHOOL WATER TREATMENT PLANT										
1	SUN											
2	MON	46.5	7.98	3,223, 358	0.62	0.72	7.0	0.00	0	1.12	JEFF C	08:00
3	TUES	47.6	6.11	3,223, 358	0.63	0.71	7.0	0.00	0	1.10	JEFF C	09:00
4	WED	53.4	8.40	3,227, 020	0.52	0.63	7.0	0.00	0	1.81	JEFF C	07:30
5	THURS	51.3	6.77	3,227, 020	0.53	0.62	7.0	0.00	0	1.80	JEFF C	07:30
6	FRID	54.9	7.62	3,248, 791	0.47	0.57	7.0	0.00	0	1.22	JEFF C	09:30
7	SAT											
8	SUN											
9	MON	54.5	4.42	3,255, 642	0.58	0.68	6.8	0.02	0	1.66	JEFF R	11:30A
10	TUES	55.9	6.88	3,255, 642	0.63	0.70	7.0	0.00	0	2.05	JEFF R.	11:30A
11	WED	58.0	7.32	3,264, 730	0.54	0.63	6.8	0.03	0	1.78	JEFF R.	11:45A
12	THURS	57.5	7.82	3,269, 398	0.56	0.66	7.0	0.01	0	1.90	JEFF R	11:45A
13	FRID	57.7	6.59	3,269, 398	0.57	0.63	7.0	0.01	0	1.92	JEFF C	08:00A
14	SAT											
15	SUN											
16	MON	54.4	8.11	3,282, 192	0.43	0.51	7.2	0.00	0	1.54	JEFF C	11:30A
17	TUES	54.0	7.52	3,282, 192	0.44	0.50	7.2	0.00	0	1.54	JEFF C	11:00A
18	WED	53.4	7.02	3,282, 192	0.39	0.42	7.2	0.00	0	1.54	JEFF C	09:00A
19	THURS	52.5	6.88	3,282, 192	0.38	0.40	7.2	0.00	0	1.52	JEFF C	08:00A
20	FRID	58.0	8.66	3,294, 455	0.83	0.96	7.2	0.02	0	1.45	JEFF C	2:00P
21	SAT											
22	SUN											
23	MON	52.4	7.78	3,294, 455	0.80	0.92	7.2	0.01	0	1.45	JEFF C	2:00P.
24	TUES	51.4	7.52	3,294, 455	0.82	0.95	7.2	0.01	0	1.42	JEFF C	10:00A
25	WED	51.2	7.26	3,294, 455	0.75	0.87	7.2	0.02	0	2.12	JEFF C	10:00A
26	THURS	51.9	6.93	3,294, 455	0.72	0.86	7.2	0.01	0	2.10	JEFF C	10:00A
27	FRID	52.7	6.53	3,294, 455	0.72	0.84	7.2	0.01	0	2.08	JEFF C	11:00A
28	SAT											
29	SUN											
30	MON	58.0	6.22	3,294, 455	0.82	0.91	7.3	0.01	0	1.56	JEFF C	08:00A
31	TUES	58.2	8.93	3,306, 936	0.78	0.80	7.3	0.00	0	1.55	JEFF C	10:00A

Meter Reading on Feb 28 - 3,211,542

3,306,936 3/31/20

2,696.06 GAD  
83,579 Gallons





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

11 March 2020

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 0030509**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 704**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	0030509-01	Drinking Water	03/05/2020 13:20	3/5/20 17:31	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

Krista Brocius for Rebecca Erwin  
 Project Manager Assistant





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 03/11/2020 11:11

Lab Sample ID#: 0030509-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 704 Kitchen Main Sink

Sample Date: 03/05/2020 13:20  
 Receipt Date: 03/05/2020 17:31

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>		<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.520	mg/L		0.200	PFS	03/05/20 13:20	03/05/20 13:20
<b>Microbiology</b>		<b>Analytical Method: SM9223 B-04</b>			<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	ANP	03/05/20 15:36	03/06/20 17:29
E. Coli	Absent	per 100 mL		1	ANP	03/05/20 15:36	03/06/20 17:29

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NI 4C M  
(57) 463-TEST  
FAX: (570) 321-1957



0030509

DIVISION  
A 16150  
(724) 465-TEST  
FAX: (724) 465-4209

Page 3 of 4

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
CIRCLE ONE: 704 KITCHEN MAIN SINK 802-ROOM 204 SINK	0030509 en	3-5-20	1:30	DW	1	STERILE PLASTIC NA THIO	TC/EC ✓ Free Chlorine : 52  4.1 iLL @ 1510 AAP 3/5/20

704: Jan, Mar, May, Jul, Sept, Nov  
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

*[Signatures]*  
Sampled By: (Signature) \_\_\_\_\_ Date/ Time 3-5-20 1:30  
Relinquished By: (Signature) \_\_\_\_\_ Date/ Time 3-5-20 1:30  
Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA Receipt Temperature \_\_\_\_\_

Notes/Special Instructions: *Drinking Water Moniteau Jr/Sr - Monthly*

Company/Name: MONTEAU SCHOOL DISTRICT  
Address: 1810 WEST SUNBURY ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL  
Phone Number: 724-406-4426  
Cell Phone: jcampbell@moniteau.k12.pa.us  
Billing Address: \_\_\_\_\_  
PWSID: 5100324

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.52	030520	704		030520	D	1320	32382	0030509-01	BROWNKA_165
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	704		030520	D	1320	32382	0030509-01	BROWNKA_345





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

13 March 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0031141**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	0031141-01	Drinking Water	03/12/2020 12:30	3/13/20 9:00	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 03/13/2020 09:54

**Lab Sample ID#:** 0031141-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink

**Sample Date:** 03/12/2020 12:30  
**Receipt Date:** 03/13/2020 09:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.500	mg/L		0.200	PFS	03/12/20 12:30	03/12/20 12:30

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Monroeville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpshville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY



0031141

3E 1 OF 1

## SAMPLE REQUEST & CHAIN OF CUSTODY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>802</u>	<u>0031141</u>	<u>3/27/20</u>	<u>1230</u>	DW	Field	Field	Free Chlorine <u>.50</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Sampled By: (Signature) </p> <p>Date/Time <u>3/27/20 1230</u></p>				<p>Notes/Special Instructions: <u>Drinking Water Moniteau Jr/Sr - Weekly</u></p>			
<p>Relinquished By: (Signature) <u>3/27/20 1413</u></p> <p>Date/Time <u>3/27/20 1413</u></p>				<p>Company/Name: <u>MONITEAU SCHOOL DISTRICT</u></p>			
<p>Relinquished By: (Signature)</p> <p>Date/Time</p>				<p>Address: <u>391 HOOKER ROAD</u></p>			
<p>Relinquished By: (Signature)</p> <p>Date/Time</p>				<p>Contact Person: <u>WEST SUNBURY, PA 16061</u></p>			
<p>Correct Preservations Y/N <u>(NA)</u></p>				<p>Phone Number: <u>JEFFREY CAMPBELL</u></p>			
<p>Correct Containers Y/N <u>(NA)</u></p>				<p>Cell Phone: <u>724-406-4426</u></p>			
<p>Receipt Temperature <u>    </u></p>				<p>Email Address: <u>jcampbell@moniteau.k12.pa.us</u></p>			
<p>Received By: (Signature) <u>    </u></p> <p>Date/Time <u>    </u></p>				<p>Billing Address: <u>5100324</u></p>			
<p>Received By: (Signature) <u>    </u></p> <p>Date/Time <u>    </u></p>				<p>PWSID: <u>    </u></p>			

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.52	030520	704		030520	D	1320	32382	0030509-01	BROWNKA_165
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	704		030520	D	1320	32382	0030509-01	BROWNKA_345
5100324	1013	FREE CHLORINE	301	0.5	031220	802		031220	D	1230	32382	0031141-01	BROWNKA_454





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

20 March 2020

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

**Work Order: 0031735**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803	0031735-01	Drinking Water	03/19/2020 11:45	3/19/20 13:45	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
 Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 03/20/2020 18:42

**Lab Sample ID#:** 0031735-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 803

**Sample Date:** 03/19/2020 11:45  
**Receipt Date:** 03/19/2020 13:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.990	mg/L		0.200	PFS	03/19/20 11:45	03/19/20 11:45

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

# SAMPLE REQUEST & CHAIN OF CUSTODY

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209



0031735

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>0031735</u>	<u>31986</u>	<u>1145</u>	DW	Field	Field	Free Chlorine <u>99</u> mg/L
	<u>- 01</u>						

ROTATION

- Wk 1 - 704 Kitchen Sink
- Wk 2 - 802 Room-204 Sink
- Wk 3 - 803 Admin Sink
- Wk 4 - 804 400 Hall RR Sink
- Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature) [Signature] Date/ Time 31986 1145  
 Relinquished By: (Signature) [Signature] Date/ Time 31986 1340

Received By: (Signature) Alex Faull Date/ Time 3-20-20 1006  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Company Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 JEFFREY CAMPBELL**  
 Phone Number: **724-406-4426**  
 Cell Phone: **jcampbell@moniteau.k12.pa.us**  
 Billing Address: **5100324**  
 PWSID: **5100324**

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature \_\_\_\_\_

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.52	030520	704		030520	D	1320	32382	0030509-01	BROWNKA_165
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	704		030520	D	1320	32382	0030509-01	BROWNKA_345
5100324	1013	FREE CHLORINE	301	0.5	031220	802		031220	D	1230	32382	0031141-01	BROWNKA_454
5100324	1013	FREE CHLORINE	301	0.99	031920	803		031920	D	1145	32382	0031735-01	BROWNKA_792





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

07 April 2020

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 0032053**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	0032053-01	Drinking Water	03/26/2020 11:00	3/26/20 13:15	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Rebecca Erwin  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 04/07/2020 08:23

**Lab Sample ID#:** 0032053-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 03/26/2020 11:00  
**Receipt Date:** 03/26/2020 13:15

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.780	mg/L		0.200	PFS	03/26/20 11:00	03/26/20 11:00

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

DATE 1 OF 1



FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# <u>0032053</u>	Sample Type	Matrix	# of Bottles	Container Type	Analysis Requested
Distribution: <u>804</u>	<u>01</u>	Grab Date <u>3/26/20</u> Time <u>1100</u>	DW	Field	Field	Free Chlorine <u>1.78</u> mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
Notes/Special Instructions:						
Drinking Water Moniteau Jr/Sr - Weekly						
Sampled By: (Signature)		Date/ Time		Company/Name:		
		<u>3-26-20 1100</u>		MONITEAU SCHOOL DISTRICT		
Relinquished By: (Signature)		Date/ Time		Address:		
		<u>3-26-20 1315</u>		391 HOOKER ROAD		
Relinquished By: (Signature)		Date/ Time		Contact Person:		
		<u>3-26-20 1315</u>		WEST SUNBURY, PA 16061		
Relinquished By: (Signature)		Date/ Time		Phone Number:		
		<u>3-26-20 1315</u>		JEFFREY CAMPBELL		
Correct Preservations Y/N/NA		Correct Containers Y/N/NA		Cell Phone:		
				724-406-4426		
				Email Address:		
				jcampbell@moniteau.k12.pa.us		
				Billing Address:		
				5100324		
				PWSID:		

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.52	030520	704		030520	D	1320	32382	0030509-01	BROWNKA_165
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030620	704		030520	D	1320	32382	0030509-01	BROWNKA_345
5100324	1013	FREE CHLORINE	301	0.5	031220	802		031220	D	1230	32382	0031141-01	BROWNKA_454
5100324	1013	FREE CHLORINE	301	0.99	031920	803		031920	D	1145	32382	0031735-01	BROWNKA_792
5100324	1013	FREE CHLORINE	301	0.78	032620	804		032620	D	1100	32382	0032053-01	BROWNKA_1204