

Moniteau School District
Maintenance Department
Moniteau High School
Wastewater Treatment Facility
Monthly Report for March 2023



**COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER**

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST
 ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 FACILITY: MONTEAU JR SR HIGH SCHOOL
 LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA, 16061-1220
 STAGE: Final Effluent

PA0091341	
PERMIT NUMBER	

001	
OUTFALL NUMBER	

Reporting Frequency: Monthly
 DMR Effective From: 03/01/2023
 DMR Effective To: 03/31/2023
 Permit Expires: 01/31/2028
 Permit Application Due: 08/04/2027
 No Discharge:

MONITORING PERIOD			
YEAR	MO	DAY	
2023	03	01	
	YEAR	MO	DAY
	2023	03	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION			SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	UNITS			
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	7.86		***	***		***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	4.0	Daily Min	***	***		***	Daily when Discharging	Grab
pH (00400)	SAMPLE MEASUREMENT	7.00		***	8.63		***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	6.0	Daily Min	***	9.0	Daily Max	***	Daily when Discharging	Grab
Total Suspended Solids (00530)	SAMPLE MEASUREMENT	***		***	<5.0		***	2/month	Grab
	PERMIT REQUIREMENT	***		***	30.0	Avg Mo	***	2/month	Grab
Ammonia-Nitrogen (00610)	SAMPLE MEASUREMENT	***		***	<.329		***	2/month	Grab
	PERMIT REQUIREMENT	***		***	Monitor & Report		***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***		***	5.54		***	Daily when Discharging	Grab
	PERMIT REQUIREMENT	***		***	Monitor & Report		***	Daily when Discharging	Grab
Flow (50050)	SAMPLE MEASUREMENT	.003465		***	***		***	1/week	Measured
	PERMIT REQUIREMENT	***	MGD	***	***		***	1/week	Measured
Fecal Coliform (74055)	SAMPLE MEASUREMENT	***		***	<1.0		***	2/month	Grab
	PERMIT REQUIREMENT	***		***	2000	No./100 ml	***	2/month	Grab
		***		***	Geo Mean		***	2/month	Grab
		***		***	10000		***		
		***		***	IMAX		***		

COMMONWEALTH OF PENNSYLVANIA
DEPARTMENT OF ENVIRONMENTAL PROTECTION
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	***		***	3.7	7.4		2/month	Grab
	PERMIT REQUIREMENT	***		***	25.0 Avg Mo	50.0 IMAX	mg/L	2/month	Grab
Facility Comments									

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



JEFFREY CAMPBELL <jcampbell@moniteau.org>

Your eDMR Report Has Been Received For Permit No. PA0091341

1 message

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Mon, Apr 17, 2023 at 10:32 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

Facility Name: MONITEAU JR SR HIGH SCHOOL

Permit Number: PA0091341

Report Frequency: Monthly

Report Type: DMR

Reporting Period: 03/01/2023-03/31/2023

Report Due Date: 04/28/2023

Submitted By: Jeffrey Campbell

Submission Id: 387927

Submission Status: Received

Submission Type: Original

To view the details of this report, access the eDMR system through DEP's GreenPort and select the link for View/Revise Submitted.

Moniteau School District

Moniteau High School – Wastewater Plant

Monthly worksheet for: March 2023

Flow	$107,428 \text{ GLs.} \div 31 = 3,465$ Daily Avg		
UV Light	$127.6 \div 23 = 5.54$ Daily Avg		
		Basin #	Date
PH Low	7.00	2	3/30/23
PH High	8.63	1	3/15/23
D. O. Low	7.86	2	3/23/23
D. O. High	10.11	1	3/15/23

Date:	3/2/23	3/16/23	SUB TOTAL	$\div 2$	AVG. TOTAL
Total Nitrogen	33.8	7.87	41.67	20.83	20.83
TSS	<5	<5	—	—	<5
TKN	4.5	1.22	5.72	2.86	2.86
Nitrate/Nitrate	29.3	6.64	35.94	17.97	17.97
Phos	4.2	1.0	5.2	2.6	2.6
CBOD	5.4	42.00	7.4	3.7	3.7
Fecal	<1	<1	—	—	<1
Ammonia	<0.329	<0.329	—	—	<0.329

Moniteau High School Sewage Treatment Plant Permit # PA0091341				Daily Operations Worksheet			
Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	Operator
3/1	Wed	8.23	9.41	AERATION		MARCH 2023	Jeff C
3/2	Thurs	8.12	9.36	7.81	9.53	UV	Jeff C
3/3	Fri	8.06	9.33	7.97	9.51	5.8	Jeff C
3/6	Mon	AERATION		7.74	9.63	5.0	Jeff C
3/7	Tues	7.74	8.96	7.71	9.21	5.5	Jeff C
3/8	Wed	7.69	9.03	7.73	9.19	5.6	Jeff C
3/9	Thurs	7.46	8.97	7.69	8.99	5.0	Jeff C
3/10	Fri	7.43	8.97	7.61	8.89	5.2	Jeff C
3/13	Mon	7.99	10.04	7.86	9.51	5.0	Jeff C
3/14	Tues	8.21	10.07	8.01	9.63	5.0	Jeff C
3/15	Wed	8.63	10.11	AERATION		4.5	Jeff C
3/16	Thurs	AERATION		8.23	9.57	4.7	Jeff C
3/17	Fri	8.42	9.72	8.27	9.53	5.0	Jeff C
3/20	Mon	8.34	9.01	8.33	9.06	5.5	Jeff C
3/21	Tues	8.31	9.08	8.29	9.09	6.1	Jeff C
3/22	Wed	8.26	9.06	8.63	9.08	6.2	Jeff C
3/23	Thurs	8.01	7.86	8.39	10.71	5.5	Jeff C
3/24	Fri	7.97	7.82	AERATION		5.7	Jeff C
3/27	Mon	7.64	7.93	7.86	9.42	5.7	Jeff C
3/28	Tues	7.72	8.26	7.45	9.51	5.7	Jeff C
3/29	Wed	7.85	8.53	7.77	9.29	6.5	Jeff C
3/30	Thurs	8.10	9.09	7.00	9.27	6.9	Jeff C
3/31	Fri	7.95	8.93	7.11	9.17	6.9	Jeff C
						127.6	

TEST DAY *



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpshville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

16 March 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C0241
Project: Wastewater
Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23C0241-01	Waste Water	03/02/2023 10:00	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/16/2023 11:02

Lab Sample ID#: 23C0241-01
 Sample Type: Waste Water
 Sample Source: Grab
 Sampler: Client
 Client Sample ID: Effluent Outfall 001

Sample Date: 03/02/2023 10:00
 Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time	
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]			
Total Nitrogen	33.8	mg/L			2.70	DAA	03/10/23 11:00	03/13/23 13:16	
General Chemistry	Analytical Method: ASTM6919-17					Prep Method: No Prep - WetChem			
Ammonia as N	<0.329	mg/L		0.329	0.800	TLL	03/13/23 21:34	03/13/23 21:34	
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B			
Total Kjeldahl Nitrogen	4.50	mg/L			0.625	DAA	03/10/23 11:00	03/13/23 13:16	
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem			
Total Suspended Solids	<5	mg/L			5	APC	03/09/23 11:30	03/09/23 17:00	
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem			
Nitrate/Nitrite	29.3	mg/L			2.08	AW	03/09/23 11:22	03/09/23 11:22	
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem			
Phosphorus	4.2	mg/L			1.0	AW	03/09/23 13:40	03/09/23 13:40	
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem			
Carbonaceous Biochemical Oxygen Demand	>5.4	mg/L	SS		2.00	ATJ	03/03/23 15:31	03/08/23 10:22	
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro			
Fecal Coliforms	<1	MPN/100 mL			1	AMB	03/02/23 14:53	03/03/23 11:45	



SAMPLE RECEIPT AND REVIEW FORM

Client: Monitow



23C0241

PART A: GENERAL INFORMATION- SATELLITE LABO

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	Received on Ice? YES <input type="checkbox"/> NO <input type="checkbox"/>
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: <input type="checkbox"/> FECAL <input type="checkbox"/> TC/EC <input type="checkbox"/> TC MPN <input type="checkbox"/> EC MPN <input type="checkbox"/> TC/EC MPN <input type="checkbox"/> N/A	

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>JD / W382</u>	Samples Received on Ice? <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO
Date/Time Received: <u>3/2/23 1350</u>	Date Sampled: <u>3/2/23</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input type="checkbox"/> <u>ESL courier</u> <input checked="" type="checkbox"/> Other: _____	
Sample Receipt Temperature: <u>2.8</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

PART C: Receipt Details Completed (if different from above): _____ / / _____

Sample Receipt Criteria	YES	NO	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
Sample containers intact and sealed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Circle Applicable: Damaged Container <input type="checkbox"/> Leaking Container <input type="checkbox"/> Custody Seal Broken <input type="checkbox"/> Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Sample IDs and Containers Affected:
Other Comments:			Deficiency Log Created: YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>

Effective Date: _____

GP.25.A-1 Sample Receipt Log

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1809 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376


NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested		
		Composite	Grab						
		Date on/off	Time	Date	Time				
Effluent Outfall 001	23C0241	 	 	 	 	 	 		
		 	 	 	 	 	 		
		 	 	 	 	 	 		
		 	 	 	 	 	 		
				3/2/23	10:00 AM	WW	1	Poly 1000mL	CBOD, TSS
						WW	1	None	Total Nitrogen, Total Phosphorus
						WW	1	H2SO4	Fecal Coliform
						WW	1	Sterile Plastic 125mL	
						WW	1	Na2S2O3	
						WW	1	Poly 500mL	AMMONIA
						WW	1	112 500mL	



23C0241

Project Notes: Wastewater

Company/Name: MONITEAU SCHOOL DISTRICT

Contact Person: JEFFREY CAMPBELL

Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061

Phone / Cell: 724-406-4426

Email: jcampbell@moniteau.org

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/Time 3/2/23 10:00 AM

Relinquished By: (Signature) *[Signature]* Date/Time 3/2/23 1156

Relinquished By: (Signature) *[Signature]* Date/Time 3/2/23 1048

Relinquished By: (Signature) *[Signature]* Date/Time 3/2/23 1350 WSSW

Relinquished By: (Signature) *[Signature]* Date/Time 3/2/23 1350 WSSW

Relinquished By: (Signature) *[Signature]* Date/Time 3/2/23 1350 WSSW

Correct Preservations Y/N/NA Y/N/NA

Correct Containers Y/N/NA Y/N/NA

Receipt Temperature



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

03 April 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C1690
 Project: Wastewater
 Project Description: Wastewater

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	23C1690-01	Waste Water	03/16/2023 10:00	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- MH Matrix Spike recovery exceeded the laboratory acceptance criteria; result may be biased high.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units
- MDL Method Detection Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/03/2023 13:55

Lab Sample ID#: 23CI690-01
Sample Type: Waste Water
Sample Source: Grab
Sampler: Client
Client Sample ID: Effluent Outfall 001

Sample Date: 03/16/2023 10:00
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	MDL	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time	
General Chemistry	Analytical Method: *** DEFAULT SPECIFIC METHOD					Prep Method: [CALC]			
Total Nitrogen	7.87	mg/L			1.14	DAA	03/22/23 13:10	03/23/23 16:43	
General Chemistry	Analytical Method: ASTM6919-17					Prep Method: No Prep - WetChem			
Ammonia as N	<0.329	mg/L		0.329	0.800	TLL	03/24/23 23:17	03/24/23 23:17	
General Chemistry	Analytical Method: EPA 351.2 2.0					Prep Method: SM 4500-Norg B			
Total Kjeldahl Nitrogen	1.22	mg/L			0.625	DAA	03/22/23 08:45	03/23/23 16:43	
General Chemistry	Analytical Method: SM2540 D-15					Prep Method: No Prep - WetChem			
Total Suspended Solids	<5	mg/L			5	APC	03/23/23 10:27	03/23/23 12:39	
General Chemistry	Analytical Method: SM4500-NO3 E-16 (discrete)					Prep Method: No Prep - WetChem			
Nitrate/Nitrite	6.64	mg/L	MH		0.520	AW	03/22/23 13:10	03/22/23 13:10	
General Chemistry	Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem			
Phosphorus	1.0	mg/L			0.10	AW	03/22/23 11:35	03/22/23 11:35	
General Chemistry	Analytical Method: SM5210 B-16					Prep Method: No Prep - WetChem			
Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L	BB, G, SS		2.00	EMH	03/16/23 16:35	03/21/23 12:45	
Microbiology	Analytical Method: Colilert-18					Prep Method: No Prep - Micro			
Fecal Coliforms	<1	MPN/100 mL			1	AMB	03/16/23 15:48	03/17/23 11:10	

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTERS
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NOF
435
Mon
(57C)
FAX



WEST DIVISION
n Street
ille, PA 16150
-3-TEST
Form: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Date	Grab Time	Matrix	# of Containers	Container Type	Analysis Requested	
		Composite	Time on/off							
Effluent Outfall 001	23C1690			3/16/03	10:00 AM	WW	1	Poly 1000mL None	CBOD, TSS	
						WW	1	Poly 1000mL H2SO4		Total Nitrogen, Total Phosphorus
						WW	1	Sterile Plastic 125mL Na2S2O3		
						WW	1	Poly 500mL H2SO4	Ammonia	

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 3/16/03 10:00 AM

Relinquished By: (Signature) *[Signature]* Date/ Time 3/16/03 11:15

Relinquished By: (Signature) *[Signature]* Date/ Time 3-16-03 1:30 PM

Relinquished By: (Signature) *[Signature]* Date/ Time

Received By: (Signature) *[Signature]* Date/ Time 3/16/03 11:16

Received By: (Signature) *[Signature]* Date/ Time 3/16/03 1:30 PM

Received By: (Signature) *[Signature]* Date/ Time

Company/Name: **MONTEAU SCHOOL DISTRICT**

Contact Person: **JEFFREY CAMPBELL**

Address: **1810 WEST SUNBURY ROAD**
WEST SUNBURY, PA 16061
724-406-4426
jcampbell@monteau.org

Project Notes: **Wastewater**

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature



SAMPLE RECEIPT AND REVIEW FORM

Client: <u>Moniteau</u>	Work Or 23C1690
-------------------------	------------------

PART A: GENERAL INFORMATION- SATELLITE LABORATORY

Received by/Lab ID: _____	Date/Time Received: / / _____
Method of Delivery: Client Drop-Off <input type="checkbox"/> ESL Courier <input type="checkbox"/> Other: _____	
Sample Receipt Temperature: _____ °C	Received on Ice? YES NO
Containers Removed by Satellite Lab for Analysis of: <input type="checkbox"/> FECAL <input type="checkbox"/> TC/EC <input type="checkbox"/> TC MPN <input type="checkbox"/> EC MPN <input type="checkbox"/> TC/EC MPN <input checked="" type="checkbox"/> (N/A)	IR Gun ID: _____

PART B: GENERAL INFORMATION- INDIANA LABORATORY

Received by/Lab ID: <u>DM 100387</u>	Samples Received on Ice? <input checked="" type="checkbox"/> YES NO
Date/Time Received: <u>3/16/23 1530</u>	Date Sampled: <u>3/16/23</u>
Method of Delivery: FedEx <input type="checkbox"/> UPS <input type="checkbox"/> Client Drop off <input checked="" type="checkbox"/> (ESL courier) Other: _____	
Sample Receipt Temperature: <u>3.0</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <input checked="" type="checkbox"/> PA <input type="checkbox"/> NY <input type="checkbox"/> OH <input type="checkbox"/> WV Other: _____	PWSID Compliance Drinking Water Samples: YES <input checked="" type="checkbox"/> NO

PART C: Receipt Details Completed (if different from above): _____ / _____ / _____

Sample Receipt Criteria	Signature	Date	Time	Comments/Qualifiers (Required for Non-Conforming Items)
Chain of custody documents included with samples?	<input checked="" type="checkbox"/> YES	NO		Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/> YES	NO		Comments:
Sample containers intact and sealed?	<input checked="" type="checkbox"/> YES	NO		Circle Applicable: Damaged Container _____ Leaking Container _____ Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/> YES	NO		Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/> YES	NO		Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/> YES	NO		Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="checkbox"/> YES	NO		Sample IDs and Containers Affected:
Samples received at appropriate pH for analysis requested?	<input checked="" type="checkbox"/> YES	NO		Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/> YES	NO		For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="checkbox"/> YES	NO		Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	YES	<input checked="" type="checkbox"/> NO		Sample IDs and Containers Affected:
Other Comments:				Deficiency Log Created: YES <input checked="" type="checkbox"/> NO

Effective Date: _____

Moniteau School District
Maintenance Department
Moniteau High School
Water Treatment Facility
Monthly Report for March 2023

MONITEAU HIGH SCHOOL WATER TREATMENT PLANT												
MONTH	DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
March	1	50.9	10.07	7,624,559	0.79	0.83	7.0	0.00	0	1.18	JEFF C	9:00 AM
	2	52.7	8.57	7,624,559	0.79	0.84	7.0	0.00	0	1.17	JEFF C	9:30 AM
	3	55.2	10.67	7,636,365	0.76	0.81	7.1	0.00	0	1.36	JEFF C	1:00 AM
	4											
	5											
	6											
	7	50.5	9.00	7,636,365	0.75	0.81	7.1	0.00	0	1.35	JEFF C	10:00 AM
	8	56.0	10.95	7,649,758	0.73	0.79	7.1	0.00	0	1.19	JEFF C	5:00 PM
	9	53.2	10.05	7,649,758	0.73	0.79	7.1	0.00	0	1.18	JEFF C	8:30 AM
	10	55.1	10.64	7,657,887	0.69	0.77	7.2	0.01	0	2.01	JEFF C	11:00 AM
	11	56.1	10.67	7,663,252	0.70	0.77	7.2	0.01	0	1.99	JEFF C	10:00 AM
	12											
	13											
	14	50.0	11.88	7,675,884	0.72	0.78	7.0	0.00	0	1.68	JEFF C	8:00 AM
	15	50.0	10.69	7,675,884	0.72	0.78	7.0	0.00	0	1.68	JEFF R	11:30 AM
	16	46.1	8.86	7,675,884	0.72	0.78	7.0	0.00	0	1.65	JEFF C	1:00 PM
	17	49.0	8.23	7,676,425	0.71	0.77	7.0	0.00	0	1.63	JEFF C	9:30 AM
	18	54.5	10.95	7,687,258	0.73	0.79	7.0	0.00	0	1.19	JEFF C	9:00 AM
	19											
	20											
	21	51.9	11.92	7,698,584	0.69	0.76	7.2	0.01	0	1.70	JEFF C	9:30 AM
	22	51.6	10.01	7,698,584	0.70	0.76	7.2	0.01	0	1.68	JEFF C	9:50 AM
	23	51.4	8.19	7,698,584	0.70	0.76	7.2	0.01	0	1.68	JEFF C	9:30 AM
	24	56.0	11.21	7,711,099	0.71	0.77	7.1	0.01	0	1.26	JEFF C	9:30 AM
	25	55.6	9.09	7,711,099	0.70	0.77	7.1	0.01	0	1.26	JEFF C	10:00 AM
	26											
	27											
	28	55.7	9.82	7,721,866	0.52	0.66	7.1	0.01	0	0.71	JEFF C	3:00 PM
	29	55.5	8.73	7,721,866	0.52	0.66	7.1	0.01	0	0.70	JEFF C	5:00 AM
	30	56.6	11.09	7,731,987	0.51	0.63	7.0	0.01	0	1.56	JEFF R	11:45 AM
	31	54.1	9.07	7,731,987	0.52	0.62	7.1	0.00	0	1.43	JEFF R	11:45 AM
		55.1	8.18	7,731,987	0.52	0.63	7.1	0.00	0	1.47	JEFF C	8:00 AM

= WATER TEST DAYS
 = SEWAGE TEST DAYS
 2/29/23 METER READING 7,624,559



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0268
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23C0268-01	Drinking Water	03/02/2023 11:50	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





ENVIRONMENTAL
SERVICE LABORATORIES, INC.

1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:11

Lab Sample ID#: 23C0268-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 03/02/2023 11:50
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.800	mg/L		0.200	PS	03/02/23 11:50	03/02/23 11:50
Analytical Method: SM4500-Cl G-11 Prep Method: No Prep - Field							
Microbiology							
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
Analytical Method: SM 9223 B-16 Prep Method: No Prep - Micro							

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209


SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16150
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
	23C0268	DW			
CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM-204 SINK	Sample Type	Date	Time	Matrix	# of Bottles
	Grab				
	3023				



23C0268

704: Jan, Mar, May, Jul, Sept, Nov
802: Feb, Apr, Jun, Aug, Oct, Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature)	Date/ Time
<i>[Signature]</i>	3-2-23 11:50
Relinquished By: (Signature)	Date/ Time
<i>[Signature]</i>	3-2-23 11:50
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature 3.1 °F

Notes/Special Instructions:
Drinking Water Moniteau Jr/Sr - Monthly

Company/Name: MONITEAU SCHOOL DISTRICT
Address: 1810 WEST SUNBURY ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
Contact Person: 724-406-4426
Phone Number: jcampbell@moniteau.org
Cell Phone:
Billing Address: 5100324
PWSID:

E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA 182



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0268
Project: Drinking Water Moniteau Jr/Sr - Monthly 704
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	23C0268-01	Drinking Water	03/02/2023 11:50	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/14/2023 11:11

Lab Sample ID#: 23C0268-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 704 Kitchen Main Sink

Sample Date: 03/02/2023 11:50
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-C1 G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.800	mg/L		0.200	PS	03/02/23 11:50	03/02/23 11:50
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	SOUTHERN DIVISION 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-8376	NORTHERN DIVISION 435 Broad Street Montoursville, PA 17754 (570) 321-9003 FAX: (570) 321-1957	NORTHWEST DIVISION 950 Main Street Sharpsville, PA 16150 (724) 463-TEST FAX: (724) 465-4209
---	--	--	--

FOR INTERNAL LABORATORY USE ONLY

Sample Identification CIRCLE ONE: 704 KITCHEN MAIN SINK 802 ROOM-204 SINK	ESL# 23C0268	Sample Type Grab _____ Date _____ Time _____		Matrix DW	# of Bottles 1	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC / EC Free Chlorine 6.80
	CA	3003 11:50					



23C0268

704: Jan, Mar, May, Jul, Sept, Nov
 802: Feb, Apr, Jun, Aug, Oct, Dec

Notes/Special Instructions:
Drinking Water Moniteau Jr/Sr - Monthly

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company Name: MONITEAU SCHOOL DISTRICT	Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061	Contact Person: JEFFREY CAMPBELL	Phone Number: 724-406-4426	Cell Phone: jcampbell@moniteau.org	Billing Address: 5100324
---	--	-------------------------------------	-------------------------------	---------------------------------------	-----------------------------

Sampled By: (Signature) [Signature]	Date/ Time 3-2-23 11:50
Relinquished By: (Signature) [Signature]	Date/ Time 3-2-23 11:50
Received By: (Signature) [Signature]	Date/ Time 3-1-23 1:55
Received By: (Signature) [Signature]	Date/ Time 3-1-23 1:55

Correct Preservations (Y) / N / NA Correct Containers (Y) / N / NA Receipt Temperature 3.1 °F

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

14 March 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C1077
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23C1077-01	Drinking Water	03/09/2023 11:45	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record IC
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNK 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNK 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNK 182

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharps
(724) 4
FAX: (

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1



23C1077

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>804</u>	23C1077			DW	Field	Field	Free Chlorine <u>0.272</u> mg/L
	01						

ROTATION
Wk 1 - 704 Kitchen Sink
Wk 2 - 802 Room 204 Sink
Wk 3 - 803 Admin Sink
Wk 4 - 804 400 Hall RR Sink
Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 3-9-23 1145
 Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 1410
 Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 1410
 Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 1410

Correct Preservations Y / N (NA) Correct Containers Y / N (NA) Receipt Temperature

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Weekly

Company Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 JEFFREY CAMPBELL**
 Contact Person:
 Phone Number:
 Cell Phone: **724-406-4426**
 Email Address: **jcampbell@moniteau.org**
 Billing Address:
 PWSID: **5100324**



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1077-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 03/09/2023 11:45
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.720	mg/L		0.200	PS	03/09/23 11:45	03/09/23 11:45



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1077
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	23C1077-01	Drinking Water	03/09/2023 11:45	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1077-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 204 Sink

Sample Date: 03/09/2023 11:45
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	0.720	mg/L		0.200	PS	03/09/23 11:45	03/09/23 11:45

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharps
(724) 4
FAX: (

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23C1077	Sample Type	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: <u>802</u>	<u>01</u>	Grab Date: <u>3-9-23</u> Time: <u>11:45</u>	DW	Field	Field	Free Chlorine <u>0.72</u> mg/L

- ROTATION**
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803-Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Weekly

Company Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcampbell@moniteau.org**

Cell Phone: **5100324**

Email Address: **5100324**

Billing Address: **5100324**

PWSID: **5100324**

Received By: (Signature) [Signature] Date/ Time 3-9-23 11:45

Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 11:45

Received By: (Signature) [Signature] Date/ Time 3-9-23 11:45

Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 11:45

Received By: (Signature) [Signature] Date/ Time 3-9-23 11:45

Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 11:45

Correct Preservations Y/N NA Correct Containers Y/N NA Receipt Temperature —

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

Department of Environmental Protection

E-Government Application for Drinking Water
Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

20 March 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C1754
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23C1754-01	Drinking Water	03/16/2023 11:28	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/20/2023 09:51

Lab Sample ID#: 23C1754-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 03/16/2023 11:28
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.780	mg/L		0.200	PS	03/16/23 11:28	03/16/23 11:28


ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Berleville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376



RTHWEST DIVISION
D Main Street
Parsippany, PA 16
(24) 463-TEST
AX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL # 23C1754	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Grab	Time				
Distribution: 803	on	5/6/93	1128	DW	Field	Field	Free Chlorine 0.75 mg/L

- ROTATION
- WK 1 - 704 Kitchen Sink
 - WK 2 - 802 Room 204 Sink
 - WK 3 - 803 Admin Sink
 - WK 4 - 804 400 Hall RR Sink
 - WK 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Monteau Jr/Sr - Weekly

Company/Name: **MONTEAU SCHOOL DISTRICT**

Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL

Phone Number: 724-406-4426

Cell Phone: [Campbell@monteau.org]

Email Address: [Campbell@monteau.org]

Billing Address: PWSID: 5100324

Receipt Temperature _____

Sampled By: (signature) [Signature] Date/ Time 3/16/93 1128

Relinquished By: (signature) [Signature] Date/ Time 3/16/93 1319

Relinquished By: (signature) _____ Date/ Time _____

Relinquished By: (signature) _____ Date/ Time _____

Relinquished By: (signature) _____ Date/ Time _____

Correct Preservations Y/N (N/A) Correct Containers Y/N (N/A)

**5100324: MONITEAU JR/SR HIGH SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA_871



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1747
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23C1747-01	Drinking Water	03/16/2023 11:05	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/20/2023 09:49

Lab Sample ID#: 23C1747-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 03/16/2023 11:05
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.660	mg/L		0.200	PS	03/16/23 11:05	03/16/23 11:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vornis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY



23C1747

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type <small>Preservative</small>	Analysis Requested
		Date	Time				
Distribution: <u>803</u>	<u>23C1747</u>	<u>3/6/03</u>	<u>1105</u>	DW	Field	Field	Free Chlorine <u>0.66</u> mg/L

ROTATION
Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 617 Sink
Wk 3 - 803 Room 606 Sink
Wk 4 - 804 Room 408 Sink
Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

<p>Sampled By: (Signature) <u>[Signature]</u> Date/ Time <u>3-16-03</u> <u>1105</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>3-16-03</u> <u>130A</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Correct Preservations <u>Y/N</u> <u>NA</u> Correct Containers <u>Y/N</u> <u>NA</u> Receipt Temperature <u> </u></p>	<p>Company/Name: MONTEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: _____</p> <p>Phone Number: _____</p> <p>Cell Phone: 724-406-4426</p> <p>Email Address: jcambell@monteau.org</p> <p>Billing Address: _____</p> <p>PWSID: 5100316</p>
--	--



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

20 March 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C1754
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	23C1754-01	Drinking Water	03/16/2023 11:28	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/20/2023 09:51

Lab Sample ID#: 23C1754-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Admin Sink

Sample Date: 03/16/2023 11:28
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.780	mg/L		0.200	PS	03/16/23 11:28	03/16/23 11:28

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

23C1754

IRTHWEST DIVISION
D Main Street
Larpsville, PA 16
(24) 463-TEST
AX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 803	23C1754			DW	Field	Field	Free Chlorine 0.78 mg/L

ROTATION							
Wk 1 - 704 Kitchen Sink							
Wk 2 - 802 Room 204 Sink							
Wk 3 - 803 Admin Sink							
Wk 4 - 804 400 Hall RR Sink							
Wk 5 - 804 400 Hall RR Sink							

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions:

Drinking Water Moniteau Jr/Sr - Weekly

Sampled By: (Signature) Date/Time 3/16/23 1128

Reinquisitioned By: (Signature) Date/Time 3/16/23 1219


Reinquisitioned By: (Signature) _____ Date/Time _____

Reinquisitioned By: (Signature) _____ Date/Time _____

Reinquisitioned By: (Signature) _____ Date/Time _____

Correct Preservations Y / N Correct Containers Y / N Receipt Temperature _____

Company/Name: MONITEAU SCHOOL DISTRICT
 Address: 391 HOOKER ROAD
 WEST SUNBURY, PA 16061
 JEFFREY CAMPBELL
 Contact Person: JEFFREY CAMPBELL
 Phone Number: 724-406-4426
 Cell Phone: _____
 Email Address: jcampbell@moniteau.org
 Billing Address: _____
 PWSID: 5100324



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA_871



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

24 March 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C2329
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23C2329-01	Drinking Water	03/23/2023 10:40	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/24/2023 12:29

Lab Sample ID#: 23C2329-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 03/23/2023 10:40
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.640	mg/L		0.200	PS	03/23/23 10:40	03/23/23 10:40



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA_180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA_181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA_182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA_871
5100324	1013	FREE CHLORINE	301	0.64	032323	804		032323	D	1040	32382	23C2329-01	BROWNKA_1259

ENVIRONMENTAL SERVICE LABORATORIES, INC.

S,

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209



SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376



NORTHERN
435 Broad St
Monroeville
(570) 321-9
FAX: (570)



23C2329

FOR INTERNAL LABORATORY USE ONLY

3E 1 OF 1

Sample Identification

ESL#
2507578

Sample Type
Grab

Matrix
DW

of Bottles
Field

Container Type
Field Preservative

Analysis Requested
Free Chlorine 0.64 mg/L

Distribution: SO1

3/23/83 1040

DW

Field

Field

Free Chlorine 0.64 mg/L

ROTATION

Wk 1 - 704 Kitchen Sink

Wk 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

Wk 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Montreau Jr/Sr - Weekly

Company/Name:

MONITEAU SCHOOL DISTRICT

Address:

391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person:

JEFFREY CAMPBELL

Phone Number:

724-406-4426

Cell Phone:

jcampbell@moniteau.org

Email Address:

Billing Address:

5100324

PWSID:

Sampled By: (Signature)

3/23/83 1040

Date/ Time

Relinquished By: (Signature)

3/23/83 1040

Date/ Time

Relinquished By: (Signature)

Date/ Time

Relinquished By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Received By: (Signature)

Date/ Time

Correct Preservations Y/N NA

Correct Containers Y/N NA

Receipt Temperature -



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2329
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23C2329-01	Drinking Water	03/23/2023 10:40	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/24/2023 12:29

Lab Sample ID#: 23C2329-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 03/23/2023 10:40
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.640	mg/L		0.200	PS	03/23/23 10:40	03/23/23 10:40
Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field			



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA 182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA 871
5100324	1013	FREE CHLORINE	301	0.64	032323	804		032323	D	1040	32382	23C2329-01	BROWNKA 1259

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorths, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN
435 Broad St
Montoursville
(570) 321-9
FAX: (570)



23C2329

FOR INTERNAL LABORATORY USE ONLY

BE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>SO4</u>	<u>23C2329</u>			DW	Field	Field	Free Chlorine @.621 mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
 - Wk 2 - 802 Room 204 Sink
 - Wk 3 - 803 Admin Sink
 - Wk 4 - 804 400 Hall RR Sink
 - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Monteau Jr/Sr - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **724-406-4426**

Email Address: **jcampbell@monteau.org**

Billing Address: **5100324**

PWSID: **5100324**

Sampled By: (Signature) [Signature] Date/ Time 3/23/03 1540

Relinquished By: (Signature) [Signature] Date/ Time 3/23/03 1845

Relinquished By: (Signature) [Signature] Date/ Time 3/23/03 1845

Relinquished By: (Signature) [Signature] Date/ Time 3/23/03 1845

Relinquished By: (Signature) [Signature] Date/ Time 3/23/03 1845

Correct Preservations Y/N (NA) Correct Containers Y/N (NA) Receipt Temperature -



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

03 April 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C2932
Project: Drinking Water Moniteau Jr/Sr - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	23C2932-01	Drinking Water	03/30/2023 10:50	3/30/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/03/2023 16:30

Lab Sample ID#: 23C2932-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler:
Client Sample ID: 804 400 Hall RR Sink

Sample Date: 03/30/2023 10:50
Receipt Date: 03/30/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.530	mg/L			Client	03/30/23 10:50	03/30/23 10:50

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Shapsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Date	Time				
Distribution: <u>804</u>	<u>23C2932</u>	<u>3-30-23</u>	<u>1650</u>	DW	Field	Field	Free Chlorine <u>0.53</u> mg/L

ROTATION

Wk 1 - 704 Kitchen Sink

Wk 2 - 802 Room 204 Sink

Wk 3 - 803 Admin Sink

Wk 4 - 804 400 Hall RR Sink

Wk 5 - 804 400 Hall RR Sink



23C2932

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions::

Drinking Water Moniteau Jr/Sr - Weekly

THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW).
THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY
ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name:

MONITEAU SCHOOL DISTRICT

Address:

391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person:

JEFFREY CAMPBELL

Phone Number:

724-406-4426

Cell Phone:

icampbell@moniteau.org

Email Address:

5100324

Billing Address:

Sampled By: (Signature) [Signature] Date/ Time 3-30-23 1650

Received By: (Signature) [Signature] Date/ Time 3/30/23 1530

Relinquished By: (Signature) [Signature] Date/ Time 3-30-23 1328

Received By: (Signature) [Signature] Date/ Time 3/30/23 1530

Relinquished By: (Signature) [Signature] Date/ Time 3-30-23 1328

Received By: (Signature) [Signature] Date/ Time 3/30/23 1530

Correct Preservations Y/N/NA Y/N/NA Correct Containers Y/N/NA Y/N/NA

Receipt Temperature



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	0.8	030223	704		030223	D	1150	32382	23C0268-01	BROWNKA 180
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	704		030223	D	1150	32382	23C0268-01	BROWNKA 181
5100324	1013	FREE CHLORINE	301	0.72	030923	802		030923	D	1145	32382	23C1077-01	BROWNKA 182
5100324	1013	FREE CHLORINE	301	0.78	031623	803		031623	D	1128	32382	23C1754-01	BROWNKA 871
5100324	1013	FREE CHLORINE	301	0.64	032323	804		032323	D	1040	32382	23C2329-01	BROWNKA 1259
5100324	1013	FREE CHLORINE	301	0.53	033023	804		033023	D	1050	32382	23C2932-01	BROWNKA 1972


Moniteau School District
Maintenance Department
Dassa McKinney Elem. School
Water Treatment Facility
Monthly Report for March 2023

Dassa McKinney Elementary School Water Treatment Facility

2023

Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
Mar.	1	8.7	0.02	0.58	0.66	3.12	13999800	JEFF R	4:30P	4000
	2	8.7	0.00	0.77	0.87	2.89	14003700	JEFF R	3:30P	3900
	3	8.7	0.02	0.76	0.86	1.95	14007600	JEFF R	4:30P	3900
	4									
	5									
	6	8.7	0.00	0.57	0.64	2.11	14011500	JEFF R	5:00P	3900
	7	8.7	0.01	0.63	0.71	2.18	14015300	JEFF R	5:00P	3800
	8	8.7	0.01	1.11	1.24	3.13	14019000	JEFF R	4:00P	3700
	9	8.7	0.00	0.59	0.67	3.35	14025300	JEFF R	4:30P	6300
	10	8.7	0.02	0.61	0.70	2.57	14027800	JEFF R	4:30P	2500
	11									
	12									
	13	8.7	0.00	0.67	0.75	2.66	14031400	JEFF R	4:30P	3600
	14	8.7	0.02	0.72	0.82	2.81	14035000	JEFF R	4:30P	3600
	15	8.7	0.01	0.70	0.78	3.08	14039000	JEFF R	4:30P	4000
	16	8.7	0.02	0.57	0.63	3.25	14042600	JEFF R	4:30P	3600
	17	8.7	0.00	0.59	0.66	3.28	14046400	JEFF R	4:30P	3800
	18									
	19									
	20	8.7	0.03	0.73	0.78	3.01	14050100	JEFF R	4:30P	3700
	21	8.7	0.00	0.86	0.96	3.22	14053900	JEFF R	3:30P	3800
	22	8.7	0.02	0.82	0.91	3.25	14058100	JEFF R	4:30P	4200
	23	8.7	0.02	0.78	0.85	3.69	14062200	JEFF R	4:30P	4100
	24	8.7	0.00	0.80	0.88	3.45	14066000	JEFF R	4:30P	3800
	25									
	26									
	27	8.7	0.02	0.73	0.83	2.64	14069900	JEFF R	4:30P	3900
	28	8.7	0.00	0.74	0.81	2.75	14073900	JEFF R	4:30P	4000
	29	8.7	0.01	0.71	0.79	2.82	14078200	JEFF R	4:30P	4300
	30	8.7	0.00	0.73	0.81	3.17	14080200	JEFF R	12:00P	2000
	31	8.7	0.02	0.73	0.80	3.28	14086300	JEFF R	4:30P	6100

Meter Reading 2/28/23 - 13995800



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

14 March 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C0267
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23C0267-01	Drinking Water	03/02/2023 11:36	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:12

Lab Sample ID#: 23C0267-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 03/02/2023 11:36
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.840	mg/L		0.200	PS	03/02/23 11:36	03/02/23 11:36
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification 801 KITCHEN SINK 802 ROOM-617 SINK	ESL# 73C0367 CA	Sample Type		Matrix DW	# of Bottles 1	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC / EC Free Chlorine 0.84 mg/L
		Date 3-23-03	Time 11:36				



23C0267

Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 3-23-03 11:36
Relinquished By: (Signature) *[Signature]* Date/ Time 3-23-03 11:36

Relinquished By: (Signature) _____ Date/ Time _____
Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y / N / NA Correct Containers Y / N / NA Receipt Temperature 3.1 #5

Notes/Special Instructions::

Drinking Water Dassa McKinney - Monthly

Company/Name: **MONITEAU SCHOOL DISTRICT**
Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL
Contact Person:
Phone Number:
Cell Phone: **724-406-4426**
Email Address: **jcampbell@moniteau.org**
Billing Address:
PWSID: **5100316**



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA 177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA 178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA 179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0267
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23C0267-01	Drinking Water	03/02/2023 11:36	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/14/2023 11:12

Lab Sample ID#: 23C0267-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 03/02/2023 11:36
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-CI G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.840	mg/L		0.200	PS	03/02/23 11:36	03/02/23 11:36
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification 801 KITCHEN SINK 802 ROOM-617 SINK	ESL# 730267	Sample Type		Matrix DW	# of Bottles 1	Container Type Preservative STERILE PLASTIC NA THIO	Analysis Requested TC / EC Free Chlorine 0.84 mg/L
		Date 3-2-23	Grab 11:36				



Rotation:
801: Jan, Mar, May, Jul, Sep,
Nov
802: Feb, Apr, Jun, Aug, Oct,
Dec

Notes/Special Instructions:
Drinking Water Dassa McKinney - Monthly

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD**
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **campbell@moniteau.org**

Email Address: **campbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (15% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) <i>[Signature]</i>	Date/ Time 3-2-23 11:36
Relinquished By: (Signature) <i>[Signature]</i>	Date/ Time 3-2-23 11:43
Relinquished By: (Signature)	Date/ Time
Relinquished By: (Signature)	Date/ Time

Received By: (Signature) *[Signature]* Date/ Time **3-2-23 11:36**

Received By: (Signature) Date/ Time

Received By: (Signature) Date/ Time

Correct Preservations N / NA Correct Containers N / NA Receipt Temperature **3.1 #3**

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C0267
Project: Drinking Water Dassa McKinney - Monthly 801
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	23C0267-01	Drinking Water	03/02/2023 11:36	3/2/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager





1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 11:12

Lab Sample ID#: 23C0267-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 801 Kitchen Sink

Sample Date: 03/02/2023 11:36
Receipt Date: 03/02/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM4500-C1 G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.840	mg/L		0.200	PS	03/02/23 11:36	03/02/23 11:36
Microbiology		Analytical Method: SM 9223 B-16			Prep Method: No Prep - Micro		
Total Coliform	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34
E. Coli	Absent	per 100 mL		1	AMB	03/02/23 14:40	03/03/23 15:34

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376




NORTHERN DIVISION
435 Broad Street
Monroeville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
801 KITCHEN SINK 802 ROOM-617 SINK	7300307 CA	3-23-23	1136	DW	1	STERILE PLASTIC NA THIO	TC / EC Free Chlorine 0.84 mg/L
 23C0267							
THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.							
1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (15% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)							
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.							
Sampled By: (Signature) 		Date/ Time 3-23-23 1136		Relinquished By: (Signature) 		Date/ Time 3-23-23 1143	
Relinquished By: (Signature)		Date/ Time		Relinquished By: (Signature)		Date/ Time	
Relinquished By: (Signature)		Date/ Time		Relinquished By: (Signature)		Date/ Time	
Correct Preservations <input checked="" type="checkbox"/> N / NA		Correct Containers <input checked="" type="checkbox"/> N / NA		Receipt Temperature 3.1 #3		PWSID: 5100316	
Notes/Special Instructions: Drinking Water Dassa McKinney - Monthly							
Company/Name: MONITEAU SCHOOL DISTRICT Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL Contact Person: Phone Number: Cell Phone: Email Address: jcampbell@moniteau.org Billing Address: PWSID:							



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1076
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23C1076-01	Drinking Water	03/09/2023 11:27	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1076-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 03/09/2023 11:27
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
---------	---------------	-------	----------------	----	-----------------------	----------------	--------------------

Field Analysis	Analytical Method: SM4500-Cl G-11			Prep Method: No Prep - Field			
Chlorine, Free	1.08	mg/L		0.200	PS	03/09/23 11:27	03/09/23 11:27

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVI
435 Broad Street
Montoursville, PA
(570) 321-9003
FAX: (570) 321-1000



23C1076

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>802</u>	<u>23C1076</u>	<u>3923</u>	<u>1127</u>	DW	Field	Field	Free Chlorine <u>1.68</u> mg/L

ROTATION
 Wk 1 - 801 Kitchen Sink
Wk 2 - 802 Room 617 Sink
 Wk 3 - 803 Room 606 Sink
 Wk 4 - 804 Room 408 Sink
 Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**
 Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**
 Contact Person: **724-406-4426**
 Phone Number: **jeacampbell@moniteau.org**
 Cell Phone:
 Email Address:
 Billing Address:
 PWSID: **5100316**

Received By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time
	<u>3923 1127</u>		<u>3923 1110</u>		

Correct Preservations Y/N/(NA) Correct Containers Y/N/(NA) Receipt Temperature ---



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

14 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1076
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23C1076-01	Drinking Water	03/09/2023 11:27	3/9/23 14:10	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/14/2023 12:08

Lab Sample ID#: 23C1076-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 802 Room 617 Sink

Sample Date: 03/09/2023 11:27
Receipt Date: 03/09/2023 14:10

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
	1.08	mg/L		0.200	PS	03/09/23 11:27	03/09/23 11:27

SAMPLE REQUEST & CHAIN OF CUSTODY

3E 1 OF 1

ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVI
435 Broad Street
Monitorsville, PA
(570) 321-9003
FAX: (570) 321-1000

23C1076

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: <u>802</u>	<u>23C1076</u>	<u>3-9-23</u>	<u>1127</u>	DW	Field	Field	Free Chlorine <u>1.68</u> mg/L

ROTATION

Wk 1 - 801 Kitchen Sink

Wk 2 - 802 Room 617 Sink

Wk 3 - 803 Room 606 Sink

Wk 4 - 804 Room 408 Sink

Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **724-406-4426**

Phone Number: **jcampbell@moniteau.org**

Cell Phone: **5100316**

Email Address: **jcampbell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Received By: (Signature) [Signature] Date/ Time 3-9-23 1110 0355V

Received By: (Signature) _____ Date/ Time _____

Received By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) [Signature] Date/ Time 3-9-23 1127

Relinquished By: (Signature) _____ Date/ Time _____

Relinquished By: (Signature) _____ Date/ Time _____

Correct Preservations Y/N (NA) _____ Correct Containers Y/N (NA) _____ Receipt Temperature _____

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNK 177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNK 178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNK 179



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

20 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C1747
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	23C1747-01	Drinking Water	03/16/2023 11:05	3/16/23 13:30	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/20/2023 09:49

Lab Sample ID#: 23C1747-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 803 Room 606 Sink

Sample Date: 03/16/2023 11:05
Receipt Date: 03/16/2023 13:30

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
---------	---------------	-------	----------------	----	-----------------------	----------------	--------------------

Field Analysis	Analytical Method: SM14500-CI G-11			Prep Method: No Prep - Field			
Chlorine, Free	0.660	mg/L		0.200	PS	03/16/23 11:05	03/16/23 11:05

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

HEADQUARTER
1803 Philadelphia St
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15386
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

FOR INTERNAL LABORATORY USE ONLY



23C1747

Sample Identification	ESL #	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Date				
Distribution: 803	23C1747		3/16/23	DW	1105	Field	Free Chlorine 0.166 mg/L

- ROTATION
- Wk 1 - 801 Kitchen Sink
 - Wk 2 - 802 Room 617 Sink
 - Wk 3 - 803 Room 606 Sink
 - Wk 4 - 804 Room 408 Sink
 - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) *[Signature]* Date/ Time 3-16-23 1105

Relinquished By: (Signature) *[Signature]* Date/ Time 3-16-23 1105

Relinquished By: (Signature) Date/ Time

Relinquished By: (Signature) Date/ Time

Company/Name: **MONTTEAU SCHOOL DISTRICT**
Address: 391 HOOKER ROAD
WEST SUNBURY, PA 16061

Contact Person: JEFFREY CAMPBELL
Phone Number: 724-406-4426
Cell Phone: 724-406-4426
Email Address: jcampbell@montteau.org

Billing Address: 5100316
PWSID: 5100316

Correct Preservations Y/N *NA* Correct Containers Y/N *NA* Receipt Temperature *---*



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

24 March 2023

Moniteau School District
 Attn: Jeffrey Campbell
 1810 West Sunbury Road
 West Sunbury, PA 16061

Work Order: 23C2330
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23C2330-01	Drinking Water	03/23/2023 10:15	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
 Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/24/2023 12:30

Lab Sample ID#: 23C2330-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 03/23/2023 10:15
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis		Analytical Method: SM14500-Cl G-11			Prep Method: No Prep - Field		
Chlorine, Free	0.840	mg/L		0.200	PS	03/23/23 10:15	03/23/23 10:15



E-Government Application for Drinking Water Program
SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870
5100316	1013	FREE CHLORINE	301	0.84	032323	804		032323	D	1015	32382	23C2330-01	BROWNKA_1258

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE #

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHE
435 Broa.
Montours
(570) 321.
FAX: (570)



23C2330

FOR INTERNAL LABORATORY USE

3E 1 OF 1

Sample Identification

ESL# 2507330

Distribution: 804

Sample Type	Matrix	# of Bottles	Field	Container Type Preservative	Analysis Requested
	DW			Field	Free Chlorine <u>0.84</u> mg/L

ROTATION

WK 1 - 801 Kitchen Sink

WK 2 - 802 Room 617 Sink

WK 3 - 803 Room 606 Sink

WK 4 - 804 Room 408 Sink

WK 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

Notes/Special Instructions: *Drinking Water Dassa McKinney - Weekly*

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM ON THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Company/Name: **MONTTEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **724-406-4426**

Email Address: **jcampbell@montteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Sampled By: (Signature) [Signature] Date/ Time 3-25-13 1015

Relinquished By: (Signature) [Signature] Date/ Time 3-25-13 1015

Received By: (Signature) [Signature] Date/ Time 3-25-13 1300

Relinquished By: (Signature) [Signature] Date/ Time

Received By: (Signature) [Signature] Date/ Time

Correct Preservations Y/N (NA) Correct Containers Y/N (NA) Receipt Temperature



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

24 March 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2330
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	23C2330-01	Drinking Water	03/23/2023 10:15	3/23/23 13:00	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

Moniteau School District
1810 West Sunbury Road
West Sunbury, PA 16061

Reported: 03/24/2023 12:30

Lab Sample ID#: 23C2330-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Paul Somogyi
Client Sample ID: 804 Room 408 Sink

Sample Date: 03/23/2023 10:15
Receipt Date: 03/23/2023 13:00

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.840	mg/L		0.200	PS	03/23/23 10:15	03/23/23 10:15



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA_177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA_178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA_179
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA_870
5100316	1013	FREE CHLORINE	301	0.84	032323	804		032323	D	1015	32382	23C2330-01	BROWNKA_1258

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLER

3E 1 OF 1

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Voorhis, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHE
495 Broad
Monroeville, PA 15146
(570) 321-
FAX: (570)



FOR INTERNAL LABORATORY USE

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: 804	25C0330			DW	Field	Field	Free Chlorine 0.84 mg/L

- ROTATION
- Wk 1 - 801 Kitchen Sink
 - Wk 2 - 802 Room 617 Sink
 - Wk 3 - 803 Room 606 Sink
 - Wk 4 - 804 Room 408 Sink
 - Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (13% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Notes/Special Instructions::

Drinking Water Dassa McKinney - Weekly

Company/Name: **MONITEAU SCHOOL DISTRICT**

Address: **391 HOOKER ROAD
WEST SUNBURY, PA 16061
JEFFREY CAMPBELL**

Contact Person: **JEFFREY CAMPBELL**

Phone Number: **724-406-4426**

Cell Phone: **724-406-4426**

Email Address: **jcambell@moniteau.org**

Billing Address: **5100316**

PWSID: **5100316**

Sampled By: (Signature) *[Signature]* Date/Time **3-25-23 10:15**

Relinquished By: (Signature) *[Signature]* Date/Time **3-25-23 10:15**

Relinquished By: (Signature) *[Signature]* Date/Time **3-25-23 10:15**

Relinquished By: (Signature) *[Signature]* Date/Time **3-25-23 10:15**

Correct Preservations **Y/N (NA)** Correct Containers **Y/N (NA)** Receipt Temperature **---**



1803 Philadelphia Street
Indiana, PA 15701
P: (724) 463-8378
F: (724) 465-4209
PADEP: 32-00382

1276 Bentleyville Road
Van Voorhis, PA 15366
P: (724) 258-8378
F: (724) 258-8376
PADEP: 63-04247

435 Broad Street
Montoursville, PA 17754
P: (570) 321-9002
F: (570) 321-1957
PADEP: 41-04880

950 West Main Street
Sharpsville, PA 16150
P: (724) 463-8378 x 500
F: (724) 465-4209
PADEP: 43-04934

03 April 2023

Moniteau School District
Attn: Jeffrey Campbell
1810 West Sunbury Road
West Sunbury, PA 16061

Work Order: 23C2937
Project: Drinking Water Dassa McKinney - Weekly
Project Description: Drinking Water

Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	23C2937-01	Drinking Water	03/30/2023 10:25	3/30/23 13:50	

Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

Definitions

RL Reporting Limit

Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Approved By

Kirsten Conoran

Kirsten Conoran
Project Manager



1803 Philadelphia Street
 Indiana, PA 15701
 P: (724) 463-8378
 F: (724) 465-4209
 PADEP: 32-00382

1276 Bentleyville Road
 Van Voorhis, PA 15366
 P: (724) 258-8378
 F: (724) 258-8376
 PADEP: 63-04247

435 Broad Street
 Montoursville, PA 17754
 P: (570) 321-9002
 F: (570) 321-1957
 PADEP: 41-04880

950 West Main Street
 Sharpsville, PA 16150
 P: (724) 463-8378 x 500
 F: (724) 465-4209
 PADEP: 43-04934

Moniteau School District
 1810 West Sunbury Road
 West Sunbury, PA 16061

Reported: 04/03/2023 16:32

Lab Sample ID#: 23C2937-01
Sample Type: Drinking Water
Sample Source: Grab
Sampler: Client
Client Sample ID: 802 Room 617 Sink

Sample Date: 03/30/2023 10:25
Receipt Date: 03/30/2023 13:50

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis							
Chlorine, Free	0.580	mg/L			Client	03/30/23 10:25	03/30/23 10:25

ENVIRONMENTAL SERVICE LABORATORIES, INC.

SAMPLE REQUEST & CHAIN OF CUSTODY

3E ___ 1 ___ OF ___ 1 ___

HEADQUARTER
1803 Philadelphia St.
Indiana, PA 15701
(724) 463-TEST
FAX: (724) 465-4209

SOUTHERN DIVISION
1276 Bentleyville Road
Van Vorths, PA 15366
(724) 258-TEST
FAX: (724) 258-8376

NORTHERN DIVISION
435 Broad Street
Montoursville, PA 17754
(570) 321-9003
FAX: (570) 321-1957

NORTHWEST DIVISION
950 Main Street
Sharpsville, PA 16
(724) 463-TEST
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 23C2937	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 802	01	3-31-03	1625	DW	Field	Field	Free Chlorine 0.58 mg/L
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>							
<p>Notes/Special Instructions::</p> <p><i>Drinking Water Dassa McKinney - Weekly</i></p>				<p>Company/Name: MONTEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: 724-406-4426</p> <p>Email Address: jcampbell@monteau.org</p> <p>Billing Address: 5100316</p> <p>PWSID: 5100316</p>			
<p>Sampled By: (Signature) <i>[Signature]</i></p> <p>Date/ Time 3-31-03 1625</p>		<p>Received By: (Signature) <i>[Signature]</i></p> <p>Date/ Time 3/30/03 1350</p>		<p>Relinquished By: (Signature) <i>[Signature]</i></p> <p>Date/ Time 3-30-03 1349</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>	
<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Received By: (Signature)</p> <p>Date/ Time</p>		<p>Relinquished By: (Signature)</p> <p>Date/ Time</p>		<p>Correct Preservations Y / N / NA</p> <p>Correct Containers Y / N / NA</p> <p>Receipt Temperature</p>	



E-Government Application for Drinking Water Program
 SAFE DRINKING WATER ACT
 VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL
SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.84	030223	801		030223	D	1136	32382	23C0267-01	BROWNKA 177
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	030323	801		030223	D	1136	32382	23C0267-01	BROWNKA 178
5100316	1013	FREE CHLORINE	301	1.08	030923	802		030923	D	1127	32382	23C1076-01	BROWNKA 179
5100316	1013	FREE CHLORINE	301	0.58	033023	802		033023	D	1025	32382	23C2937-01	BROWNKA 1971
5100316	1013	FREE CHLORINE	301	0.66	031623	803		031623	D	1105	32382	23C1747-01	BROWNKA 870
5100316	1013	FREE CHLORINE	301	0.84	032323	804		032323	D	1015	32382	23C2330-01	BROWNKA 1258