

**Moniteau School District  
Maintenance Department  
Moniteau High School School  
Monthly Operations Report  
Water Quality Test Results  
May 2022**

MONTH		MONTEAU HIGH SCHOOL WATER TREATMENT PLANT									
DAY	TEMP	LEVEL	METER READING	CL2 FREE	CL2 TOTAL	PH	IRON	MAG.	HARDNESS	OPERATOR	TIME
1	SUN										
2	Mon	68.0	9.70	5,996, 605	1.13	1.27	7.1	0.00	0	Jeff C	5:00 AM
3	Tues	68.0	8.57	5996, 605	1.14	1.27	7.1	0.00	0	Jeff C	8:00 AM
4	Wed	62.0	8.90	6,006, 286	1.13	1.23	7.0	0.02	0	Jeff C	3:00 PM
5	Thurs	62.0	8.45	6,010, 636	1.09	1.18	7.0	0.00	0	Jeff C	9:00 AM
6	Fri	69.0	9.30	6,034, 385	1.01	1.10	7.0	0.00	0	Jeff C	8:00 AM
7	SAT										
8	SUN										
9	Mon	73.0	9.70	6,099, 500	0.67	0.73	6.9	0.03	0	Jeff C	9:15 AM
10	Tues	70.1	8.56	6,108, 866	0.67	0.73	7.0	0.02	0	Jeff C	9:00 AM
11	Wed	77.1	7.16	6,108, 866	0.66	0.72	7.0	0.02	0	Jeff C	4:00 PM
12	Thurs	79.5	8.76	6,128, 821	0.54	0.61	7.0	0.04	0	Jeff C	11:00 AM
13	Fri	69.6	9.89	6,142, 715	0.62	0.70	7.0	0.01	0	Jeff C	4:00 PM
14	SAT										
15	SUN										
16	Mon	55.8	9.17	6,163, 081	0.85	0.90	6.9	0.03	0	Jeff C	1:00 PM
17	Tues	62.0	9.42	6,174, 489	0.78	0.85	7.0	0.02	0	Jeff C	4:00 PM
18	Wed	67.0	9.14	6,187, 673	1.07	1.13	7.0	0.00	0	Jeff C	5:00 PM
19	Thurs	67.0	10.00	6,222, 488	0.89	0.91	7.0	0.00	0	Jeff C	2:00 PM
20	Fri	66.0	9.41	6,222, 488	0.89	0.90	7.0	0.00	0	Jeff C	4:00 PM
21	SAT										
22	SUN										
23	Mon	70.0	7.22	6,222, 488	0.88	0.90	7.0	0.00	0	Jeff C	7:00 AM
24	Tues	68.0	9.15	6,295, 562	0.55	0.61	7.1	0.02	0	Jeff C	7:00 AM
25	Wed	71.0	9.20	6,319, 603	0.58	0.64	7.1	0.01	0	Jeff C	3:00 PM
26	Thurs	71.0	9.69	6,331, 978	0.54	0.61	6.9	0.02	0	Jeff C	8:00 AM
27	Fri										
28	SAT										
29	SUN										
30	Mon	71.0	7.27	6,331, 978	0.47	0.50	6.9	0.01	0	Jeff C	5:00 PM
31	Tues	71.0	8.95	6,413, 097	0.33	0.43	6.9	0.03	0	Jeff C	11:00 AM

TTHM  
HAAS

4/30/22 Meter Reading 5,982, 391

WATER

SEWAGE



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 May 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2050556**  
**Project: Drinking Water Moniteau Jr/Sr - Monthly 704**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
704 Kitchen Main Sink	2050556-01	Drinking Water	05/05/2022 12:00	5/5/22 14:56	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/11/2022 11:23

**Lab Sample ID#:** 2050556-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 704 Kitchen Main Sink

**Sample Date:** 05/05/2022 12:00  
**Receipt Date:** 05/05/2022 14:56

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	1.10	mg/L		0.200	PS	05/05/22 12:00	05/05/22 12:00
<b>Microbiology</b>	<b>Analytical Method: SM9223 B-04</b>				<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	05/05/22 15:42	05/06/22 17:51
E. Coli	Absent	per 100 mL		1	DAA	05/05/22 15:42	05/06/22 17:51

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Ro.  
Van Voorhis, PA 153  
(724) 258-TEST  
FAX: (724) 258-9371

2050556



NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16150  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE 1 OF 1

Sample Identification		ESL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested			
CIRCLE ONE: 704 KITCHEN MAIN SINK <del>802-ROOM 204 SINK</del>		2050556	Grab	Time							
		07	5522	1200	DW	1	STERILE PLASTIC NA THIO	TC/EC Free Chlorine <u>1.10</u>			
<p>704: Jan, Mar, May, Jul, Sept, Nov</p> <p>802: Feb, Apr, Jun, Aug, Oct, Dec</p>											
<p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.2% PER MONTH (1.8% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>											
<p>Sampled By: (Signature) <u>[Signature]</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u></p> <p>Relinquished By: (Signature)</p> <p>Relinquished By: (Signature)</p>			<p>Received By: (Signature) <u>[Signature]</u></p> <p>Received By: (Signature)</p> <p>Received By: (Signature)</p>			<p>Date/ Time <u>5522 1200</u></p> <p>Date/ Time <u>5522 1456</u></p> <p>Date/ Time</p> <p>Date/ Time</p>			<p>Notes/Special Instructions:  <i>Drinking Water Moniteau Jr/Sr - Monthly</i></p>		
<p>Company/Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 1810 WEST SUNBURY ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>											
<p>Correct Preservations <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N / <input type="checkbox"/> NA</p>			<p>Correct Containers <input checked="" type="checkbox"/> Y / <input type="checkbox"/> N / <input type="checkbox"/> NA</p>			<p>Receipt Temperature <u>41.9</u> <sup>CE</sup> <sub>103</sub></p>					



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.1	050522	704		050522	D	1200	32382	2050556-01	BROWNKA_78
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	704		050522	D	1200	32382	2050556-01	BROWNKA_79
5100324	1013	FREE CHLORINE	301	0.69	050922	802		050922	D	0855	32382	2050836-01	BROWNKA_80



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 May 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2050836**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 204 Sink	2050836-01	Drinking Water	05/09/2022 08:55	5/9/22 17:43	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/11/2022 14:26

**Lab Sample ID#:** 2050836-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 204 Sink

**Sample Date:** 05/09/2022 08:55  
**Receipt Date:** 05/09/2022 17:43

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>			<b>Prep Method: No Prep - Field</b>			
Chlorine, Free	0.690	mg/L		0.200	PS	05/09/22 08:55	05/09/22 08:55



WATER SERVICE  
WORKS, INC.

REQUEST & CHAIN OF CUSTODY

BE 1 OF 1



2050836

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 453-TEST  
FAX: (724) 455-4205

LABORATORY USE ONLY

Sample ID/Location	E.L.#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Time				
Distribution: 802	2050836	5/27	0855	DW	Field	Field	Free Chlorine .69 mg/L

- ROTATION
- Wk 1 - 704 Kitchen Sink
  - Wk 2 - 802 Room 204 Sink
  - Wk 3 - 803 Admin Sink
  - Wk 4 - 804 400 Hall RR Sink
  - Wk 5 - 804 400 Hall RR Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)
- THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Drinking Water Moniteau Jr/Sr - Weekly


Notes/Special Instructions:

Sampled By: (Signature) *S-927 0855* Date/ Time 5/14/22 17:43  
 Relinquished By: (Signature) *S-927 1528* Date/ Time 5/14/22 17:43

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Company Name: MONITEAU SCHOOL DISTRICT  
 Address: 391 HOOKER ROAD  
 WEST SUNBURY, PA 16061  
 Contact Person: JEFFREY CAMPBELL  
 Phone Number: 724-406-4426  
 Cell Phone: 724-406-4426  
 Email Address: [JCampbell@moniteau.org](mailto:JCampbell@moniteau.org)  
 Billing Address: \_\_\_\_\_  
 PWSID: 5100324

Correct Preservations Y/N/NA Correct Containers Y/N/NA Receipt Temperature \_\_\_\_\_



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.1	050522	704		050522	D	1200	32382	2050556-01	BROWNKA_78
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	704		050522	D	1200	32382	2050556-01	BROWNKA_79
5100324	1013	FREE CHLORINE	301	0.69	050922	802		050922	D	0855	32382	2050836-01	BROWNKA_80



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 463-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8378  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 463-4209  
 PADEP: 43-04934

23 May 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 2051908  
 Project: Drinking Water Moniteau Jr/Sr - Weekly  
 Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Admin Sink	2051908-01	Drinking Water	05/19/2022 11:40	5/19/22 14:53	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions


RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
 Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpshville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/23/2022 16:15

Lab Sample ID#: 2051908-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Paul Somogyi  
 Client Sample ID: 803 Admin Sink

Sample Date: 05/19/2022 11:40  
 Receipt Date: 05/19/2022 14:53

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11		Prep Method: No Prep - Field				
Chlorine, Free	1.19	mg/L		0.200	PS	05/19/22 11:40	05/19/22 11:40

**ENVIRONMENTAL SERVICE LABORATORIES, INC.**

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Vorum, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

SE 1 OF 1

Sample Identification	ESL#	Sample Type		Matrix	# of Bottles	Container Type	Analysis Requested
		Grab	Time				
Distribution: <u>SCS</u>	<u>2051902</u>	<u>5/19/22</u>	<u>11:30</u>	DW	Field	Field	Free Chlorine <u>1.19</u> mg/L
<p>FOR INTERNAL LABORATORY USE ONLY</p>							
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803 Admin Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>							
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.25% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS</p>							
<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>5/19/22 11:30</u></p> <p>Relinquished By: (Signature) <u>[Signature]</u> Date/ Time <u>5/19/22 13:14</u></p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p> <p>Relinquished By: (Signature) _____ Date/ Time _____</p>				<p>Notes/Special Instructions:</p> <p><i>Drinking Water Moniteau Jr/Sr - Weekly</i></p>			
<p>Received By: (Signature) <u>[Signature]</u> Date/ Time <u>5/19/22</u></p> <p>Received By: (Signature) _____ Date/ Time _____</p> <p>Received By: (Signature) _____ Date/ Time _____</p>				<p>Company/Name: <b>MONITEAU SCHOOL DISTRICT</b></p> <p>Address: <b>391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</b></p> <p>Contact Person: _____ Phone Number: <b>724-406-4426</b> Cell Phone: <b>jcampbell@moniteau.org</b> Email Address: _____ Billing Address: _____ PWSID: <b>5100324</b></p>			
<p>Correct Preservations Y / N / NA</p>				<p>Correct Containers Y / N / NA</p> <p>Receipt Temperature _____</p>			






E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

5100324: MONITEAU JR/SR HIGH SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.1	050522	704		050522	D	1200	32382	2050556-01	BROWNKA_78
5100324	2450	MONOCHLOROACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_903
5100324	2451	DICHLOROACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_904
5100324	2452	TRICHLOROACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_905
5100324	2453	MONOBROMOACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_906
5100324	2454	DIBROMOACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_907
5100324	2456	HALOACETIC ACIDS (FIVE)	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_908
5100324	2941	CHLOROFORM (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_909
5100324	2942	BROMOFORM (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_910
5100324	2943	BROMODICHLOROMETHANE (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_911
5100324	2944	CHLORODIBROMOMETHANE (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_912
5100324	2950	TRihalOMETHANES	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_913
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	704		050522	D	1200	32382	2050556-01	BROWNKA_79
5100324	1013	FREE CHLORINE	301	0.69	050922	802		050922	D	0855	32382	2050836-01	BROWNKA_80
5100324	1013	FREE CHLORINE	301	1.19	051922	803		051922	D	1140	32382	2051908-01	BROWNKA_1219



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

31 May 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2052494**  
**Project: Drinking Water Moniteau Jr/Sr - Weekly**  
**Project Description: Drinking Water**

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 400 Hall RR Sink	2052494-01	Drinking Water	05/26/2022 10:15	5/26/22 12:45	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 05/31/2022 15:17

**Lab Sample ID#:** 2052494-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Logan Robbins  
**Client Sample ID:** 804 400 Hall RR Sink

**Sample Date:** 05/26/2022 10:15  
**Receipt Date:** 05/26/2022 12:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.510	mg/L		0.200	LR	05/26/22 10:15	05/26/22 10:15



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15366  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

FOR INTERNAL LABORATORY USE ONLY

## SAMPLE REQUEST & CHAIN OF CUSTODY

3E \_\_\_1\_\_\_ OF \_\_\_1\_\_\_

Sample Identification	ESL# 2052494	Sample Type Grab	Matrix	# of Bottles	Container Type Preservative	Analysis Requested
Distribution: 804	01	Date 5/26/22	DW	Field	Field	Free Chlorine 51 mg/L
<p>ROTATION</p> <p>Wk 1 - 704 Kitchen Sink</p> <p>Wk 2 - 802 Room 204 Sink</p> <p>Wk 3 - 803-Admin-Sink</p> <p>Wk 4 - 804 400 Hall RR Sink</p> <p>Wk 5 - 804 400 Hall RR Sink</p>						
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW.)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>						
<p>Notes/Special Instructions: Drinking Water Moniteau Jr/Sr - Weekly</p>						
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061</p> <p>Contact Person: JEFFREY CAMPBELL</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone: jcampbell@moniteau.org</p> <p>Email Address: jcampbell@moniteau.org</p> <p>Billing Address: 5100324</p> <p>PWSID: 5100324</p>						
Sampled By: (Signature) YVR	Date/ Time 5/26/22 1015	Received By: (Signature) Alex Popper	Date/ Time 5/26/22 1245	Correct Containers	Y / N / NA	Receipt Temperature
Relinquished By: (Signature) YVR	Date/ Time 5/26/22 1245	Received By: (Signature)	Date/ Time	Correct Containers	Y / N / NA	Receipt Temperature
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Correct Containers	Y / N / NA	Receipt Temperature
Relinquished By: (Signature)	Date/ Time	Received By: (Signature)	Date/ Time	Correct Containers	Y / N / NA	Receipt Temperature





E-Government Application for Drinking Water Program  
**SAFE DRINKING WATER ACT**  
 VIEW/EDIT RECORDS

**5100324: MONITEAU JR/SR HIGH SCHOOL**  
**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100324	1013	FREE CHLORINE	301	1.1	050522	704		050522	D	1200	32382	2050556-01	BROWNKA_78
5100324	2450	MONOCHLOROACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_903
5100324	2451	DICHLOROACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_904
5100324	2452	TRICHLOROACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_905
5100324	2453	MONOBROMOACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_906
5100324	2454	DIBROMOACETIC ACID	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_907
5100324	2456	HALOACETIC ACIDS (FIVE)	206	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_908
5100324	2941	CHLOROFORM (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_909
5100324	2942	BROMOFORM (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_910
5100324	2943	BROMODICHLOROMETHANE (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_911
5100324	2944	CHLORODIBROMOMETHANE (THM)	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_912
5100324	2950	TRIHALOMETHANES	221	0.0	051222	704		050922	D	0900	32382	2050761-01	BROWNKA_913
5100324	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	704		050522	D	1200	32382	2050556-01	BROWNKA_79
5100324	1013	FREE CHLORINE	301	0.69	050922	802		050922	D	0855	32382	2050836-01	BROWNKA_80
5100324	1013	FREE CHLORINE	301	1.19	051922	803		051922	D	1140	32382	2051908-01	BROWNKA_1219
5100324	1013	FREE CHLORINE	301	0.51	052622	804		052622	D	1015	32382	2052494-01	BROWNKA_1807

**Moniteau School District  
Maintenance Department  
Dassa McKinney Elem. School  
Monthly Operations Report  
Water Quality Test Results  
May 2022**

Dassa McKinney Elementary School Water Treatment Facility										
Month	Day	PH	Iron	Cl2 Free	Cl2 Total	Hardness	Meter Reading	Operator	Time	Notes
1	Sun									
2	Mon	8.6	0.02	0.67	0.73	1.41	13379100	JEFF C	5:00 AM	
3	Tues	8.6	0.02	0.67	0.74	1.44	13383300	JEFF C	4:30 AM	
4	Wed	8.6	0.02	0.66	0.73	1.37	13383300	JEFF C	4:30 AM	
5	Thurs									
6	Fri									
7	Sat									
8	Sun									
9	Mon	8.7	0.04	0.60	0.68	1.78	13395700	JEFF R	4:30P	12400
10	Tues	8.7	0.02	0.67	0.73	1.88	13399700	JEFF R	5:00P	4000
11	Wed	8.7	0.02	0.58	0.65	1.35	13403900	JEFF R	4:30P	4200
12	Thurs	8.7	0.00	0.75	0.83	1.44	13408200	JEFF R	4:30P	4300
13	Fri	8.7	0.04	0.70	0.78	1.47	13411500	JEFF R	3:30P	3300
14	Sat									
15	Sun									
16	Mon	8.7	0.02	0.59	0.66	1.68	13415400	JEFF R	3:30P	3900
17	Tues	8.7	0.04	0.55	0.63	1.71	13419700	JEFF R	3:30P	4300
18	Wed	8.7	0.02	0.73	0.80	1.44	13423500	JEFF R	2:30P	3800
19	Thurs	8.7	0.00	0.65	0.72	1.59	13428500	JEFF R	4:00P	5000
20	Fri	8.7	0.01	0.68	0.76	1.84	13432800	JEFF R	4:30P	4300
21	Sat									
22	Sun									
23	Mon	8.7	0.00	0.59	0.66	1.33	13436500	JEFF R	3:30P	3700
24	Tues	8.7	0.00	0.61	0.70	1.48	13441500	JEFF R	3:30P	5000
25	Wed	8.7	0.02	0.73	0.80	1.71	13446500	JEFF R	4:30P	5000
26	Thurs	8.7	0.00	0.73	0.81	1.62	13451600	JEFF R	4:30P	5100
27	Fri	8.7	0.01	0.72	0.79	1.33	13456100	JEFF R	3:30P	4500
28	Sat									
29	Sun									
30	Mon									
31	Tues	8.7	0.03	0.64	0.73	1.25	13461000	JEFF R	3:30P	4900

Meter Reading - Apr. 29, 2022 - 13370000



1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 May 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2050555**  
**Project: Drinking Water Dassa McKinney - Monthly 801**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
801 Kitchen Sink	2050555-01	Drinking Water	05/05/2022 11:40	5/5/22 15:13	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager





1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/11/2022 11:22

**Lab Sample ID#:** 2050555-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 801 Kitchen Sink

**Sample Date:** 05/05/2022 11:40  
**Receipt Date:** 05/05/2022 15:13

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-CI G-11</b>				<b>Prep Method: No Prep - Field</b>		
Chlorine, Free	0.640	mg/L		0.200	PS	05/05/22 11:40	05/05/22 11:40
<b>Microbiology</b>	<b>Analytical Method: SM9223 B-04</b>				<b>Prep Method: No Prep - Micro</b>		
Total Coliform	Absent	per 100 mL		1	DAA	05/05/22 15:42	05/06/22 17:51
E. Coli	Absent	per 100 mL		1	DAA	05/05/22 15:42	05/06/22 17:51

This sample MEETS current EPA and DEP bacteriological standards of no detectable coliform bacteria per 100 mL sample.

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St.  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Bentleyville Roe  
Van Voorhis, PA 1531  
(724) 258-TEST  
FAX: (724) 258-837

NORTHWEST DIVISION  
950 Main Street  
Sharpshville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

Page 3 of 4

Sample Identification <b>801 KITCHEN SINK</b> <b>802 ROOM 617 SINK</b>	ESL# <b>2050555</b>	Sample Type Date <b>5-5-22</b>	Grab Time <b>1140</b>	Matrix <b>DW</b>	# of Bottles <b>1</b>	Container Type Preservative <b>STERILE PLASTIC</b> <b>NA THIO</b>	Analysis Requested <b>TC / EC</b> Free Chlorine <b>64</b> mg/L

Rotation:  
801: Jan, Mar, May, Jul, Sep,  
Nov  
802: Feb, Apr, Jun, Aug, Oct,  
Dec

Notes/Special Instructions:

*Drinking Water Dassa McKinney - Monthly*

Company Name: **MONITEAU SCHOOL DISTRICT**  
Address: **391 HOOKER ROAD**  
**WEST SUNBURY, PA 16061**  
Contact Person: **JEFFREY CAMPBELL**  
Phone Number: **724-406-4426**  
Cell Phone: **jcampbell@moniteau.org**  
Billing Address:  
PWSID: **5100316**

Received By: (Signature) *Joseph Shady* Date/Time **5-5-22 1513**

Sampled By: (Signature) *[Signature]* Date/Time **5-5-22 1140**

Relinquished By: (Signature) *[Signature]* Date/Time **5-5-22 1409**

Received By: (Signature) Date/Time

Relinquished By: (Signature) Date/Time

Relinquished By: (Signature) Date/Time

Correct Preservations **Y** / **N** / **NA** Correct Containers **Y** / **N** / **NA** Receipt Temperature **4.9** *(45)*

THE UNDERSIGNED PURCHASER AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 30 DAYS OLD.

IF THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.2% PER MONTH (1.8% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW.

IF THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.64	050522	801		050522	D	1140	32382	2050555-01	BROWNKA_75
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	801		050522	D	1140	32382	2050555-01	BROWNKA_76
5100316	1013	FREE CHLORINE	301	0.44	050922	802		050922	D	0840	32382	2050835-01	BROWNKA_77





1803 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Sharpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

11 May 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

**Work Order: 2050835**  
**Project: Drinking Water Dassa McKinney - Weekly**  
**Project Description: Drinking Water**

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
802 Room 617 Sink	2050835-01	Drinking Water	05/09/2022 08:40	5/9/22 17:41	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

*Kirsten Conoran*

Kirsten Conoran  
Project Manager



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/11/2022 14:23

**Lab Sample ID#:** 2050835-01  
**Sample Type:** Drinking Water  
**Sample Source:** Grab  
**Sampler:** Paul Somogyi  
**Client Sample ID:** 802 Room 617 Sink

**Sample Date:** 05/09/2022 08:40  
**Receipt Date:** 05/09/2022 17:41

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
<b>Field Analysis</b>	<b>Analytical Method: SM4500-Cl G-11</b>		<b>Prep Method: No Prep - Field</b>				
Chlorine, Free	0.440	mg/L		0.200	PS	05/09/22 08:40	05/09/22 08:40

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

3000 W. 15th St.  
Denver, CO 80202  
(303) 463-7777  
FAX: (303) 463-7778



MONTICLOM DIVISION  
734

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

3E 1 OF 1

Sample Identification	EOL#	Sample Type		Matrix	# of Bottles	Container Type Preservative	Analysis Requested
		Date	Grab Time				
Distribution: <u>802</u>	<u>2050835</u>	<u>5-02-07</u>	<u>0840</u>	DW	Field	Field	Free Chlorine <u>0.14</u> mg/L

**ROTATION**  
 Wk 1 - 801 Kitchen Sink  
 Wk 2 - 802 Room 617 Sink  
 Wk 3 - 803 Room 606 Sink  
 Wk 4 - 804 Room 408 Sink  
 Wk 5 - 802 Room 617 Sink

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (18% PER ANNUM) OR THE MAXIMUM ALLOWED BY LAW;
2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Sampled By: (Signature) [Signature] Date/ Time 5-02-07 0840  
 Relinquished By: (Signature) [Signature] Date/ Time 5-02-07 1538

Received By: (Signature) [Signature] Date/ Time 5/19/07 1741  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Notes/Special Instructions: **Drinking Water Dassa McKinney - Weekly**

Company Name: **MONITEAU SCHOOL DISTRICT**  
 Address: **391 HOOKER ROAD  
WEST SUNBURY, PA 16061  
JEFFREY CAMPBELL**  
 Contact Person: **JEFFREY CAMPBELL**  
 Phone Number: **724-406-4426**  
 Cell Phone: **724-406-4426**  
 Email Address: **jcampbell@moniteau.org**  
 Billing Address: **JEFFREY CAMPBELL**  
 PWSID: **5100316**

Correct Preservations Y/N/NA    Correct Containers Y/N/NA    Receipt Temperature \_\_\_\_\_



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

**5100316: DASSA MCKINNEY ELEM SCHOOL**

**SDWA1**

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.64	050522	801		050522	D	1140	32382	2050555-01	BROWNKA_75
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	801		050522	D	1140	32382	2050555-01	BROWNKA_76
5100316	1013	FREE CHLORINE	301	0.44	050922	802		050922	D	0840	32382	2050835-01	BROWNKA_77



1805 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpsville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

23 May 2022

Moniteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 2051910  
 Project: Drinking Water Dassa McKinney - Weekly  
 Project Description: Drinking Water

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
803 Room 606 Sink	2051910-01	Drinking Water	05/19/2022 11:30	5/19/22 14:56	

#### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

#### Definitions

RL Reporting Limit

#### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

#### Approved By

Kirsten Conoran  
 Project Manager



1805 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 32-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Snarpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

Moniteau School District  
1810 West Sunbury Road  
West Sunbury, PA 16061

Reported: 05/23/2022 16:16

Lab Sample ID#: 2051910-01  
Sample Type: Drinking Water  
Sample Source: Grab  
Sampler: Paul Somogyi  
Client Sample ID: 803 Room 606 Sink

Sample Date: 05/19/2022 11:30  
Receipt Date: 05/19/2022 14:56

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-Cl G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.600	mg/L		0.200	PS	05/19/22 11:30	05/19/22 11:30

# ENVIRONMENTAL SERVICE LABORATORIES, INC.

HEADQUARTER  
1803 Philadelphia St  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 465-4209

SOUTHERN DIVISION  
1276 Beniteyville Road  
Van Voorhis, PA 15365  
(724) 258-TEST  
FAX: (724) 258-8376

NORTHERN DIVISION  
435 Broad Street  
Montoursville, PA 17754  
(570) 321-9003  
FAX: (570) 321-1857

NORTHWEST DIVISION  
950 Main Street  
Sharpville, PA 16  
(724) 463-TEST  
FAX: (724) 465-4209

## SAMPLE REQUEST & CHAIN OF CUSTODY

SE \_\_\_ OF \_\_\_

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL# 2051910	Matrix	# of Bottles	Container Type	Analysis Requested										
Distribution: 305	01	DW	Field	Preservative	Free Chlorine .60 mg/L										
<table border="1"> <thead> <tr> <th colspan="2">Sample Type</th> <th rowspan="2">Date</th> <th rowspan="2">Time</th> </tr> <tr> <th>Grab</th> <th>Time</th> </tr> </thead> <tbody> <tr> <td></td> <td></td> <td>5/19/22</td> <td>1130</td> </tr> </tbody> </table>						Sample Type		Date	Time	Grab	Time			5/19/22	1130
Sample Type		Date	Time												
Grab	Time														
		5/19/22	1130												
<p>ROTATION</p> <p>Wk 1 - 801 Kitchen Sink</p> <p>Wk 2 - 802 Room 617 Sink</p> <p>Wk 3 - 803 Room 606 Sink</p> <p>Wk 4 - 804 Room 408 Sink</p> <p>Wk 5 - 802 Room 617 Sink</p>															
<p>THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD</p> <p>1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.25% PER MONTH (16% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)</p> <p>2. THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.</p>															
<p>Notes/Special Instructions: <i>Drinking Water Dassa McKinney - Weekly</i></p>															
<p>Sampled By: (Signature) <i>[Signature]</i></p> <p>Relinquished By: (Signature) <i>[Signature]</i></p> <p>Relinquished By: (Signature)</p> <p>Relinquished By: (Signature)</p>		<p>Received By: (Signature) <i>Alex Popera</i> Date/ Time 5/19/22</p> <p>Received By: (Signature)</p> <p>Received By: (Signature)</p>													
<p>Correct Preservations Y/N/NA</p>		<p>Correct Containers Y/N/NA</p> <p>Receipt Temperature</p>													
<p>Company Name: MONITEAU SCHOOL DISTRICT</p> <p>Address: 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL</p> <p>Contact Person: jcampbell@moniteau.org</p> <p>Phone Number: 724-406-4426</p> <p>Cell Phone:</p> <p>Email Address: jcampbell@moniteau.org</p> <p>Billing Address:</p> <p>PWSID: 5100316</p>															





E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.64	050522	801		050522	D	1140	32382	20505555-01	BROWNKA_75
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	801		050522	D	1140	32382	20505555-01	BROWNKA_76
5100316	1013	FREE CHLORINE	301	0.44	050922	802		050922	D	0840	32382	2050835-01	BROWNKA_77
5100316	1013	FREE CHLORINE	301	0.6	051922	803		051922	D	1130	32382	2051910-01	BROWNKA_1218





1801 Philadelphia Street  
Indiana, PA 15701  
P: (724) 463-8378  
F: (724) 465-4209  
PADEP: 3C-00382

1276 Bentleyville Road  
Van Voorhis, PA 15366  
P: (724) 258-8378  
F: (724) 258-8376  
PADEP: 63-04247

435 Broad Street  
Montoursville, PA 17754  
P: (570) 321-9002  
F: (570) 321-1957  
PADEP: 41-04880

950 West Main Street  
Snarpsville, PA 16150  
P: (724) 463-8378 x 500  
F: (724) 465-4209  
PADEP: 43-04934

31 May 2022

Moniteau School District  
Attn: Jeffrey Campbell  
1810 West Sunbury Road  
West Sunbury, PA 16061

Work Order: 2052491  
Project: Drinking Water Dassa McKinney - Weekly  
Project Description: Drinking Water

## Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
804 Room 408 Sink	2052491-01	Drinking Water	05/26/2022 09:42	5/26/22 12:45	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

RL Reporting Limit

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.

### Approved By

Kirsten Conoran  
Project Manager



1605 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 463-4209  
 PADEP: 32-00362

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 83-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04680

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 463-4209  
 PADEP: 43-04934

Moniteau School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/31/2022 11:47

Lab Sample ID#: 2052491-01  
 Sample Type: Drinking Water  
 Sample Source: Grab  
 Sampler: Logan Robbins  
 Client Sample ID: 804 Room 408 Sink

Sample Date: 05/26/2022 09:42  
 Receipt Date: 05/26/2022 12:45

Analyte	Sample Result	Units	Data Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
Field Analysis	Analytical Method: SM4500-C1 G-11				Prep Method: No Prep - Field		
Chlorine, Free	0.570	mg/L		0.200	LR	05/26/22 09:42	05/26/22 09:42

**ENVIRONMENTAL SERVICE  
LABORATORIES, INC.**

HEADQUARTER  
1805 Philadelphia St  
Indiana, PA 15701  
(724) 463-TEST  
FAX: (724) 406-4209

SOUTHERN DIVISION  
1276 Bentleyville Road  
Van Voorhis, PA 15386  
(724) 258-TEST  
FAX: (724) 256-8376

NORTHERN DIVISION  
435 Broad Street  
Monroeville, PA 17174  
(570) 321-5003  
FAX: (570) 321-1957

NORTHWEST DIVISION  
950 Main Street  
Sharpsville, PA 15  
(724) 463-TEST  
FAX: (724) 465-4209

**SAMPLE REQUEST & CHAIN OF CUSTODY**

SE \_\_\_\_\_ OF \_\_\_\_\_

FOR INTERNAL LABORATORY USE ONLY

Sample Identification	ESL#	# of Bottles	Container Type Preservative	Analysis Requested
	2052491			
Distribution: SCH	01	DW	Field	

Sample Type	Sample Type		# of Bottles	Container Type Preservative	Analysis Requested
	Date	Time			
	5/20/12	0942	Field	Field	

**ROTATION**

- Wk 1 - 801 Kitchen Sink
- Wk 2 - 802 Room 617 Sink
- Wk 3 - 803 Room 606 Sink
- Wk 4 - 804 Room 408 Sink
- Wk 5 - 802 Room 617 Sink



THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD

- THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.10% PER MONTH (6% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)
- THE UNDERSIGNED PURCHASER AGREES TO PAY IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION. REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS

Sampled By (Signature) <i>John R</i> Date/ Time <i>5/20/12 0942</i> Relinquished By (Signature) <i>John R</i> Date/ Time <i>5/20/12 1243</i>		Received By (Signature) <i>Alex Popperin</i> Date/ Time <i>5/20/12</i> Received By (Signature) _____ Date/ Time _____ Received By (Signature) _____ Date/ Time _____	
Correct Preservations Y / N / NA		Correct Containers Y / N / NA	
Receipt Temperature		Receipt Temperature	
Company Name MONITEAU SCHOOL DISTRICT		Address 391 HOOKER ROAD WEST SUNBURY, PA 16061 JEFFREY CAMPBELL	
Contact Person Phone Number Cell Phone Email Address Billing Address PWSID		724-406-4426 jcampbell@moniteau.org 5100316	

Notes/Special Instructions:

Drinking Water Dassa McKinney - Weekly



E-Government Application for Drinking Water Program

SAFE DRINKING WATER ACT  
VIEW/EDIT RECORDS

5100316: DASSA MCKINNEY ELEM SCHOOL

SDWA1

PWSID	Contam ID	Contam	Analysis Method	Result	Analysis Date	Location ID 1	Location ID 2	Sample Date	Sample Type	Sample Time	Lab ID	Sample ID	Record ID
5100316	1013	FREE CHLORINE	301	0.64	050522	801		050522	D	1140	32382	2050555-01	BROWNKA_75
5100316	3100	TOTAL COLIFORM PRESENCE	331	0.0	050622	801		050522	D	1140	32382	2050555-01	BROWNKA_76
5100316	1013	FREE CHLORINE	301	0.44	050922	802		050922	D	0840	32382	2050835-01	BROWNKA_77
5100316	1013	FREE CHLORINE	301	0.6	051922	803		051922	D	1130	32382	2051910-01	BROWNKA_1218
5100316	1013	FREE CHLORINE	301	0.57	052622	804		052622	D	0942	32382	2052491-01	BROWNKA_1806

**Moniteau School District  
Maintenance Department  
Moniteau High School  
Monthly Operations Report  
Wastewater DMR Test Results  
May 2022**





JEFFREY CAMPBELL <jcampbell@moniteau.org>

## Your eDMR Report Has Been Received For Permit No. PA0091341

depgreenporthelpdesk@state.pa.us <depgreenporthelpdesk@state.pa.us>  
To: jcampbell@moniteau.org, mcafoose92@hotmail.com

Mon, Jun 13, 2022 at 11:42 AM

This email is to confirm that the following report was received by DEP through the eDMR system:

**Facility Name:** MONITEAU JR SR HIGH SCHOOL  
**Permit Number:** PA0091341  
**Report Frequency:** Monthly  
**Report Type:** DMR  
**Reporting Period:** 05/01/2022-05/31/2022  
**Report Due Date:** 06/28/2022

**Submitted By:** Jeffrey Campbell  
**Submission Id:** 332697  
**Submission Status:** Received  
**Submission Type:** Original

To view the details of this report, access the eDMR system through DEP's [GreenPort](#) and select the link for View/Revise Submitted.







COMMONWEALTH OF PENNSYLVANIA  
DEPARTMENT OF ENVIRONMENTAL PROTECTION  
BUREAU OF CLEAN WATER

DISCHARGE MONITORING REPORT (DMR)

NAME: MONTEAU SCH DIST  
ADDRESS: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220  
FACILITY: MONTEAU JR SR HIGH SCHOOL  
LOCATION: 1810 W SUNBURY RD, WEST SUNBURY, PA , 16061-1220  
STAGE: Final Effluent

PA0091341	001
PERMIT NUMBER	OUTFALL NUMBER

Reporting Frequency: Monthly  
DMR Effective From: 05/01/2022  
DMR Effective To: 05/31/2022  
Permit Expires: 05/31/2022  
Permit Application Due: 12/02/2021  
No Discharge:

MONITORING PERIOD					
YEAR	MO	DAY	YEAR	MO	DAY
2022	05	01	2022	05	31

FROM

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING		QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	UNITS	VALUE	UNITS	VALUE	UNITS		
Dissolved Oxygen (00300)	SAMPLE MEASUREMENT	***	***	5.78	***	***	***	1/week	Grab
	PERMIT REQUIREMENT	***	***	4.0 Min	***	***	***	1/week	Grab
pH (00400)	SAMPLE MEASUREMENT	***	***	7.60	***	8.93	***	1/week	Grab
	PERMIT REQUIREMENT	***	***	6.0 Min	***	9.0 Max	S.U.	1/week	Grab
Total Suspended Solids (00590)	SAMPLE MEASUREMENT	***	***	***	***	<5.0	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	***	30 Avg Mo	***	2/month	Grab
Total Nitrogen (00600)	SAMPLE MEASUREMENT	***	***	***	***	<.729	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	***	Monitor & Report Avg Mo	***	2/month	Grab
Total Phosphorus (00665)	SAMPLE MEASUREMENT	***	***	***	***	.235	***	2/month	Grab
	PERMIT REQUIREMENT	***	***	***	***	Monitor & Report Avg Mo	***	2/month	Grab
Ultraviolet light intensity (49607)	SAMPLE MEASUREMENT	***	***	***	***	5.34	***	1/week	Grab
	PERMIT REQUIREMENT	***	***	***	***	Monitor & Report Avg Mo	µW/cm²	1/week	Grab
Flow (50050)	SAMPLE MEASUREMENT	.013883	***	***	***	***	***	1/week	Measured
	PERMIT REQUIREMENT	Monitor & Report Avg Mo	***	MGD	***	***	***	1/week	Measured



DISCHARGE MONITORING REPORT (DMR)

PARAMETER	SAMPLE MEASUREMENT	QUANTITY OR LOADING			QUANTITY OR CONCENTRATION				SAMPLING FREQUENCY	SAMPLING TYPE
		VALUE	VALUE	UNITS	VALUE	VALUE	VALUE	UNITS		
Fecal Coliform (74055)	SAMPLE MEASUREMENT	...	...	...	<1.0	<1.0		No./100 ml	2/month	Grab
	PERMIT REQUIREMENT	...	...	...	200	1000	IMAX		2/month	Grab
Carbonaceous Biochemical Oxygen Demand (CBOD5) (80082)	SAMPLE MEASUREMENT	...	...	...	<2.00	...		mg/L	2/month	Grab
	PERMIT REQUIREMENT	...	...	...	25	Avg Mo			2/month	Grab
Facility Comments										

COMMENT DETAILS

COMMENTS	OPERATOR NAME	OPERATOR CERTIFICATION NUMBER	OPERATOR CONTACT NUMBER
----------	---------------	-------------------------------	-------------------------



High 8.75 #1 DABIN 5/20

DO Low 5.78

High 9.53

TOTAL Nitrogen  $< 0.729 + < 0.729 = < 0.729$

TSS  $< 5 + < 5 = < 5$

TKN  $< 0.625 + < 0.625 = < 0.625$

Nitrate / Nitrite  $0.317 + 0.379 = 0.348$

Phos  $0.23 + 0.24 = 0.235$

COD  $< 2.00 + < 2.00 = < 2.00$

Fecal  $< 1 + < 1 = < 1$

8.78  
8.78  
8.78

$\angle 0.78 + \angle 0.78 = \angle 1.56$   
 $\angle 2 + \angle 2 = \angle 4$   
 $\angle 0.98 + \angle 0.98 = \angle 1.96$   
 $0.815 + 0.815 = 1.63$   
 $0.88 + 0.88 = 1.76$   
 $\angle 2.00 + \angle 2.00 = \angle 4.00$   
 $\angle 1 + \angle 1 = \angle 2$

TRN  
Kilometer  
Pipes  
Cipod  
Lamp

Moniteau High School Sewage Treatment Plant  
 Permit # PA0091341  
 Daily Operations Worksheet

Date	Day	#1 PH	#1 DO	#2 PH	#2 DO	Month	UV	Meter Reading	Time	Operator
5/1	Sun					MAY		5,996,605		JEFF C
5/2	Mon	8.78	8.45	7.71	9.05				5:00 pm	JEFF C
5/3	Tues	8.90	8.60	7.83	9.51				8:00 am	JEFF C
5/4	Wed	8.37	8.55	7.89	9.32				4:00 pm	JEFF C
5/5	Thurs	8.75	8.94	7.75	8.28				11:00 am	JEFF C
5/6	Fri	8.73	8.74	7.71	8.14				5:00 am	JEFF C
5/7	SAT									
5/8	Sun									
5/9	Mon	8.29	8.05	7.60	8.05				5:00 pm	JEFF C
5/10	Tues	8.62	9.01	7.77	8.12				1:00 pm	JEFF C
5/11	Wed	8.71	9.48	7.95	8.37				9:00 am	JEFF C
5/12	Thurs	8.58	9.53	8.05	8.40				11:00 am	JEFF C
5/13	Fri	8.52	9.42	7.95	8.35				11:00 am	JEFF C
5/14	SAT									
5/15	Sun									
5/16	Mon	8.71	6.11	9.99	6.22		5.0		4:00 pm	JEFF C
5/17	Tues	8.81	5.78	8:00	5.97		4.8	#2 Decant	1:30 am	JEFF C
5/18	Wed	8.75	6.92	8.21	6.43		4.9		4:00 pm	JEFF C
5/19	Thurs	8.63	8.00	8.11	7.70		6.1		9:30 am	JEFF C
5/20	Fri	8.23	7.69	8.01	7.75		6.3		2:00 pm	JEFF C
5/21	SAT									
5/22	Sun									
5/23	Mon	8.93	7.63	8.58	5.32		6.1		4:30 pm	JEFF C
5/24	Tues	8.88	7.64	8.40	7.21		6.3		2:30 pm	JEFF C
5/25	Wed	8.53	7.69	8.31	7.44		6.1		11:30 am	JEFF C
5/26	Thurs	8.40	7.70	8.38	7.38		6.0		11:00 am	JEFF C
5/27	Fri	8.38	7.70	8.35	7.96		6.0		7:00 am	JEFF C
5/28	SAT									
5/29	Sun									
5/30	Mon	1st Holiday								
5/31	Tues	8.20	7.76	Acetate			6.0	6,413,097	1:00 pm	JEFF C

112.2  
 2.2

D

C

C


1000

1000





# ENVIRONMENTAL SERVICE LABORATORIES, INC.



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP#: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP#: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP#: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP#: 43-04934

Monteuan School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/31/2022 17:05

Lab Sample ID#: 2051876-01  
 Sample Type: Waste Water  
 Sample Source: Client Grab  
 Sample ID: Effluent Outfall 001

Analyte	Sample	Result	Units	Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
---------	--------	--------	-------	-----------	----	---------------------------	-------------------	-----------------------

General Chemistry	Total Nitrogen	<0.729	mg/L		0.729	DAA	05/30/22 06:30	05/31/22 11:05
Prep Method: CALC Analytical Method: CALC								

General Chemistry	Total Suspended Solids	<5	mg/L		5	LMB	05/25/22 07:57	05/25/22 09:50
Prep Method: No Prep - WetChem Analytical Method: SM2540 D-11								

General Chemistry	Total Kjeldahl Nitrogen	<0.625	mg/L		0.625	DAA	05/30/22 06:30	05/31/22 11:05
Prep Method: SM 4500-Norg B Analytical Method: SM4500 NH3 F-11								

General Chemistry	Nitrate/Nitrite	0.379	mg/L		0.104	AW	05/26/22 13:19	05/26/22 13:19
Prep Method: No Prep - WetChem Analytical Method: SM4500-NO3 E-11 (discrete)								

General Chemistry	Phosphorus	0.24	mg/L		0.10	AW	05/25/22 13:50	05/25/22 13:50
Prep Method: No Prep - WetChem Analytical Method: SM4500-P E-11								

General Chemistry	Carbonaceous Biochemical Oxygen Demand	<2.00	mg/L		2.00	KB	05/20/22 13:20	05/25/22 09:17
Prep Method: No Prep - WetChem Analytical Method: SM5210 B-11								

Microbiology	Fecal Coliforms	<1	MPN/100 mL		1	JDS	05/19/22 14:52	05/20/22 11:09
Prep Method: No Prep - Micro Analytical Method: Collett-18								



# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

<b>HEADQUARTERS</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<input checked="" type="checkbox"/>  <b>SOUTHERN DIVISION</b> 1276 Bentleyville Road Van Voorhis, PA 15366 (724) 258-TEST FAX: (724) 258-9376	<input type="checkbox"/>  <b>NORTHERN DIVISION</b>   2051876   <b>NORTHWEST DIVISION</b> 950 Main Street Sharpville, PA 16150 (724) 463-TEST FAX: (724) 465-4209
--	---	--

**FOR INTERNAL L.**

Sample Identification	ESL#	Sample Type			Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested	
		Composite	Grab	Date					Time
Effluent Outfall 001	2051876								
				5/19/03	10:00 AM	WW	1	Poly 1000mL None	Total Nitrogen, Total Phosphorus
						WW	1	Poly 1000mL H2SO4	
						WW	1	Sterile Plastic 125mL Na2SO3	Fecal Coliform

**THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.**

1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1 1/2% PER MONTH (18% PER ANNUM OR THE MAXIMUM ALLOWED BY LAW)

2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

**Project Notes:**

*Wastewater*

Company/Name: **MONTEAU SCHOOL DISTRICT**

Sampled By: (Signature) *[Signature]* Date/ Time 5/19/03 10:00 AM  
 Received By: (Signature) *[Signature]* Date/ Time 5-19-03 1143

Relinquished By: (Signature) *[Signature]* Date/ Time 5-19-03 1244  
 Received By: (Signature) *[Signature]* Date/ Time SP/WR TSC WSS

Relinquished By: (Signature) *[Signature]* Date/ Time \_\_\_\_\_  
 Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA      Correct Containers Y / N / NA      Receipt Temperature \_\_\_\_\_

Contact Person: **JEFFREY CAMPBELL**  
 Address: **1810 WEST SUNBURY ROAD**  
**WEST SUNBURY, PA 16061**  
 Phone / Cell: **724-406-4426**  
 Email: **jcampbell@monteau.org**





**SAMPLE RECEIPT AND REVIEW FORM**

Client: <u>Monfeyan</u>	Work Or
-------------------------	---------

**PART A: GENERAL INFORMATION - SATELLITE LABORATORY**

Received by/Lab ID: _____	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: <u>FECAL TC/EC TC MPN EC MPN TC/EC MPN</u> <u>N/A</u>	

**PART B: GENERAL INFORMATION - INDIANA LABORATORY**

Received by/Lab ID: <u>00382</u>	Samples Received on Ice? YES NO
Date/Time Received: <u>5/19/22 1350</u>	Date Sampled: <u>5/19/22</u>
Method of Delivery: FedEx UPS Client Drop off _____	Other: <u>ESL courier</u>
Sample Receipt Temperature: <u>13.5</u> °C	IR Gun ID: <u>3</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	PWSID Compliance Drinking Water Samples: YES NO

**PART C: Receipt Details** Completed (if different from above): \_\_\_\_\_ / \_\_\_\_\_ / \_\_\_\_\_

Sample Receipt Criteria	Comments	YES	NO
Chain of custody documents included with samples?	Comments:	YES	NO
COC form is properly signed in relinquished/received sections?	Comments:	YES	NO
Sample containers intact and sealed?	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____	YES	NO
Number of containers received matches number indicated on COC?	Sample IDs and Containers Affected:	YES	NO
Sample IDs on COC match IDs on bottles?	Sample IDs and Containers Affected:	YES	NO
Date and time on COC match date and time on bottles?	Sample IDs and Containers Affected:	YES	NO
Samples received within holding time?	Sample IDs and Containers Affected:	YES	NO
Samples received at appropriate pH for analysis requested?	Sample IDs and Containers Affected and Observed pH:	YES	NO
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.	YES	NO
Adequate sample volume received?	Analyses Affected:	YES	NO
VOA vials free of headspace (defined as < 6 mm bubble)?	Sample IDs and Containers Affected:	YES	NO
Other Comments:	Deficiency Log Created:	YES	NO



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 1754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934



31 May 2022

Monteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 2051876  
 Project: Wastewater  
 Project Description: Wastewater

**Report of Analysis**

Sample ID	Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Notes
2051876-01	Effluent Outfall 001	Waste Water	05/19/2022 10:00	5/19/22 13:50		

**Report Narrative**  
 The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

**Definitions**  
 RL Reporting Limit

**Certifications**  
 Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified.  
 Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

Approved By *Kirsten Conoran*  
 Kirsten Conoran  
 Project Manager







# ENVIRONMENTAL SERVICE LABORATORIES, INC.

## SAMPLE REQUEST & CHAIN OF CUSTODY

PAGE 1 OF 1

<b>HEADQUARTERS</b> 1803 Philadelphia St. Indiana, PA 15701 (724) 463-TEST FAX: (724) 465-4209	<input checked="" type="checkbox"/>	<b>SOUTHERN DIVISION</b> 1276 Berleyleville Road Van Voorhis, PA 15386 (724) 258-TEST FAX: (724) 258-8376	<input type="checkbox"/>	<b>NORTHERN DIVISION</b> 435 Penn... 2050499	<input type="checkbox"/>	<b>NORTHWEST DIVISION</b> 950 Main Street Sharpville, PA 16150 (724) 463-TEST FAX: (724) 465-4209	<input type="checkbox"/>
--	-------------------------------------	---	--------------------------	--	--------------------------	---	--------------------------

Sample Identification	ESL#	Composite		Date	Grab Time	Matrix	# of Containers	Container Type <small>Preservative</small>	Analysis Requested
		Date on/off	Time on/off						
Effluent Outfall 001	2050499			5/5/02	10:00 AM	WW	1	Poly 1000mL None	CBOD, TSS
						WW	1	Poly 1000mL H2SO4	Total Nitrogen, Total Phosphorus
						WW	1	Sterile Plastic 125mL NA2S2O3	Fecal Coliform

THE UNDERSIGNED PURCHASER HEREBY AGREES TO PAY SERVICE CHARGES ON ACCOUNTS OVER 31 DAYS OLD.  
 1. THESE SERVICE CHARGES WILL ACCRUE AT THE RATE OF 1.12% PER MONTH (1.3% PER ANNUM ON THE MAXIMUM ALLOWED BY LAW);  
 2. THE UNDERSIGNED PURCHASER AGREES TO PAY, IN THE EVENT HIS ACCOUNT BECOMES DELINQUENT AND IS TURNED OVER TO ANY ATTORNEY FOR COLLECTION, REASONABLE ATTORNEY'S FEES PLUS ALL COURT AND ATTENDANT COLLECTION COSTS.

Project Notes:  
**Wastewater**

Company/Name: **MONTEAU SCHOOL DISTRICT**

Contact Person: **JEFFREY CAMPBELL**

Address: **1810 WEST SUNBURY ROAD**

Phone / Cell: **724-406-4426**

Email: **jcampbell@monteau.org**

Sampled By: (Signature) \_\_\_\_\_ Date/ Time **5/5/02 10:00 AM**

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time **5/5/02 1:05**

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time **5/5/02 1:05**

Relinquished By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Received By: (Signature) \_\_\_\_\_ Date/ Time **5/5/02 12:05**


Received By: (Signature) \_\_\_\_\_ Date/ Time **5/5/02 1:15**

Received By: (Signature) \_\_\_\_\_ Date/ Time \_\_\_\_\_

Correct Preservations Y / N / NA \_\_\_\_\_ Correct Containers Y / N / NA \_\_\_\_\_ Receipt Temperature \_\_\_\_\_



**SAMPLE RECEIPT AND REVIEW FORM**

Client: <u>Montevu</u>	Work Ord
 2050499	

**PART A: GENERAL INFORMATION - SATELLITE LABORATORY**

Received by/Lab ID: _____	Date/Time Received: / /
Method of Delivery: Client Drop-Off ESL Courier Other: _____	Received on Ice? YES NO
Sample Receipt Temperature: _____ °C	IR Gun ID: _____
Containers Removed by Satellite Lab for Analysis of: FE/CAL TC/EC TC/MPN EC/MPN TC/EC/MPN <u>N/A</u>	

**PART B: GENERAL INFORMATION - INDIANA LABORATORY**

Received by/Lab ID: <u>51/0028</u>	Samples Received on Ice? <u>YES</u> NO
Date/Time Received: <u>5/12/11 11:51 AM</u>	Date Sampled: <u>5/5/11</u>
Method of Delivery: FedEx UPS Client Drop off <u>ESL courier</u> Other: _____	IR Gun ID: <u>3</u>
Sample Receipt Temperature: <u>30</u> °C	PWSID Compliance Drinking Water Samples: YES <u>NO</u>
Sample State of Collection: <u>PA</u> NY OH WV Other: _____	

**PART C: Receipt Details** Completed (if different from above): \_\_\_\_\_ / /

Sample Receipt Criteria	YES	NO	Comments
Chain of custody documents included with samples?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
COC form is properly signed in relinquished/received sections?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Comments:
Sample containers intact and sealed?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Circle Applicable: Damaged Container Leaking Container Custody Seal Broken Other: _____
Number of containers received matches number indicated on COC?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Sample IDs on COC match IDs on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Date and time on COC match date and time on bottles?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received within holding time?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Samples received at appropriate pH for analysts requested?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected and Observed pH:
Samples requiring thermal preservation within 0 ≤ 6°C? Microbiology within 0 ≤ 10°C?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	For non-WV samples outside of thermal preservation range sampled same day and received on ice are considered acceptable as long as the cooling process has begun.
Adequate sample volume received?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Analyses Affected:
VOA vials free of headspace (defined as < 6 mm bubble)?	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Sample IDs and Containers Affected:
Other Comments:	Deficiency Log Created: YES <u>NO</u>		

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADERP: 43-04934

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADERP: 41-04880

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADERP: 63-04247

1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADERP: 32-00382



18 May 2022

Monteau School District  
 Attn: Jeffrey Campbell  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Work Order: 2050499  
 Project: Wastewater  
 Project Description: Wastewater

### Report of Analysis

Client Sample ID	Lab Sample ID	Matrix	Date Sampled	Date Received	Sample Notes
Effluent Outfall 001	2050499-01	Waste Water	05/05/2022 10:00	5/5/22 14:15	

### Report Narrative

The results contained in this report are only representative of the samples received. Environmental Service Laboratories, Inc. is not responsible for use or interpretation of the data included herein.

### Definitions

- SS Seed Control did not meet reference method acceptance criteria.
- G CBOD / BOD result may be biased low due to GGA standard falling below laboratory acceptance criteria.
- BB Dilution water blank exceeded method acceptance criteria of 0.20 mg/L DO loss.
- RL Reporting Limit
- CFU Colony Forming Units

### Certifications

Analyses performed by Environmental Service Laboratories, Inc., Indiana PA unless otherwise specified. Environmental Service Laboratories, Inc., Indiana, PA/TNI Certification #32-00382

### Approved By

*Kirsten Conoran*

Kirsten Conoran  
 Project Manager



# ENVIRONMENTAL SERVICE LABORATORIES, INC.



1803 Philadelphia Street  
 Indiana, PA 15701  
 P: (724) 463-8378  
 F: (724) 465-4209  
 PADEP: 32-00382

1276 Bentleyville Road  
 Van Voorhis, PA 15366  
 P: (724) 258-8378  
 F: (724) 258-8376  
 PADEP: 63-04247

435 Broad Street  
 Montoursville, PA 17754  
 P: (570) 321-9002  
 F: (570) 321-1957  
 PADEP: 41-04880

950 West Main Street  
 Sharpville, PA 16150  
 P: (724) 463-8378 x 500  
 F: (724) 465-4209  
 PADEP: 43-04934

Monteuan School District  
 1810 West Sunbury Road  
 West Sunbury, PA 16061

Reported: 05/18/2022 15:10

Lab Sample ID#: 2050499-01  
 Sample Type: Waste Water  
 Sample Source: Grab  
 Client: Client  
 Client Sample ID: Effluent Outfall 001

Sample Date: 05/05/2022 10:00  
 Receipt Date: 05/05/2022 14:15

Analyte	Sample	Units	Qualifier	RL	Analyst/ Certification	Prep Date/Time	Analysis Date/Time
---------	--------	-------	-----------	----	---------------------------	-------------------	-----------------------

General Chemistry	Total Nitrogen	mg/L		0.729	DAA	05/09/22 13:06	05/10/22 13:12
Analytical Method: CALC					Prep Method: [CALC]		
General Chemistry	Total Suspended Solids	mg/L		5	LMB	05/10/22 13:09	05/10/22 13:45
Analytical Method: SM2540 D-11					Prep Method: No Prep - WetChem		
General Chemistry	Total Kjeldahl Nitrogen	mg/L		0.625	DAA	05/09/22 12:20	05/10/22 13:12
Analytical Method: SM4500 NH3 E-11					Prep Method: SM 4500-Norg B		
General Chemistry	Nitrate/Nitrite	mg/L		0.104	AW	05/09/22 13:06	05/09/22 13:06
Analytical Method: SM4500-NO3 E-11 (discrete)					Prep Method: No Prep - WetChem		
General Chemistry	Phosphorus	mg/L		0.10	AW	05/13/22 14:20	05/13/22 14:20
Analytical Method: SM4500-P E-11					Prep Method: No Prep - WetChem		
General Chemistry	Carbonaceous Biochemical Oxygen Demand	mg/L	BB, G, SS	2.00	TLL	05/06/22 13:14	05/11/22 13:35
Analytical Method: SM5210 B-11					Prep Method: No Prep - WetChem		
Microbiology	Fecal Coliforms	MPN/100 mL		1	DAA	05/05/22 15:30	05/06/22 13:00
Analytical Method: Coliert-18					Prep Method: No Prep - Micro		